


FINISHED ROAD SURFACE




- NOTES:
- WHEN SIDEWALK IS CONTINUOUSLY ADJACENT, THE DROPPED CURB AT ENTRANCES IS REDUCED TO 75mm
 - FOR SLIPFORMING PROCEDURE, A 5% BATTER IS ACCEPTABLE
 - TREATMENT AT ENTRANCES SHALL BE ACCORDING TO OPSD 351.010
 - OUTLET TREATMENT SHALL BE ACCORDING TO OPSD 610 SERIES
 - THE TRANSITION FROM ONE CURB TYPE TO ANOTHER SHALL BE A MINIMUM LENGTH OF 3.0m
 - ALL DIMENSIONS ARE IN MILLIMETERS



Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

1 ISSUED FOR ADDENDUM 03 2014/02/04

revisions description date



SIR FREDERICK BANTING RESEARCH CENTRE ANIMAL TO WET LAB CONVERSION

251 SIR FREDERICK BANTING WAY, ON

drawing dessin

PARTIAL GRADING PLAN & REVISED CONCRETE CURB DETAIL

Designed By I.GIANNINI Conçu par

Date (yyyy/mm/dd)

Drawn By I.GIANNINI Dessiné par

Date 2013 02 01 (yyyy/mm/dd)

Reviewed By Examiné par

Date (yyyy/mm/dd)

Approved By Approuvé par

Date (yyyy/mm/dd)

Tender Soumission

Project Manager Administrateur de projets

Project no. No. du projet

R.044033.002

Drawing no. No. du dessin

L100-R1