

1. PART 1 – GENERAL

1.1 Related sections

- .1 Section 260500E - Common Work Results - Electrical.

1.2 Submittals

- .1 Submit product data in accordance with Section 260500E – Common Work Results – Electrical.

2. PART 2 – PRODUCTS

2.1 Disconnect switches

- .1 Fusible, non-fusible, horsepower rated disconnect switch in CSA Enclosure, EEMAC 1, 3R or 4X size as indicated.
- .2 Provision for padlocking in on-off switch position by three locks.
- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Fuseholders: relocatable and suitable without adaptors, for type and size of fuse indicated.
- .5 Quick-make, quick-break action.
- .6 ON-OFF switch position indication on switch enclosure cover.

2.2 Equipment identification

- .1 Provide equipment identification in accordance with Section 260500E - Common Work Results - Electrical.

2.3 Accredited manufacturers

- .1 Cutler-Hammer, Square-D, Siemens or G.E.

3. PART 3 – EXECUTION

3.1 Installation

- .1 Install disconnect switches complete with fuses if applicable.