

1. PART 1 – GENERAL

1.1 References

- .1 Canadian Standards Association (CSA)
 - .1 CAN/CSA C22.2 No. 18, Outlet Boxes, Conduit Boxes, and Fittings and Associated Hardware.
 - .2 CSA C22.2 No. 45, Rigid Metal Conduit.
 - .3 CSA C22.2 No. 56, Flexible Metal Conduit and Liquid Tight Flexible Metal Conduit.
 - .4 CSA C22.2 No. 83, Electrical Metallic Tubing.
 - .5 CSA C22.2 No. 211.2, Rigid PVC (Unplasticized) Conduit.
 - .6 CAN/CSA C22.2 No. 227.3, Flexible Nonmetallic Tubing.

2. PART 2 – PRODUCTS

2.1 Conduits

- .1 Rigid metal conduit: to CSA C22.2 No. 45, galvanized steel hot dipped galvanized steel aluminum threaded.
- .2 Epoxy coated conduit: to CSA C22.2 No. 45, with zinc coating and corrosion resistant epoxy finish inside and outside.
- .3 Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings with expanded ends.
- .4 Rigid PVC conduit: to CSA C22.2 No. 211.2.
- .5 Flexible metal conduit: to CSA C22.2 No. 56, steel aluminum liquid tight flexible metal.
- .6 Flexible PVC conduit: to CAN/CSA C22.2 No. 227.3.

2.2 Conduit fastenings

- .1 One hole malleable iron steel straps to secure surface conduits NPS 50 mm and smaller. Two hole steel straps for conduits larger than NPS 50 mm.
- .2 Beam clamps to secure conduits to exposed steel work.
- .3 Channel type supports for two or more conduits.
- .4 Threaded rods, 6 mm dia., to support suspended channels.
- .5 PVC spacers with stainless steel fastenings.

2.3 Conduit fittings

- .1 Fittings: manufactured for use with conduit specified. Coating: same as conduit.
- .2 Factory made elbows where 90° bends are required for NPS 1 and larger conduits.

2.4 Expansion fittings for rigid conduit

- .1 Weatherproof expansion fittings with internal bonding assembly suitable for 100 mm linear expansion.
- .2 Watertight expansion fittings with integral bonding jumper suitable for linear expansion and 19 mm deflection in all directions.
- .3 Weatherproof expansion fittings for linear expansion at entry to panel.

2.5 Fish cord

- .1 Polypropylene.

3. PART 3 – EXECUTION

3.1 General

- .1 Unless otherwise indicated, use following conduits:
 - .1 Outside:
 - ☐ galvanized steel
 - ☐ aluminum
 - ☒ PVC
 - ☐
 - .2 Encased in slab (concrete):
 - ☐ galvanized steel
 - ☒ PVC
 - .3 Dry area:
 - ☒ EMT
 - ☐ galvanized steel
 - ☐
 - .4 Damp and wet areas:
 - ☐ galvanized steel
 - ☐ aluminum
 - ☒ PVC
 - .5 Damage prone area:
 - ☒ galvanized steel

3.2 Installation

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms in unfinished areas.
- .3 Surface mount conduits except as indicated.
- .4 Use flexible metal conduit for connection to transformers, motors, and vibrating equipment.
- .5 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment in damp, wet or corrosive locations.
- .6 Bend conduit cold. Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .7 Mechanically bend steel conduit over 19 mm dia.
- .8 Field threads on rigid conduit must be of sufficient length to draw conduits up tight.
- .9 Install fish cord in empty conduits.
- .10 For each flush mounting panel board, run 2-25 mm spare conduits up to ceiling space. Terminate these conduits in 300 x 300 x 150 mm junction boxes in ceiling space.
- .11 Remove and replace blocked conduit sections. Do not use liquids to clean out conduits.
- .12 Dry conduits out before installing wire.
- .13 For PVC conduits, install dilatation fittings in accordance with manufacture's instructions.
- .14 Install green wire of required rating in all conduits.

3.3 Surface conduits

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.
- .3 Run conduits in flanged portion of structural steel.
- .4 Group conduits wherever possible on suspended surface channels.
- .5 Do not pass conduits through structural members except as indicated.
- .6 Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.
- .7 In food areas, install conduits on spacers for clearance from walls and ceilings.

3.4 Concealed conduits

- .1 Run parallel or perpendicular to building lines.
- .2 Do not install horizontal runs in masonry walls.
- .3 Do not install conduits in terrazzo or concrete toppings.

3.5 Underground conduits

- .1 Slope conduits to provide drainage.
- .2 Waterproof joints (PVC excepted) with heavy coat of bituminous paint.