



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS À:

**Parks Canada Agency – Bids Receiving**  
**111 Water Street**  
**Cornwall, ON, K6H 6S3**  
**Bid Fax: (613) 938-5785**

AMENDMENT#2 TO INVITATION TO

TENDER

MODIFICATION#2 D'APPEL D'OFFRES

**Tender To: Parks Canada Agency**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor.

**Soumission aux: l'Agence Parcs Canada**

Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

**Comments - Commentaries**

Vendor/Firm Name and Address

Raison sociale et adresse du fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Parks Canada Agency  
 CFOD – Contracting Operations  
 111 Water St.  
 Cornwall, ON K6H 6S3

Title-Sujet <b>Building Renovations at Ottawa Lockstation</b>		Date <b>Feb 7, 2014</b>
Solicitation No. - No. de l'invitation <b>10131328</b>	Client Ref. No. – No. de réf du client.	
GETS Reference No. – No de reference de SEAG		
Solicitation Closes L'invitation prend fin –  <b>at – à 02:00 PM on – le Feb 14, 2014</b>	Time Zone Fuseau horaire -  <b>Eastern Time</b>	
F.O.B. - F.A.B. <b>Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/></b>		
Address Inquiries to: - Adresser toute demande de renseignements à :  <b>dale.rudderham@pc.gc.ca</b>		
Telephone No. - No de téléphone <b>(613) 938-5751</b>	Fax No. – No de FAX: <b>(613 ) 938-5785</b>	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction:  <b>See Herein</b>		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature	Date	

## 10131328 Amendment#2

This amendment gives effect to the following changes:

1. **Delete** original tender drawings dated 13.01.14 issued for tender

**And Replace with:** drawings REVISED FOR TENDER dated 06.02.14.

2. **Delete demolition and removal of interior materials. Removal and replacement of concrete flooring remain Contractor's responsibility.**
3. **Delete supplying D.Fir timber required for beams and posts in new visitor gallery and north vestibule. Parks Canada will supply and deliver D.Fir timber for beams and posts.**
4. **Supplementary viewing:**

The building will be open Monday, February 10, from approximately 10:00 am until 4:00 pm to allow contractors and/or subcontractors the opportunity to visit the site. Departmental representative will be on site from noon until 4:00 pm. Demolition by Parks Staff will be in progress, bring appropriate safety gear (hard hat, safety glasses, steel toe boots, etc)

### 5. QUESTIONS AND ANSWERS:

**Q1. Will there be a fixture spec?**

A2. Do not carry any cost for the supply of light fixtures, only installation. Parks Canada to provide light fixtures.

**Q2. What is the incoming electrical service?**

A2. Electrical service to building is 600 volt, 150 amp. The approximate location of electrical service and breakers to isolate building are shown on drawing A1 – Partial Site Plan.

**Q3. Is the Contractor responsible for heating the space?**

A3. The Contractor is responsible to maintain minimum temperature in building to prevent freezing of existing water pipes, etc.

**Q4. Is there parking available?**

A4. Location of areas for use as parking, material storage, garbage bins, etc. have been added to drawing A1 – Partial Site Plan. Due to concurrent construction activities unknown at time of job showing, parking at Bytown museum may not be allowed. Special arrangements for additional space can

be made under the Rideau Street bridge but is dependent on NCC approval and therefore may not be possible.

**Q5. What else, if anything, is powered from the lockstation building? (exterior lighting, etc)**

A5. Currently there is no power supplied from the building to exterior lights etc.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**