

## PART 1 - GENERAL

### 1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.1-12, Canadian Electrical Code, Part 1 (22nd Edition), Safety Standard for Electrical Installations.
  - .2 CSA C22.2.
  - .3 CAN/CSA-C22.3 No. 1-01(Update March 2005), Overhead Systems.
  - .4 CAN3-C235-83(R2000), Preferred Voltage Levels for AC Systems, 0 to 50,000 V.
- .2 Electrical and Electronic Manufacturer's Association of Canada (EEMAC)
  - .1 EEMAC 2Y-1-1958, Light Gray Colour for Indoor Switch Gear.
- .3 Institute of Electrical and Electronics (IEEE)/National Electrical Safety Code Product Line (NESC)
  - .1 IEEE SP1122-2000, The Authoritative Dictionary of IEEE Standards Terms, 7th Edition.

### 1.2 DEFINITIONS

- .1 Electrical and electronic terms: unless otherwise specified or indicated, terms used in these specifications, and on drawings, are those defined by IEEE SP1122.

### 1.3 DESIGN REQUIREMENTS

- .1 Operating voltages: to CAN3-C235.
- .2 Motors, electric heating, control and distribution devices and equipment to operate satisfactorily at 60 Hz within normal operating limits established by above standard.
  - .1 Equipment to operate in extreme operating conditions established in above standard without damage to equipment.
- .3 Language operating requirements: provide identification nameplates for control items in English and French.
- .4 Use one nameplate for both languages.
- .5 All equipment and materials indicated to be new unless otherwise noted.

1.4 ACTION AND  
INFORMATIONAL  
SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data: submit WHMIS MSDS in accordance with Section 01 00 10 - General Instructions.
- .3 Shop drawings:
  - .1 Submit drawings stamped and signed by professional engineer registered or licensed in Province of Ontario, Canada.
  - .2 Submit wiring diagrams and installation details of equipment indicating proposed location, layout and arrangement, control panels, accessories, piping, ductwork, and other items that must be shown to ensure co-ordinated installation.
  - .3 Identify on wiring diagrams circuit terminals and indicate internal wiring for each item of equipment and interconnection between each item of equipment.
  - .4 Indicate of drawings clearances for operation, maintenance, and replacement of operating equipment devices.
  - .5 Submit six copies of 600 x 600 mm minimum size drawings and product data to Engineer.
  - .6 If changes are required, notify Departmental Representative of these changes before they are made.
- .4 Quality Control: in accordance with Section 01 00 10 - General Instructions.
  - .1 Provide CSA certified equipment and material.
  - .2 Where CSA certified equipment and material is not available, submit such equipment and material to inspection authorities for approval before delivery to site.
  - .3 Submit test results of installed electrical systems and instrumentation.
  - .4 Permits and fees: in accordance with General Conditions of contract.
  - .5 Submit, upon completion of Work, load balance report as described in PART 3 - LOAD BALANCE.
  - .6 Submit certificate of acceptance from authority having jurisdiction upon completion of Work to Departmental Representative.
- .5 Manufacturer's Field Reports: submit to Departmental Representative manufacturer's written report, within 3 days of review, verifying compliance of Work and electrical system and instrumentation testing, as described in PART 3 - FIELD QUALITY CONTROL.

### 1.5 QUALITY ASSURANCE

- .1 Quality Assurance: in accordance with Section 01 00 10 - General Instructions.
- .2 Qualifications: electrical Work to be carried out by qualified, licensed electricians who hold valid Master Electrical Contractor license or apprentices in accordance with authorities having jurisdiction as per the conditions of Provincial Act respecting manpower vocational training and qualification.
  - .1 Employees registered in provincial apprentices program: permitted, under direct supervision of qualified licensed electrician, to perform specific tasks.
  - .2 Permitted activities: determined based on training level attained and demonstration of ability to perform specific duties.
- .3 Site Meetings:
  - .1 In accordance with Section 01 00 10 - General Instructions.
  - .2 Site Meetings: as part of Manufacturer's Field Services described in Part 3 - FIELD QUALITY CONTROL, and in appropriate NMS Section, schedule site visits, to review Work, at stages listed.
    - .1 After delivery and storage of products, and when preparatory Work is complete but before installation begins.
    - .2 Twice during progress of Work at 25% and 60% complete.
    - .3 Upon completion of Work, after cleaning is carried out.
- .4 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.

### 1.6 DELIVERY, STORAGE AND HANDLING

- .1 Material Delivery Schedule: provide Departmental Representative with schedule within 2 weeks after award of Contract.
- .2 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

- 1.7 SYSTEM STARTUP
- .1 Instruct Departmental Representative and operating personnel in operation, care and maintenance of systems, system equipment and components.
  - .2 Arrange and pay for services of manufacturer's factory service engineer to supervise start-up of installation, check, adjust, balance and calibrate components and instruct operating personnel.
  - .3 Provide these services for such period, and for as many visits as necessary to put equipment in operation, and ensure that operating personnel are conversant with aspects of its care and operation.
- 1.8 OPERATING INSTRUCTIONS
- .1 Provide for each system and principal item of equipment as specified in technical sections for use by operation and maintenance personnel.
  - .2 Operating instructions to include following:
    - .1 Wiring diagrams, control diagrams, and control sequence for each principal system and item of equipment.
    - .2 Start up, proper adjustment, operating, lubrication, and shutdown procedures.
    - .3 Safety precautions.
    - .4 Procedures to be followed in event of equipment failure.
    - .5 Other items of instruction as recommended by manufacturer of each system or item of equipment.
  - .3 Print or engrave operating instructions and frame under glass or in approved laminated plastic.
  - .4 Post instructions where directed.
  - .5 For operating instructions exposed to weather, provide weather-resistant materials or weatherproof enclosures.
  - .6 Ensure operating instructions will not fade when exposed to sunlight and are secured to prevent easy removal or peeling.

PART 2 - PRODUCTS

- 2.1 SUSTAINABLE REQUIREMENTS
- .1 Materials and products in accordance with Section 01 00 10 - General Instructions.

- .2 Do verification requirements in accordance with Section 01 00 10 - General Instructions: Contractor's Verification.

## 2.2 MATERIALS AND EQUIPMENT

- .1 Provide material and equipment in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Material and equipment to be CSA certified. Where CSA certified material and equipment are not available, obtain special approval from inspection authorities before delivery to site and submit such approval as described in PART 1 - SUBMITTALS.
- .3 Factory assemble control panels and component assemblies.

## 2.3 ELECTRIC MOTORS, EQUIPMENT AND CONTROLS

- .1 Verify installation and co-ordination responsibilities related to motors, equipment and controls, as indicated.
- .2 Control wiring and conduit: by electrical contractor except for conduit, wiring and connections below 50 V which are related to control systems specified in mechanical sections and as shown on mechanical drawings.

## 2.4 WARNING SIGNS

- .1 Warning Signs: in accordance with requirements of authority having jurisdiction, inspection authorities and Departmental Representative.
- .2 Decal signs, minimum size 175 x 250 mm.

## 2.5 WIRING TERMINATIONS

- .1 Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

## 2.6 EQUIPMENT IDENTIFICATION

- .1 Identify electrical equipment with nameplates and labels as follows:
  - .1 Nameplates: lamicaid 3 mm melamine, matt white finish face, black core, lettering accurately aligned and engraved into core mechanically attached with self tapping screws.

.2      Sizes as follows:

| <u>NAMEPLATE SIZES</u> |             |         |                    |
|------------------------|-------------|---------|--------------------|
| Size 1                 | 10 x 50 mm  | 1 line  | 3 mm high letters  |
| Size 2                 | 12 x 70 mm  | 1 line  | 5 mm high letters  |
| Size 3                 | 12 x 70 mm  | 2 lines | 3 mm high letters  |
| Size 4                 | 20 x 90 mm  | 1 line  | 8 mm high letters  |
| Size 5                 | 20 x 90 mm  | 2 lines | 5 mm high letters  |
| Size 6                 | 25 x 100 mm | 1 line  | 12 mm high letters |
| Size 7                 | 25 x 100 mm | 2 lines | 6 mm high letters  |

- .2      Labels: embossed plastic labels with 6mm high letters unless specified otherwise.
- .3      Wording on nameplates and labels to be approved by Departmental Representative prior to manufacture.
- .4      Allow for minimum of twenty-five (25) letters per nameplate and label.
- .5      Nameplates for terminal cabinets and junction boxes to indicate system and/or voltage characteristics.
- .6      Identify equipment with Size 3 labels engraved "ASSET INVENTORY NO. " as directed by Departmental Representative.
- .7      Disconnects, starters and contactors: indicate equipment being controlled and voltage.
- .8      Terminal cabinets and pull boxes: indicate system and voltage.
- .9      Transformers: indicate capacity, primary and secondary voltages.

## 2.7 WIRING IDENTIFICATION

- .1      Identify wiring with permanent indelible identifying markings, coloured plastic tapes, on both ends of phase conductors of feeders and branch circuit wiring.
- .2      Maintain phase sequence and colour coding throughout.
- .3      Colour coding: to CSA C22.1.

- .4 Use colour coded wires in communication cables, matched throughout system.

## 2.8 CONDUIT AND CABLE IDENTIFICATION

---

- .1 Colour code conduits, boxes and metallic sheathed cables.
- .2 Code with plastic tape or paint at points where conduit or cable enters wall, ceiling, or floor, and at 15 m intervals.
- .3 Colours: 25 mm wide prime colour and 20 mm wide auxiliary colour.

|                             | Prime  | Auxiliary |
|-----------------------------|--------|-----------|
| up to 250 V                 | Yellow |           |
| up to 600 V                 | Yellow | Green     |
| Telephone                   | Green  |           |
| Other Communication Systems | Green  | Blue      |
| Fire Alarm                  | Red    |           |
| Emergency Voice             | Red    | Blue      |
| Other Security Systems      | Red    | Yellow    |

## 2.9 FINISHES

---

- .1 Shop finish metal enclosure surfaces by application of rust resistant primer inside and outside, and at least two coats of finish.
- .1 Paint outdoor electrical equipment "equipment green" finish.
- .2 Paint indoor switchgear and distribution enclosures light gray to EEMAC 2Y-1.

## PART 3 - EXECUTION

---

### 3.1 INSTALLATION

---

- .1 Do complete installation in accordance with CSA C22.1 except where specified otherwise.
- .2 Do overhead and underground systems in accordance with CSA C22.3 No.1 except where specified otherwise.

### 3.2 NAMEPLATES AND LABELS

- .1 Ensure manufacturer's nameplates, CSA labels and identification nameplates are visible and legible after equipment is installed.

### 3.3 CONDUIT AND CABLE INSTALLATION

- .1 If plastic sleeves are used in fire rated walls or floors, remove before conduit installation.
- .2 Install cables, conduits and fittings embedded or plastered over, close to building structure so furring can be kept to minimum.

### 3.4 LOCATION OF OUTLETS

- .1 Locate outlets in accordance with Section 26 05 32 - Outlet Boxes, Conduit Boxes and Fittings.
- .2 Do not install outlets back-to-back in wall; allow minimum 150 mm horizontal clearance between boxes.
- .3 Change location of outlets at no extra cost or credit, providing distance does not exceed 3000 mm, and information is given before installation.
- .4 Locate light switches on latch side of doors.
  - .1 Locate disconnect devices in mechanical and elevator machine rooms on latch side of floor.

### 3.5 MOUNTING HEIGHTS

- .1 Mounting height of equipment is from finished floor to centreline of equipment unless specified or indicated otherwise.
- .2 If mounting height of equipment is not specified or indicated, verify before proceeding with installation.
- .3 Install electrical equipment at following heights unless indicated otherwise.
  - .1 Local switches: 1200 mm.
  - .2 Wall receptacles:
    - .1 General: 400 mm.
    - .2 Above top of continuous baseboard heater: 200 mm.
    - .3 Above top of counters or counter splash backs: 175 mm.
    - .4 In mechanical rooms: 1200 mm.
  - .3 Telephone and interphone outlets: 400 mm.
  - .4 Wall mounted telephone and interphone outlets: 1200 mm.
  - .5 Fire alarm stations: 1200 mm.



- .6 Television outlets: 400 mm.
- .7 Wall mounted fire alarm speakers: 2100 mm.

### 3.6 CO-ORDINATION OF PROTECTIVE DEVICES

- .1 Ensure circuit protective devices such as overcurrent trips, relays and fuses are installed to required values and settings.

### 3.7 FIELD QUALITY CONTROL

- .1 Load Balance:
  - .1 Measure phase current to panelboards with normal loads (lighting) operating at time of acceptance; adjust branch circuit connections as required to obtain best balance of current between phases and record changes.
  - .2 Measure phase voltages at loads and adjust transformer taps to within 2% of rated voltage of equipment.
  - .3 Provide upon completion of work, load balance report as directed in PART 1 - SUBMITTALS: phase and neutral currents on panelboards, dry-core transformers and motor control centres, operating under normal load, as well as hour and date on which each load was measured, and voltage at time of test.
- .2 Conduct following tests in accordance with Section 01 00 10 - General Instructions.
  - .1 Power generation and distribution system including phasing, voltage, grounding and load balancing.
  - .2 Circuits originating from branch distribution panels.
  - .3 Lighting and its control.
  - .4 Motors, heaters and associated control equipment including sequenced operation of systems where applicable.
  - .5 Systems: fire alarm system.
  - .6 Insulation resistance testing:
    - .1 Megger circuits, feeders and equipment up to 350 V with a 500 V instrument.
    - .2 Megger 350-600 V circuits, feeders and equipment with a 1000 V instrument.
    - .3 Check resistance to ground before energizing.
- .3 Carry out tests in presence of Departmental Representative.
- .4 Provide instruments, meters, equipment and personnel required to conduct tests during and at conclusion of project.

- .5 Manufacturer's Field Services:
  - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
  - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
  - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

### 3.8 CLEANING

- .1 Clean and touch up surfaces of shop-painted equipment scratched or marred during shipment or installation, to match original paint.
- .2 Clean and prime exposed non-galvanized hangers, racks and fastenings to prevent rusting.

### 3.9 DEMOLITION

- .1 Full extent of demolition is not illustrated on drawings. Disconnect and remove all equipment located on existing ceilings and walls to be demolished. Remove wiring and conduit formerly serving demolished equipment back to source. Remove from site unless otherwise noted.
- .2 Reconnect any existing loads which do not appear on panel details and which are to be re-used.
- .3 Maintain electrical services and systems at all times to areas beyond the construction area. Reinstate immediately any existing services disrupted during demolition not intended to be removed as part of this contract.

END OF SECTION

## PART 1 - GENERAL

### 1.1 REFERENCES

- .1 CSA International
  - .1 CAN/CSA-C22.2 No.18-98(R2003), Outlet Boxes, Conduit Boxes and Fittings.
  - .2 CAN/CSA-C22.2 No.65-03(R2008), Wire Connectors (Tri-National Standard with UL 486A-486B and NMX-J-543-ANCE-03).
- .2 Electrical and Electronic Manufacturers' Association of Canada (EEMAC)
  - .1 EEMAC 1Y-2-1961, Bushing Stud Connectors and Aluminum Adapters (1200 Ampere Maximum Rating).
- .3 National Electrical Manufacturers Association (NEMA)

### 1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for wire and box connectors and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Sustainable Design Submittals:
  - .1 Construction Waste Management:
    - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
    - .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating % of construction wastes recycled or salvaged.

### 1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wire and box connectors for incorporation into manual.

1.4 DELIVERY,  
STORAGE AND  
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
  - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect wire and box connectors from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 MATERIALS

- .1 Pressure type wire connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors as required.
- .2 Fixture type splicing connectors to: CAN/CSA-C22.2 No.65, with current carrying parts of copper sized to fit copper conductors 10 AWG or less.
- .3 Clamps or connectors for armoured cable, flexible conduit, as required to: CAN/CSA-C22.2 No.18.

### PART 3 - EXECUTION

- 3.1 EXAMINATION
- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wire and box connectors installation in accordance with manufacturer's written instructions.
    - .1 Visually inspect substrate in presence of Departmental Representative.
    - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
    - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.
- 3.2 INSTALLATION
- .1 Remove insulation carefully from ends of conductors and cables and:
    - .1 Apply coat of zinc joint compound on aluminum conductors prior to installation of connectors.
    - .2 Install mechanical pressure type connectors and tighten screws with appropriate compression tool recommended by manufacturer. Installation shall meet secureness tests in accordance with CAN/CSA-C22.2 No.65.
    - .3 Install fixture type connectors and tighten to CAN/CSA-C22.2 No.65. Replace insulating cap.
- 3.3 CLEANING
- .1 Progress Cleaning: clean in accordance with Section 01 00 10 - General Instructions.
    - .1 Leave Work area clean at end of each day.
  - .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 00 10 - General Instructions.
  - .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
    - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

PART 1 - GENERAL

- |   |    |  |
|---|----|--|
| <u>1.1 PRODUCT DATA</u>                   | .1 | Provide product data in accordance with Section 01 33 00 - Submittal Procedures.   |
| <u>1.2 DELIVERY, STORAGE AND HANDLING</u> | .1 | Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal. |

PART 2 - PRODUCTS

- |                            |    |  |
|----------------------------|----|--|
| <u>2.1 BUILDING WIRES</u>  | .1 | Conductors: stranded for 10 AWG and larger. Minimum size: 12 AWG.  |
|                            | .2 | Copper conductors: size as indicated, with 600 V insulation of cross-linked thermosetting polyethylene material rated RW90 XLPE, Jacketted.  |
| <u>2.2 ARMOURED CABLES</u> | .1 | Conductors: insulated, copper, size as indicated.  |
|                            | .2 | Type: AC90.  |
|                            | .3 | Armour: interlocking type fabricated from aluminum strip.  |
|                            | .4 | Connectors: anti short connectors.   |
| <u>2.3 CONTROL CABLES</u>  | .1 | Type: LVT: 2 soft annealed copper conductors, sized as indicated:<br>.1 Insulation: thermoplastic.<br>.2 Sheath : thermoplastic jacket, FT-6 |
|                            | .2 | Type: 600 V solid annealed copper conductors, minimum size 16 AWG in conduit.  |
|                            | .3 | Fire alarm and signal cables: type FAS90.  |

### PART 3 - EXECUTION

#### 3.1 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.

#### 3.2 GENERAL CABLE INSTALLATION

- .1 Terminate cables in accordance with Section 26 05 20 - Wire and Box Connectors - (0-1000 V).
- .2 Cable Colour Coding: to Section 26 05 00 - Common Work Results for Electrical.
- .3 Conductor length for parallel feeders to be identical.
- .4 Lace or clip groups of feeder cables at distribution centres, pull boxes, and termination points.
- .5 Wiring in walls: typically drop or loop vertically from above to better facilitate future renovations. Generally wiring from below and horizontal wiring in walls to be avoided unless indicated.
- .6 Branch circuit wiring for permanently wired computer and electronic equipment, dimmed lighting and dedicated circuits to be 2-wire circuits only, i.e. common neutrals not permitted.
- .7 Provide numbered wire collars for control wiring. Numbers to correspond to control shop drawing legend. Obtain wiring diagram for control wiring.

#### 3.3 INSTALLATION OF BUILDING WIRES

- .1 Install wiring as follows:
  - .1 In conduit systems in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.

3.4 INSTALLATION OF  
ARMOURED CABLES

- .1 Group cables wherever possible on channels.
- .2 Maximum length: 3 meters.

3.5 INSTALLATION OF  
CONTROL CABLES

- .1 Install control cables in conduit.
- .2 Ground control cable shield.

END OF SECTION



PART 1 - GENERAL1.1 REFERENCES

- .1 American National Standards Institute /Institute of Electrical and Electronics Engineers ( ANSI/IEEE )
  - .1 ANSI/IEEE 837-02, IEEE Standard for Qualifying Permanent Connections Used in Substation Grounding.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for grounding equipment and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Sustainable Design Submittals:
  - .1 Construction Waste Management:
    - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
    - .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating % of construction wastes recycled or salvaged.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for grounding equipment for incorporation into manual.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.

- .3 Storage and Handling Requirements:
  - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect grounding equipment from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## PART 2 - PRODUCTS

### 2.1 EQUIPMENT

- .1 Clamps for grounding of conductor: size as required.
- .2 Grounding conductors: bare stranded copper, soft annealed, size as indicated.
- .3 Insulated grounding conductors: green, copper conductors, size as indicated.
- .4 Non-corroding accessories necessary for grounding system, type, size, material as indicated, including but not necessarily limited to:
  - .1 Grounding and bonding bushings.
  - .2 Protective type clamps.
  - .3 Bolted type conductor connectors.
  - .4 Bonding jumpers, straps.
  - .5 Pressure wire connectors.

## PART 3 - EXECUTION

### 3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for grounding equipment installation in accordance with manufacturer's written instructions.

- .1 Visually inspect substrate in presence of Departmental Representative.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

### 3.2 INSTALLATION GENERAL

- .1 Install complete permanent, continuous grounding system including, conductors, connectors, accessories. Where EMT is used, run ground wire in conduit.
- .2 Install connectors in accordance with manufacturer's instructions.
- .3 Protect exposed grounding conductors from mechanical injury.
- .4 Use mechanical connectors for grounding connections to equipment provided with lugs.
- .5 Soldered joints not permitted.
- .6 Install bonding wire for flexible conduit, connected at both ends to grounding bushing, solderless lug, clamp or cup washer and screw. Neatly cleat bonding wire to exterior of flexible conduit.
- .7 Make grounding connections in radial configuration only, with connections terminating at single grounding point. Avoid loop connections.
- .8 Bond single conductor, metallic armoured cables to cabinet at supply end, and load end.

### 3.3 SYSTEM AND CIRCUIT GROUNDING

- .1 Install system and circuit grounding connections to neutral of, secondary system.

### 3.4 EQUIPMENT GROUNDING

- .1 Install grounding connections to typical equipment included in, but not necessarily limited to following list. Service equipment, transformers,

switchgear, duct systems, frames of motors, motor control centres, starters, control panels, building steel work, generators, elevators and escalators, distribution panels, outdoor lighting, cable trays.

### 3.5 FIELD QUALITY CONTROL

- .1 Perform tests in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Perform ground continuity and resistance tests using method appropriate to site conditions and to approval of Departmental Representative and local authority having jurisdiction over installation.
- .3 Perform tests before energizing electrical system.
- .4 Disconnect ground fault indicator during tests.

### 3.6 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 00 10 - General Instructions.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 00 10 - General Instructions.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
  - .1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

END OF SECTION

## PART 1 - GENERAL

### 1.1 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate and recycle waste materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .2 Remove from site and dispose of all packaging materials at appropriate recycling facilities.
- .3 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .4 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative.
- .5 Fold up metal banding, flatten and place in designated area for recycling.

## PART 2 - PRODUCTS

### 2.1 SUPPORT CHANNELS

- .1 U shape, size 41 x 41 mm, 2.5 mm thick, surface mounted.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- .1 Secure equipment to masonry, tile and plaster surfaces with nylon shields.
- .2 Secure equipment to poured concrete with expandable inserts.
- .3 Secure equipment to hollow masonry walls or suspended ceilings with toggle bolts.
- .4 Secure surface mounted equipment with twist clip fasteners to inverted T bar ceilings. Ensure that T bars are adequately supported to carry weight of equipment specified before installation.
- .5 Support equipment, conduit or cables using clips, spring loaded bolts, cable clamps designed as accessories to basic channel members.

- .6 Fasten exposed conduit or cables to building construction or support system using straps.
  - .1 One-hole steel straps to secure surface conduits and cables 50 mm and smaller.
  - .2 Two-hole steel straps for conduits and cables larger than 50 mm.
  - .3 Beam clamps to secure conduit to exposed steel work.
- .7 Suspended support systems.
  - .1 Support individual cable or conduit runs with 6 mm diameter threaded rods and spring clips.
  - .2 Support 2 or more cables or conduits on channels supported by 6 mm diameter threaded rod hangers where direct fastening to building construction is impractical.
- .8 Provide metal brackets, frames, hangers, clamps and related types of support structures where indicated or as required to support conduit and cable runs.
- .9 Ensure adequate support for raceways and cables dropped vertically to equipment where there is no wall support.
- .10 Do not use wire lashing or perforated strap to support or secure raceways or cables.
- .11 Do not use supports or equipment installed for other trades for conduit or cable support except with permission of other trade and approval of Departmental Representative.
- .12 Install fastenings and supports as required for each type of equipment cables and conduits, and in accordance with manufacturer's installation recommendations.

END OF SECTION

## PART 1 - GENERAL

- |  |    |  |
|--|----|--|
| <u>1.1 REFERENCES</u>                                  | .1 | Canadian Standards Association (CSA International)<br>.1 CSA C22.1 Canadian Electrical Code, Part 1.   |
| <u>1.2 ACTION AND<br/>INFORMATIONAL<br/>SUBMITTALS</u> | .1 | Provide submittals in accordance with Section<br>01 33 00 - Submittal Procedures.  |
|  | .2 | Product Data:<br>.1 Provide manufacturer's printed product<br>literature, specifications and datasheet and<br>include product characteristics, performance<br>criteria, physical size, finish and limitations. |
|  | .3 | Provide shop drawings: in accordance with Section<br>01 33 00 - Submittal Procedures.  |
| <u>1.3 DELIVERY,<br/>STORAGE AND<br/>HANDLING</u>      | .1 | Waste Management and Disposal:<br>.1 Separate waste materials for reuse and<br>recycling in accordance with Section 01 74 21 -<br>Construction/Demolition Waste Management and<br>Disposal.                    |

## PART 2 - PRODUCTS

- |  |    |  |
|--|----|--|
| <u>2.1 JUNCTION AND<br/>PULL BOXES</u> | .1 | Construction: welded steel enclosure.  |
|  | .2 | Covers Flush Mounted: 25 mm minimum extension all<br>around.   |
|  | .3 | Covers Surface Mounted: screw-on flat covers.  |
| <u>2.2 CABINETS</u>                    | .1 | Construction: welded sheet steel hinged door,<br>handle, latch lock 2 keys and catch.  |
|  | .2 | Type E Empty: surface return flange flush<br>overlapping sides mounting as indicated.  |
|  | .3 | Type T Terminal: surface return flange flush<br>overlapping sides mounting as indicated containing<br>19 mm G1S plywood backboard. |

### PART 3 - EXECUTION

- |   |    |  |
|---|----|--|
| 3.1 JUNCTION, PULL<br>BOXES AND CABINETS<br><u>INSTALLATION</u> | .1 | Install pull boxes in inconspicuous but accessible locations.  |
|   | .2 | Mount cabinets with top not higher than 2 m above finished floor except where indicated otherwise.       |
|   | .3 | Install terminal block as indicated in Type T cabinets.  |
|   | .4 | Only main junction and pull boxes are indicated. Install additional pull boxes as required by CSA C22.1. |
| 3.2 IDENTIFICATION  | .1 | Equipment Identification: to Section 26 05 00-Common Work Results for Electrical .                       |
|   | .2 | Identification Labels: size 2 indicating system name voltage and phase or as indicated.                  |

END OF SECTION



## PART 1 - GENERAL

|  |    |   |
|--|----|---|
| <u>1.1 REFERENCES</u>                                  | .1 | Canadian Standards Association (CSA International)<br>.1 CSA C22.1 Canadian Electrical Code, Part 1.  |
| <u>1.2 ACTION AND<br/>INFORMATIONAL<br/>SUBMITTALS</u> | .1 | Provide submittals in accordance with Section<br>01 33 00 - Submittal Procedures.   |
|  | .2 | Submit samples for floor box in accordance with<br>Section 01 33 00 - Submittal Procedures.   |
| <u>1.3 DELIVERY,<br/>STORAGE AND<br/>HANDLING</u>      | .1 | Deliver, store and handle materials in accordance<br>with Section 01 61 00 - Common Product<br>Requirements.  |
|  | .2 | Waste Management and Disposal:<br>.1 Separate waste materials for reuse and<br>recycling in accordance with Section 01 74 21 -<br>Construction/Demolition Waste Management and<br>Disposal. |

## PART 2 - PRODUCTS

|   |    |  |
|---|----|--|
| <u>2.1 OUTLET AND<br/>CONDUIT BOXES<br/>GENERAL</u> | .1 | Size boxes in accordance with CSA C22.1.   |
|   | .2 | 102 mm square or larger outlet boxes as required.                                      |
|   | .3 | Gang boxes where wiring devices are grouped.   |
|   | .4 | Blank cover plates for boxes without wiring<br>devices.                                |
|   | .5 | 347 V outlet boxes for 347 V switching devices.  |
|   | .6 | Combination boxes with barriers where outlets for<br>more than one system are grouped. |
| <u>2.2 GALVANIZED<br/>STEEL OUTLET BOXES</u>        | .1 | One-piece electro-galvanized construction.   |

- .2 Single and multi gang flush device boxes for flush installation, minimum size 76 x 50 x 38 mm or as indicated. 102 mm square outlet boxes when more than one conduit enters one side with extension and plaster rings as required.
- .3 Utility boxes for outlets connected to surface-mounted EMT conduit, minimum size 102 x 54 x 48 mm.
- .4 102 mm square or octagonal outlet boxes for lighting fixture outlets.
- .5 Extension and plaster rings for flush mounting devices in finished plaster, or tile walls.

#### 2.3 MASONRY BOXES

- .1 Electro-galvanized steel masonry single and multi gang boxes for devices flush mounted in exposed block walls.

#### 2.4 CONCRETE BOXES

- .1 Electro-galvanized sheet steel concrete type boxes for flush mount in concrete with matching extension and plaster rings as required.

#### 2.5 FLOOR BOXES

- .1 Electro-galvanized sheet steel floor boxes with adjustable finishing rings to suit raised floor finish with faceplate. Device mounting plate to accommodate short or long ear duplex receptacles. Minimum depth: 73 mm for receptacles and communication outlets.

#### 2.6 CONDUIT BOXES

- .1 Cast FS or FD boxes with factory-threaded hubs and mounting feet for surface wiring of devices.

#### 2.7 FITTINGS - GENERAL

- .1 Bushing and connectors with nylon insulated throats.
- .2 Knock-out fillers to prevent entry of debris.
- .3 Conduit outlet bodies for conduit up to 35 mm and pull boxes for larger conduits.
- .4 Double locknuts and insulated bushings on sheet metal boxes.

### PART 3 - EXECUTION

#### 3.1 INSTALLATION

- .1 Support boxes independently of connecting conduits.
- .2 Fill boxes with paper, sponges or foam or similar approved material to prevent entry of debris during construction. Remove upon completion of work.
- .3 For flush installations mount outlets flush with finished wall using plaster rings to permit wall finish to come within 6 mm of opening.
- .4 Provide correct size of openings in boxes for conduit, mineral insulated and armoured cable connections. Do not install reducing washers.
- .5 Vacuum clean interior of outlet boxes before installation of wiring devices.
- .6 Identify systems for outlet boxes as required.

END OF SECTION

PART 1 - GENERAL

1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
  - .1 CAN/CSA C22.2 No. 18-98(R2003), Outlet Boxes, Conduit Boxes, Fittings and Associated Hardware, A National Standard of Canada.
  - .2 CSA C22.2 No. 56-04, Flexible Metal Conduit and Liquid-Tight Flexible Metal Conduit.
  - .3 CSA C22.2 No. 83-M1985(R2003), Electrical Metallic Tubing.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product data: submit manufacturer's printed product literature, specifications and datasheets.
  - .1 Submit cable manufacturing data.
- .3 Quality assurance submittals:
  - .1 Test reports: submit certified test reports.
  - .2 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
  - .3 Instructions: submit manufacturer's installation instructions.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Place materials defined as hazardous or toxic waste in designated containers.
- .3 Ensure emptied containers are sealed and stored safely for disposal away from children.

PART 2 - PRODUCTS

2.1 CABLES AND REELS

- .1 Provide cables on reels or coils.
  - .1 Mark or tag each cable and outside of each reel or coil, to indicate cable length, voltage rating, conductor size, and manufacturer's lot number and reel number.

- .2    Each coil or reel of cable to contain only one continuous cable without splices.
- .3    Identify cables for exclusively dc applications.

## 2.2 CONDUITS

- .1    Electrical metallic tubing (EMT): to CSA C22.2 No. 83, with couplings.
- .2    Flexible metal conduit: to CSA C22.2 No. 56, aluminum liquid-tight flexible metal.

## 2.3 CONDUIT FASTENINGS

- .1    One hole steel straps to secure surface conduits 50 mm and smaller.
  - .1    Two hole steel straps for conduits larger than 50 mm.
- .2    Beam clamps to secure conduits to exposed steel work.
- .3    Channel type supports for two or more conduits.
- .4    Threaded rods, 6 mm diameter, to support suspended channels.

## 2.4 CONDUIT FITTINGS

- .1    Fittings: to CAN/CSA C22.2 No. 18, manufactured for use with conduit specified. Coating: same as conduit.
- .2    Ensure factory "ells" where 90 degrees bends for 25 mm and larger conduits.
- .3    Watertight connectors and couplings for EMT.
  - .1    Set-screws are not acceptable.

## 2.5 FISH CORD

- .1    Polypropylene.

### PART 3 - EXECUTION

#### 3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

#### 3.2 INSTALLATION

- .1 Install conduits to conserve headroom in exposed locations and cause minimum interference in spaces through which they pass.
- .2 Conceal conduits except in mechanical and electrical service rooms and in unfinished areas.
- .3 Use electrical metallic tubing (EMT) except where specified otherwise.
- .4 Use flexible metal conduit for connection to motors in dry areas.
- .5 Use liquid tight flexible metal conduit for connection to motors or vibrating equipment in damp, wet or corrosive locations, and for branch connections to wiring devices from local junction boxes under raised floor.
- .6 Minimum conduit size for lighting and power circuits: 19 mm.
- .7 Bend conduit cold:
  - .1 Replace conduit if kinked or flattened more than 1/10th of its original diameter.
- .8 Mechanically bend steel conduit over 19 mm diameter.
- .9 Install fish cord in empty conduits.
- .10 Remove and replace blocked conduit sections.
  - .1 Do not use liquids to clean out conduits.
- .11 Dry conduits out before installing wire.

#### 3.3 SURFACE CONDUITS

- .1 Run parallel or perpendicular to building lines.
- .2 Locate conduits behind infrared or gas fired heaters with 1.5 m clearance.

- .3    Run conduits in flanged portion of structural steel.
- .4    Group conduits wherever possible on channels.
- .5    Do not pass conduits through structural members except as indicated.
- .6    Do not locate conduits less than 75 mm parallel to steam or hot water lines with minimum of 25 mm at crossovers.

#### 3.4 CONCEALED CONDUITS

- .1    Run parallel or perpendicular to building lines.
- .2    Do not install horizontal runs in masonry walls.
- .3    Do not install conduits in terrazzo or concrete toppings.

#### 3.5 CLEANING

- .1    Proceed in accordance with Section 01 00 10 - General Instructions.
- .2    On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION

---

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA International
  - .1 CSA C22.2 No.42-10, General Use Receptacles, Attachment Plugs and Similar Devices.
  - .2 CAN/CSA C22.2 No.42.1-00(R2009), Cover Plates for Flush-Mounted Wiring Devices (Bi-national standard, with UL 514D).
  - .3 CSA C22.2 No.55-M1986(R2008), Special Use Switches.
  - .4 CSA C22.2 No.111-10, General-Use Snap Switches (Bi-national standard, with UL 20).

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for wiring devices and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Sustainable Design Submittals:
  - .1 Construction Waste Management:
    - .1 Submit project Waste Management Plan highlighting recycling and salvage requirements.
    - .2 Submit calculations on end-of-project recycling rates, salvage rates, and landfill rates demonstrating % of construction wastes recycled or salvaged.

1.3 CLOSEOUT SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for wiring devices for incorporation into manual.

1.4 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.



- .3 Storage and Handling Requirements:
  - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect wiring devices from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.
- .4 Develop Construction Waste Management Plan related to Work of this Section.
- .5 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## PART 2 - PRODUCTS

### 2.1 SWITCHES

- .1 20 A, 120 V or 347 V, single pole, double pole, three-way, four-way switches to: CSA C22.2 No.55 CSA C22.2 No.111.
- .2 Manually-operated general purpose AC switches with following features:
  - .1 Terminal holes approved for No. 10 AWG wire.
  - .2 Silver alloy contacts.
  - .3 Urea or melamine moulding for parts subject to carbon tracking.
  - .4 Suitable for back and side wiring.
  - .5 White toggle.
- .3 Toggle operated fully rated for tungsten filament and fluorescent lamps, and up to 80% of rated capacity of motor loads and heating loads.
- .4 Switches of one manufacturer throughout project.

### 2.2 RECEPTACLES

- .1 Duplex receptacles, CSA type 5-15 R, 125 V, 15 A, U ground, to: CSA C22.2 No.42 with following features:
  - .1 Orange urea moulded housing.
  - .2 Suitable for No. 10 AWG for back and side wiring.

- 
- .3 Break-off links for use as split receptacles.
  - .4 Eight back wired entrances, four side wiring screws.
  - .5 Triple wipe contacts and rivetted grounding contacts.
  - .6 Isolated ground (IG)
- .2 Other receptacles with ampacity and voltage as indicated.
  - .3 Receptacles of one manufacturer throughout project.
- 2.3 SPECIAL WIRING DEVICES
- .1 Special wiring devices:
    - .1 Clock hanger outlets, 15 A, 125 V, 3 wire, grounding type, suitable for No. 10 AWG for installation in flush outlet box.
    - .2 Pilot lights as indicated, with neon type 0.04 W, 125 V lamp and red plastic jewel flush type.
- 2.4 COVER PLATES
- .1 Cover plates for wiring devices to: CSA C22.2 No.42.1.
  - .2 Sheet steel utility box cover for wiring devices installed in surface-mounted utility boxes.
  - .3 Stainless steel, vertically brushed, 1 mm thick cover plates for wiring devices mounted in flush-mounted outlet box.
  - .4 Sheet metal cover plates for wiring devices mounted in surface-mounted FS or FD type conduit boxes.
- 2.5 SOURCE QUALITY CONTROL
- .1 Cover plates from one manufacturer throughout project.

### PART 3 - EXECUTION

- 3.1 EXAMINATION
- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for wiring devices installation in accordance with manufacturer's written instructions.

- .1 Visually inspect substrate in presence of Departmental Representative.
- .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
- .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

### 3.2 INSTALLATION

- .1 Switches:
  - .1 Install single throw switches with handle in "UP" position when switch closed.
  - .2 Install switches in gang type outlet box when more than one switch is required in one location.
  - .3 Mount toggle switches at height in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Receptacles:
  - .1 Install receptacles in gang type outlet box when more than one receptacle is required in one location.
  - .2 Mount receptacles at height in accordance with Section 26 05 00 - Common Work Results for Electrical.
  - .3 Where split receptacle has one portion switched, mount vertically and switch upper portion.
  - .4 Install GFI type receptacles as indicated.
- .3 Cover plates:
  - .1 Install suitable common cover plates where wiring devices are grouped.
  - .2 Do not use cover plates meant for flush outlet boxes on surface-mounted boxes.

### 3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 00 10 - General Instructions.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 00 10 - General Instructions.
- .3 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

#### 3.4 PROTECTION

- .1 Protect installed products and components from damage during construction.
- .2 Protect stainless steel cover plate finish with paper or plastic film until painting and other work is finished.
- .3 Repair damage to adjacent materials caused by wiring device installation.

END OF SECTION

## PART 1 - GENERAL

### 1.1 REFERENCES

- .1 Canadian Standards Association (CSA International).  
.1 CSA-C22.2 No. 5-02, Moulded-Case Circuit Breakers, Molded-Case Switches and Circuit-Breaker Enclosures (Tri-national standard with UL 489, tenth edition, and the second edition of NMX-J-266-ANCE).

### 1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Submit product data in accordance with Section 01 33 00 - Submittal Procedures.

### 1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .2 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
- .3 Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan.

## PART 2 - PRODUCTS

### 2.1 BREAKERS GENERAL

- .1 Moulded-case circuit breakers, Circuit breakers, and Ground-fault circuit-interrupters: to CSA C22.2 No. 5
- .2 Bolt-on moulded case circuit breaker: quick- make, quick-break type, for manual and automatic operation.
- .3 Common-trip breakers: with single handle for multi-pole applications.
- .4 Magnetic instantaneous trip elements in circuit breakers to operate only when value of current reaches setting.

.1 Trip settings on breakers with adjustable trips to range from 3-10 times current rating.

.5 Circuit breakers to have minimum 10,000 A symmetrical rms (root mean square) interrupting capacity rating.

## 2.2 THERMAL MAGNETIC BREAKERS

.1 Moulded case circuit breaker to operate automatically by means of thermal and magnetic tripping devices to provide inverse time current tripping and instantaneous tripping for short circuit protection.

## 2.3 OPTIONAL FEATURES

.1 Include:  
.1 Shunt trip.  
.2 On-off locking device.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

.1 Install circuit breakers as indicated.

END OF SECTION

## PART 1 - GENERAL

- |  |    |   |
|--|----|---|
| <u>1.1 REFERENCES</u>                          | .1 | Canadian Standards Association (CSA International).<br>.1 CAN/CSA C22.2 No.4-M89 (R2000), Enclosed Switches.  |
| <u>1.2 ACTION AND INFORMATIONAL SUBMITTALS</u> | .1 | Submit product data in accordance with Section 01 33 00 - Submittal Procedures.   |
| <u>1.3 HEALTH AND SAFETY</u>                   | .1 | Do construction occupational health and safety in accordance with Section 01 35 29.06 - Health and Safety Requirements.   |
| <u>1.4 WASTE MANAGEMENT AND DISPOSAL</u>       | .1 | Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.   |
|  | .2 | Remove from site and dispose of packaging materials at appropriate recycling facilities.  |
|  | .3 | Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan. |
|  | .4 | Separate for reuse and recycling and place in designated containers Steel Metal Plastic waste in accordance with Waste Management Plan.   |
|  | .5 | Fold up metal banding, flatten and place in designated area for recycling.  |

## PART 2 - PRODUCTS

- |                                |    |  |
|--------------------------------|----|--|
| <u>2.1 DISCONNECT SWITCHES</u> | .1 | Non-fusible, horsepower rated disconnect switch in CSA Enclosure, to CAN/CSA C22.2 No.4 size as indicated. |
|                                | .2 | Provision for padlocking in on-off switch position.  |

- .3 Mechanically interlocked door to prevent opening when handle in ON position.
- .4 Quick-make, quick-break action.
- .5 ON-OFF switch position indication on switch enclosure cover.

## 2.2 EQUIPMENT IDENTIFICATION

- .1 Provide equipment identification in accordance with Section 26 05 00 - Common Work Results for Electrical.
- .2 Indicate name of load controlled on size 4 nameplate.

## PART 3 - EXECUTION

### 3.1 INSTALLATION

- .1 Install disconnect switches.

END OF SECTION



PART 1 - GENERAL1.1 REFERENCES

- .1 American National Standards Institute (ANSI)
  - .1 ANSI C82.1-04, Lamp Ballasts-Line Frequency Fluorescent Lamp Ballast.
- .2 American National Standards Institute/Institute of Electrical and Electronics Engineers ( ANSI/IEEE )
  - .1 ANSI/IEEE C62.41-1991, Recommended Practice for Surge Voltages in Low-Voltage AC Power Circuits.
- .3 ASTM International Inc.
  - .1 ASTM F 1137-00(2006), Standard Specification for Phosphate/Oil and Phosphate/Organic Corrosion Protective Coatings for Fasteners.
- .4 Canadian Standards Association (CSA International)
- .5 ICES-005-07, Radio Frequency Lighting Devices.
- .6 Underwriters' Laboratories of Canada (ULC)

1.2 ACTION AND  
INFORMATIONAL  
SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Provide manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
  - .2 Provide complete photometric data prepared by independent testing laboratory for luminaires where specified, for approval by Departmental Representative.
  - .3 Photometric data to include: VCP Table where applicable.
- .3 Samples:
  - .1 Provide samples as indicated.
- .4 Quality assurance submittals: provide following in accordance with Section 01 00 10 - General Instructions.
  - .1 Manufacturer's instructions: provide manufacturer's written installation instructions and special handling criteria, installation sequence, cleaning procedures.

1.3 QUALITY  
ASSURANCE

- .1 Provide mock-ups in accordance with Section 01 00 10 - General Instructions.

1.4 DELIVERY,  
STORAGE AND  
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return by manufacturer of pallets crates padding and packaging materials in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
- .4 Divert unused metal materials from landfill to metal recycling facility.
- .5 Disposal and recycling of fluorescent lamps as per local regulations.
- .6 Disposal of old PCB filled ballasts.

PART 2 - PRODUCTS2.1 LAMPS

- .1 Incandescent lamps to be - clear, A19, 100 Watt with 1000 hour lamp life, rough-service rated; or as indicated..
- .2 Tungsten halogen lamps to be - clear, T-3, 300 Watt, RSC base, 2000 hour lamp life, 5000 lumens; or as indicated.
- .3 Fluorescent lamps to be - T8, 32 Watt, medium bi-pin, rapid-start, 4100 K, 30,000 hour lamp life, 2950 initial lumens, CRI 85; or as indicated.
- .4 Compact fluorescent lamps to be - 12,000 hour lamp life, 4100 K, CRI 85; or as indicated.

2.2 BALLASTS

- .1 Fluorescent ballast: CBM and CSA certified, energy efficient type, IC electronic.
  - .1 Voltage Rating: 60 Hz as indicated, for use with two(2) 32W lamps, rapid start type.
  - .2 Totally encased and designed for 40 degrees Celsius ambient temperature.
  - .3 Power factor: minimum 95% with 95% of rated lamp lumens.
  - .4 Current crest factor: 1.7 maximum.
  - .5 Harmonics: 10% maximum THD.
  - .6 Operating frequency of electronic ballast: 20 kHz minimum.
  - .7 Total circuit power: 62 Watts.
  - .8 Ballast factor: greater than 0.90.
  - .9 Sound rated: Class A.
  - .10 Mounting: integral with luminaire.

2.3 FINISHES

- .1 Light fixture finish and construction to meet ULC listings and CSA certifications related to intended installation.

2.4 OPTICAL CONTROL DEVICES

- .1 As indicated in luminaire schedule.

2.5 LUMINAIRES

- .1 As indicated in luminaire schedule.

PART 3 - EXECUTION3.1 INSTALLATION

- .1 Locate and install luminaires as indicated.
- .2 Provide adequate support to suit ceiling system.

3.2 WIRING

- .1 Connect luminaires to lighting circuits:
  - .1 Install flexible or rigid conduit for luminaires as indicated.

3.3 LUMINAIRE SUPPORTS

- .1 For suspended ceiling installations support luminaires independently of ceiling.

3.4 LUMINAIRE  
ALIGNMENT

- .1 Align luminaires mounted in continuous rows to form straight uninterrupted line.
- .2 Align luminaires mounted individually parallel or perpendicular to building grid lines.

3.5 CLEANING

- .1 Clean in accordance with Section 01 00 10 - General Instructions.
  - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION

PART 1 - GENERAL1.1 REFERENCES

- .1 CSA International
  - .1 CSA C22.2 No.141-10, Emergency Lighting Equipment.

1.2 ACTION AND  
INFORMATIONAL  
SUBMITTALS

- .1 Submit in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's instructions, printed product literature and data sheets for emergency lighting and include product characteristics, performance criteria, physical size, finish and limitations.

1.3 CLOSEOUT  
SUBMITTALS

- .1 Submit in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Operation and Maintenance Data: submit operation and maintenance data for emergency lighting for incorporation into manual.

1.4 DELIVERY,  
STORAGE AND  
HANDLING

- .1 Deliver, store and handle materials in accordance with Section 01 61 00 - Common Product Requirements and with manufacturer's written instructions.
- .2 Delivery and Acceptance Requirements: deliver materials to site in original factory packaging, labelled with manufacturer's name and address.
- .3 Storage and Handling Requirements:
  - .1 Store materials off ground indoors in dry location and in accordance with manufacturer's recommendations in clean, dry, well-ventilated area.
  - .2 Store and protect emergency lighting from nicks, scratches, and blemishes.
  - .3 Replace defective or damaged materials with new.

- .4 Packaging Waste Management: remove for reuse and return by manufacturer of pallets, crates, padding, and packaging materials as specified in Construction Waste Management Plan in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

## PART 2 - PRODUCTS

### 2.1 EQUIPMENT

- .1 Emergency lighting equipment: to CSA C22.2 No.141.
- .2 Supply voltage: 120 V, AC.
- .3 Output voltage: 24 V DC.
- .4 Operating time: 30 minutes.
- .5 Battery: sealed, maintenance free.
- .6 Charger: solid state, multi-rate, voltage/current regulated, inverse temperature compensated, short circuit protected with regulated output of plus or minus 0.01 V for plus or minus 10% input variations.
- .7 Solid state transfer circuit.
- .8 Low voltage disconnect: solid state, modular, operates at 80% battery output voltage.
- .9 Signal lights: solid state, for 'AC Power ON' and 'High Charge'.
- .10 Lamp heads: integral on unit and remote, 345 degrees horizontal and 180 degrees vertical adjustment. Lamp type: quartz halogen MR-16, 12 W.
- .11 Cabinet: suitable for direct or shelf mounting to wall and c/w knockouts for conduit. Removable or hinged front panel for easy access to batteries.
- .12 Finish: White
- .13 Auxiliary equipment:
  - .1 Test switch.
  - .2 Battery disconnect device.
  - .3 AC input and DC output terminal blocks inside cabinet.
  - .4 Cord and plug connection for AC.

2.2 WIRING OF  
REMOTE HEADS

- .1 Conduit: type EMT, in accordance with Section 26 05 34 - Conduits, Conduit Fastenings and Conduit Fittings.
- .2 Conductors: RW90 type in accordance with Section 26 05 21 - Wires and Cables (0-1000 V), sized as indicated.

PART 3 - EXECUTION3.1 EXAMINATION

- .1 Verification of Conditions: verify that conditions of substrate previously installed under other Sections or Contracts are acceptable for emergency lighting installation in accordance with manufacturer's written instructions.
  - .1 Visually inspect substrate in presence of Departmental Representative.
  - .2 Inform Departmental Representative of unacceptable conditions immediately upon discovery.
  - .3 Proceed with installation only after unacceptable conditions have been remedied and after receipt of written approval to proceed from Departmental Representative.

3.2 INSTALLATION

- .1 Install unit equipment and remote mounted fixtures.
- .2 Direct heads.
- .3 Connect exit lights to unit equipment.

3.3 CLEANING

- .1 Progress Cleaning: clean in accordance with Section 01 00 10 - General Instructions.
  - .1 Leave Work area clean at end of each day.
- .2 Final Cleaning: upon completion remove surplus materials, rubbish, tools and equipment in accordance with Section 01 00 10 - General Instructions.
- .3 Waste Management: separate waste materials for

reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

.1 Remove recycling containers and bins from site and dispose of materials at appropriate facility.

### 3.4 PROTECTION

.1 Protect installed products and components from damage during construction.

.2 Repair damage to adjacent materials caused by emergency lighting installation.

END OF SECTION



PART 1 - GENERAL1.1 REFERENCES

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.2 No.141-02, Unit Equipment for Emergency Lighting.
  - .2 CSA C860-01(December 2002), Performance of Internally-Lighted Exit Signs.
- .2 National Building Code of Canada
  - .1 NBCC-2010.

1.2 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedures.
- .2 Product Data:
  - .1 Submit manufacturer's printed product literature, specifications and datasheet and include product characteristics, performance criteria, physical size, finish and limitations.
- .3 Submit WHMIS MSDS - Material Safety Data Sheets in accordance with Section 01 00 10 - General Instructions.
- .4 Quality Assurance Submittals: submit following in accordance with Section 01 00 10 - General Instructions.
  - .1 Instructions: submit manufacturer's installation instructions and special handling criteria, installation sequence, cleaning procedures.

1.3 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS2.1 STANDARD UNITS

- .1 Exit lights: to CSA C22.2 No.141 and CSA C860.
- .2 Housing: extruded aluminum housing, white baked enamel finish.
- .3 Face and back plates: extruded aluminum.

- .4 Lamps: LED 50,000 hours.
- .5 Operation: designed for 50,000 hours of continuous operation without relamping.
- .6 Letters: 150 mm high x 19 mm, with 13 mm thick stroke, red on die-cast aluminum face, reading EXIT and SORTIE.
- .7 Downlight: translucent acrylic in bottom of unit.
- .8 Face plate to remain captive for relamping.

### PART 3 - EXECUTION

#### 3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and datasheets.

#### 3.2 INSTALLATION

- .1 Install exit lights to manufacturer's recommendations, listing requirements, and local regulatory requirements.
- .2 Connect fixtures to exit light circuits.
- .3 Connect emergency lamp sockets to emergency circuits.
- .4 Ensure that exit light circuit breaker is locked in on position.

#### 3.3 CLEANING

- .1 Proceed in accordance with Section 01 00 10 - General Instructions.
- .2 On completion and verification of performance of installation, remove surplus materials, excess materials, rubbish, tools and equipment.

END OF SECTION