

1  
ED-2  
1:100  
DEMOLITION / DÉMOLITION

GENERAL NOTES / NOTES GÉNÉRALES


1. WORK INDICATED IN HATCHED AREA IS N.I.C. AND SHALL BE COMPLETED BY CLIENT AT A LATER DATE / LES TRAVAUX INDiquÉS DANS LES ZONES N.I.C. SERONT EFFECTUÉS. PAR LE CLIENT À UNE DATE ULTÉRIEURE.
2. ALL REDUNDANT CABLING SHALL BE REMOVED BY OTHERS. CONTRACTOR TO ALLOW FOR 20% OF EXISTING CABLE TRAY ASSOCIATED WITH LEGACY CABLING TO REMAIN. LEGACY CABLING SHALL BE SECURED BY OTHERS PRIOR TO THE START OF WORK BY THE GC. COORDINATE WITH THE DEPARTMENTAL REPRESENTATIVE PRIOR TO REMOVING CABLE TRAY WHICH MIGHT AFFECT LEGACY CABLING. IN GENERAL CABLE TRAY TO REMAIN WILL BE LOCATED WITHIN HATCHED AREA OF PHASE 2 CONSTRUCTION / LE CÂBLAGE REDONDANT SERA DÉBRANCHÉ ET ENLEVÉ À L'EXTÉRIEUR DU PRÉSENT CONTRAT. L'ENTREPRENEUR DOIT CONSERVER 20% DU CHEMIN DE CÂBLAGE EXISTANT SERA FIXÉ À LA STRUCTURE DU PLANCHER À L'EXTÉRIEUR DU PRÉSENT CONTRAT ET CE, AVANT MÊME LE DÉBUT DES TRAVAUX PAR L'ENTREPRENEUR GÉNÉRAL. L'ENTREPRENEUR SE DOIT D'AVISER LE REPRÉSENTANT DU MINISTÈRE AVANT D'ENLEVER LE CHEMIN DE CÂBLE POUR LE CÂBLAGE DEVANT DEMEURER EN PLACE. EN GÉNÉRAL, LE CHEMIN DE CÂBLE À CONSERVER SE RETROUVE DANS LA PHASE 2 DE CONSTRUCTION À L'INTÉRIEUR DE LA ZONE HACHURÉE.
3. EXISTING POWER/FIRE ALARM CONDUITS MOUNTED TO REMOVED CABLE TRAY SHALL BE MAINTAINED. CONTRACTOR TO PROVIDE ADDITIONAL SUPPORT TO SUIT / LES CONDUITS EXISTANTS DE POUVOIR ET D'ALARME INCENDIE MONTÉS SUR LES CHEMINS DE CÂBLE À ENLEVER DOIVENT ÊTRE CONSERVÉS. L'ENTREPRENEUR DOIT FOURNIR ET INSTALLER DES SUPPORTS SUPPLÉMENTAIRES.

Canada

**McKEE**  
ENGINEERING

R.J. McKEE  
ENGINEERING LTD.  
1785 Woodward Drive  
Ottawa, ON K2C 0P9  
CANADA  
Tel: (613) 723-9585  
Fax: (613) 723-9584  
www.mckeeottawa.ca

This drawing is the property of the designer. Copyright is reserved.  
No reproduction may be made without prior consent of the  
designers and such copies must bear their names.  
This drawing shall not be used for construction purposes until  
signed by the designer.  
The contractor is to verify dimensions and data noted herein with  
the conditions on the site and report any discrepancy to the  
designer. Do not scale this drawing.



Key Plan



Contractor to verify all dimensions  
& conditions on site and immediately  
notify the engineer of all discrepancies.

revisions	description	date
8.	Issued for Tender	04.12.13
7.	Issued for Final Client Review	22.11.13
6.	Issued for Final Client Review	01.11.13
5.	Issued for Final Client Review	16.07.13
4.	Issued for Final Client Review	19.06.13
3.	Issued for Final Review	03.05.13
2.	Issued for 99% Client Review	03.04.13
1.	Issued for 66% Client Review	13.03.13

A C	A detail no. no. du détail B location drawing no. sur dessin no. C drawing no. dessin no.	A B C
--------	--	-------------

project  
OPS Fit-up  
Leitrim  
project

drawing  
dessin

ELECTRICAL / ÉLECTRICITÉ:  
DEMOLITION / DÉMOLITION

Scale / Échelle 1:100

Designed By	M.O.	Conçu par
Date	MARCH / MARS 2013	(yyyy/mm/dd)
Drawn By	M.O.	Dessiné par
Date	MARCH / MARS 2013	(yyyy/mm/dd)
Reviewed By	G.O.M.	Examiné par
Date	MARCH / MARS 2013	(yyyy/mm/dd)
Approved By	-	Approuvé par
Date	-	(yyyy/mm/dd)
Tender	-	Soumission
Project Manager	-	Administrateur de projets
Project no.	-	No. du projet
Drawing no.	13-040	No. du dessin

ED-2