

Phasing Legend - Plan B:

Indicates Phase 2 of the project.

Protect Construction and Tenant occupied zone as indicated. Protection required at Main Corridors and around equipment to remain as shown above - Protection type varies. Extent and location to be confirmed on site with Project Manager. Ensure adequate space is left for Occupant access to remainder of space. Ensure not to leave construction materials and equipment that could be a tripping hazard or other for Occupants. Upon completion of work, Contractor to remove protection material. Do NOT perforate and/or damage existing partitions, ceiling, finishes and all other components to remain and to adjacent spaces.

Indicates activities part of Phase 1 and Phase 2 of the project.

Indicates area not included in Phase 1 and/or Phase 2. Area to be manned and operational during Construction. Work required in these areas must be schedule with Client ahead of time, either during Phase 1 or Phase 2.

Temporary Hoarding Legend - Plan B:

Protect Construction/Equipment and Tenant occupied zone with POLY 6 mil (minimum) and construction tape on all joints. Ensure not to leave construction materials and equipment that could be a tripping hazard or other for Occupants. Upon completion of all work, Contractor to remove POLY. Do NOT perforate and/or damage existing partitions, ceiling, finishes and all other components to remain and to adjacent spaces. Contractor will be held responsible for any damage done to existing spaces.

Main Corridors
Ensure adequate space is left for Occupant access to remainder of space within each Main Corridors.

Equipment
Equipment shown above to remain. Ensure to leave 915mm clear space between equipment and POLY. Ensure all joints are taped and top and bottom edges are properly sealed. Ensure no dust and construction debris enters the protected spaces.

5 | 1 | 11

Erect temporary hoarding as follows. Partition to be 65mm metal stud at 410mm, 0.45 gauge o.c. with 13mm gypsum board one side only (Exterior side of room) to u/s of suspended T-bar ceiling at approximately 3016mm A.F.F.

Temporary Hoarding Notes - Plan B:

1. Provide adequate ventilation (supply and return) inside temporary POLY enclosure. Perforated raised floor tiles to be relocated as required surrounding the server racks.

PWGSC A1 (841x594)

0 10 20mm 40 60 80 100 120 140 160 180 200mm

Publics Works and Government Services Canada / Travaux publics et services gouvernementaux Canada

Canada

LWG ARCHITECTURAL INTERIORS
211-2141 Thurston Drive
Ottawa ON K1G 6C9
T 613-739-3699
F 613-739-3965
info@LWG-ai.com
LWG-ai.com

This drawing is the property of the designer. Copyright is reserved. No reproduction may be made without prior consent of the designers and such copies must bear their names.
This drawing shall not be used for construction purposes until signed by the designer.
The contractor is to verify dimensions and data noted herein with the conditions on the site and report any discrepancy to the designer. Do not scale this drawing.

Key Plan



N

Project North

ARIDO Association of Registered Interior Designers of Ontario

Contractor to verify all dimensions & conditions on site and immediately notify the engineer of all discrepancies.

revisions	description	date
BW	Issued for Tender	13.12.09
BW	Issued for Final Client Review	13.11.22
bw	Issued for Final Client Review	13.11.08
BW	Issued for Final Client Review	13.06.19
BW	Issued for 99% Client Review	13.04.03
BW	Issued for 66% Client Review	13.03.13

A detail no. / no. du detail
B location drawing no. / sur dessin no.
C drawing no. / dessin no.

project / projet
OPS Fit-up
Leitrim

drawing / dessin
Project Phasing and Temporary Hoarding - Plan B

Scale 1:100

Designed By	CSD	Conçu par
Date	2013-01-09	(yyyy/mm/dd)
Drawn By	CSD	Dessiné par
Date	2013-03-06	(yyyy/mm/dd)
Reviewed By	BW	Examiné par
Date	2013-12-09	(yyyy/mm/dd)
Approved By	-	Approuvé par
Date	-	(yyyy/mm/dd)
Tender	-	Soumission
Project Manager	-	Administrateur de projets

PWGSC Project no. / TPSGC No. du projet
R.050134.002

Drawing no. / No. du dessin
ID01B