



RETURN BIDS TO:	Title-Sujet		Date
RETOURNER LES SOUMISSIONS Á:	Building Renovations at Ottawa Lockstation		Feb 13, 2014
Parks Canada Agency – Bids Receiving 111 Water Street Cornwall, ON, K6H 6S3 Bid Fax: (613) 938-5785	Solicitation No No. de l'invitation 10131328 GETS Reference No. – No de reference		No. – No. de réf du client.
	Solicitation Closes	Time Zor	
AMENDMENT#4 TO INVITATION TO		Fuseau horaire -	
TENDER	4 4 0 2 00 DM		
MODIFICATION#4 D'APPEL D'OFFRES	at – á 02:00 PM on – le Feb 14, 2014	Eastern T	ime
Tender To: Parks Canada Agency We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefor. Soumission aux: l'Agence Parcs Canada Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente at aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci- annexée, au(x) prix indiqué(s).	F.O.B F.A.B. Plant-Usine: Destination: Other-Autre: Address Inquiries to: - Adresser toute demande de renseignements à : dale.rudderham@pc.gc.ca Telephone No No de téléphone Fax No. – No de FAX: (613) 938-5751 (613) 938-5785 Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Commentaries	Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Vendor/Firm Name and Address			
Raison sociale et adresse du			
fournisseur/de l'entrepreneur	Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Issuing Office - Bureau de distribution			
Parks Canada Agency CFOD – Contracting Operations 111 Water St.	Signature		Date
Cornwall, ON K6H 6S3	0		



10131328 Amendment#4

This amendment gives effect to the following changes:

1. QUESTIONS AND ANSWERS:

Q1. Drawing A8, "section 4/A2", Note "Replace and/or patch concrete floor as require". Are we permitted to carry a unit rate for concrete as the extent to this item is unknown?

A2. No, the amount of concrete required to complete the installation of new plumbing and electrical is easily estimated. Any unforeseen quantities will be dealt with during construction.

Q2. Drawing A3, "Second Floor Plan – New", Note "Reinstate Window". Are there any further specifications or details available on this note? A2. the window frame is intact just have to install new thermopane window to suit.

Q3. Drawings A2, A7 & A8, all notes pertaining to wood to be used in staircase, railings, wainscoting, sills and nosing. Please confirm type of wood to be used on each.

A3. All finished wood ie: stair treads, risers, wainscotting, nosing, sills etc. are to be maple finish to be chosen during construction.

Q4. In Addendum #3 it is stated that measurements for the existing windows to be covered with Lexan panels are not available at this moment. Without dimensions, and seeing that there are multiple sizes and shapes of windows, it is difficult to provide an accurate quotation without knowing the quantities of Lexan panels and the number of stainless steel brackets needed to hold them in place. Will this information be made available before the tender closing? A4. Parks staff is not currently available to take these measurements. The exterior of the building is readily accessible for measuring. Please refer to drawing A7 for quantities of brackets

Note:

Please check for amendments on buyandsell.gc.ca periodically and prior to closing. You can use your browser's "newsfeed" option to update you on changes.

Bids must be received at 111 Water St E, Cornwall ON before closing via mail/delivery/in-person. Faxed <u>revisions</u> are accepted.

Tender opening is public.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME