



RETURN BIDS TO:

Attn: Robbie Harracksingh
Shared Services Canada | Services
partagés Canada
180 Kent Street, 13th Floor – K105
PO Box 98085, STN T CSC
Ottawa, Ontario K1G 4A8

RETOURNER LES SOUMISSIONS À:

Attn: Robbie Harracksingh
Shared Services Canada | Services
partagés Canada
180 Kent Street, 13th Floor – K105
PO Box 98085, STN T CSC
Ottawa, Ontario K1G 4A8

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised,
unless otherwise indicated, all other terms and
conditions of the Solicitation remain the same

Ce document est par la présente révisé; sauf
indication contraire, les modalités de l'invitation
demeurent les mêmes.

Comments - Commentaires

*This document contains a Security
Requirement.*

Title – Sujet Dark Fibre Installation and Lease – Winnipeg, MB Location et Installation de Fibre Noire – Winnipeg, Manitoba	
Solicitation No. – N° de l'invitation 10030876	Amendment No. - N° modif. 002
Client Reference No. – N° référence du client 13-1419	Date : 18 Feb 2014
File No. – N° de dossier 10030876 - C66	
Solicitation Closes – L'invitation prend fin at – à 11 :59 PM on – le 26 February 2014	
Time Zone Fuseau horaire Eastern Standard Time EST	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Inquiries to : - Adresser toutes questions à: Robbie Harracksingh	Buyer Id – Id de l'acheteur C66
Telephone No. – N° de téléphone : 613-852-2043	FAX No. – N° de FAX Not applicable
Email : Robbie.harracksingh@ssc-spc-gc.ca	
Delivery required - Livraison exigée See Herein	Delivered Offered – Livraison proposée
Destination – of Goods, Services, and Construction: Destination – des biens, services et construction : See Herein	

Vendor/firm Name and address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Facsimile No. – N° de télécopieur	
Telephone No. – N° de téléphone	
Name and title of person authorized to sign on behalf of Vendor/firm (type or print)- Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

SOLICITATION AMENDMENT 002

This solicitation amendment 002 is issued to:

- A) Respond to Bidders questions received as of 18 Feb 2014; and
- B) To Amend the Solicitation Closing Date.

SECTION A – Bidder's Questions and Subsequent Answers

Ref: CSCHAC Winnipeg Lab – 1015 Arlington Ave

Question # 1

Is the main termination with patch panel to be in C1117?

Answer # 1

Yes

Question # 2

- a) Does the tender require Fibre runs from C1117 to Other Rooms

Answer a: No

- b) Are there Patch Panels at both ends (e.g. C1117 and A1249, and C1117 and C1112)?

Answer b: Only in C1117

- c) Number of pairs for each run?

Answer c: No additional runs required.

- d) Will space be provided for patch panels in each room?

Answer d: The only patch panel is located in room C1117. Space is provided.

- e) Distances of internal runs?

Answer e: Not applicable, see answer to question a.

Question# 3

There is an existing outdoor pull pit. Can the successful vendor use that and the existing conduit into the building?

Answer # 3

Yes.

Solicitation No. - N° de l'invitation
10030876
Client Ref. No. - N° de réf. du client
13-1419

Amd. No. - N° de la modif.
002
File No. - N° du dossier
10030876 – C66

Buyer ID - Id de l'acheteur
C66
CCC No./N° CCC - FMS No./N° VME

Ref: JC Wilt Lab – 745 Logan Ave.

Question # 4

Can the successful vendor use the existing MTA conduit from outside or is a new hole required through the concrete? Is it under grade?

Answer # 4

Yes, the successful vendor can use the existing conduit. Yes, it is under grade.

Question # 5

4U of rack space will need to be confirmed for the panel.

Answer # 5

Yes, there is sufficient rack space for the Fibre Panel.

Question # 6

We would like to ask for a 1 week extension to the closing date?

Answer # 6

The closing date of 11:59pm EST on 20 February 2014 will be amended to a new closing of 11:59pm EST on 26 February 2014.

SECTION B: Amend the Solicitation Closing

1. On the front page of the Solicitation

At Solicitation Closes

Replace with: 11:59pm EST on 26 February 2014

All other terms and Conditions of the Bid Solicitation remain unchanged