




Smith Carter Architects  
and Engineers  
Incorporated  
1000  
Winnipeg, Manitoba  
Canada, R3T 6B8  
T: 204.477.6346  
F: 204.477.6346  
www.smithcarter.com


**Smith Carter**

SC Proj. #20C-00061-00

stamp



key plan



plan repaire

Contractor to verify all dimensions  
& conditions on site and immediately  
notify the engineer of all discrepancies.

revisions	description	date
0	ISSUED FOR DESIGN DEVELOPMENT	2013/02/22
1	ISSUED FOR 90% CONSTRUCTION DOCUMENTS (P&S)	2013/05/20
2	ISSUED FOR 90% CONSTRUCTION DOCUMENTS (VOL. 1)	2013/06/16
3	ISSUED FOR 90% CONSTRUCTION DOCUMENTS (VOL. 2)	2013/06/29
4	ISSUED FOR 100% CONSTRUCTION DOCUMENTS	2013/10/16
5	ISSUED FOR ADDENDUMS	2014/02/10

<b>A</b>	A: detail no. no. du détail	<b>A</b>
<b>C</b>	B: location drawing no. sur dessin no.	<b>B C</b>
	C: drawing no. dessin no.	

project  
**SIR FREDERICK BANTING  
RESEARCH CENTRE  
ANIMAL TO WET LAB CONVERSION**


251 SIR FREDERICK BANTING WAY, ON

drawing

dessin


**EMERGENCY POWER  
SYSTEM  
DETAILS**

Designed By	P. KIEMENEY	Conçu par
Date		(yyyy/mm/dd)
Drawn By	P. LAPOINTE	Dessiné par
Date		(yyyy/mm/dd)
Reviewed By	P. KIEMENEY	Examiné par
Date		(yyyy/mm/dd)
Approved By	P. KIEMENEY	Approuvé par
Date		(yyyy/mm/dd)
Tender		Soumission
Project Manager	Administrateur de projets	
Project no.	No. du projet	
	<b>R.044033.002</b>	
Drawing no.	No. du dessin	
	<b>EP112-X1</b>	




1 OUTDOOR EMERGENCY POWER ENCLOSURE LAYOUT

NOTES:  
1. WIRE AND CONNECT ALL NEW FIRE ALARM DEVICES TO EXISTING MAIN FLOOR  
FIRE ALARM SIGNALING AND ANNUNCIATION LOOPS. PROVIDE FIRE ALARM  
VERIFICATION FOR ALL AFFECTED DEVICES. CONFIRM EXISTING ON SITE.



2 TRENCH ELEVATION DETAIL

1. IN ADDITION TO EMERGENCY FEEDER CONDUITS, PROVIDE  
4x27mm CONDUITS FOR CLASS A FIRE ALARM SIGNALING  
AND ANNUNCIATION LOOPS AND 2x27mm CONDUITS AS  
SPARE FOR FUTURE.



3 AIR RELIEF VENT DETAIL

