

**APPENDIX F  
ASBESTOS INVENTORY**

<b>AEC #<sup>(1)</sup></b>	<b>Structure/Site Debris Designation</b>	<b>Material Description<sup>(3)</sup></b>	<b>Estimated Uncrushed Volume (m<sup>3</sup>)<sup>(2)</sup></b>
<b>1</b>	Storage Shed 01	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Fibreglass Insulation (Actinolite contaminated)</li> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> <li>- Exterior White Siding (chrysotile)</li> </ul>	99
<b>3</b>	New Radio Building	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Fibreglass Insulation (Actinolite contaminated)</li> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> <li>- Asbestos Vinyl Floor Tiles (chrysotile)</li> <li>- Light Fixture Backings (chrysotile)</li> <li>- Exterior White Siding (chrysotile)</li> </ul>	74.5
<b>5</b>	Outhouse	<ul style="list-style-type: none"> <li>- Asphalt Shingles (chrysotile)</li> </ul>	0.2
<b>6</b>	Storage Shed 02	<ul style="list-style-type: none"> <li>- Asphalt Shingles (chrysotile)</li> </ul>	0.5
<b>7</b>	Storage Building & Small Shed	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Fibreglass Insulation (Actinolite contaminated)</li> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> <li>- Exterior White Siding (chrysotile)</li> </ul>	28
<b>8</b>	Chicken Coop & Caged Area	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Asphalt Shingles (chrysotile)</li> </ul>	6.7
<b>9</b>	Bunkhouse	<ul style="list-style-type: none"> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> <li>- Furnace Gaskets (chrysotile)</li> </ul>	25.1

**APPENDIX F**  
**ASBESTOS INVENTORY (Continued)**

<b>10</b>	Generator Building	- Asbestos Panels (chrysotile and/or crocidolite)	13.5
<b>11</b>	House & Garage	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Fibreglass Insulation (Actinolite contaminated)</li> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> <li>- Light Fixture Backings (chrysotile)</li> <li>- Exterior White Siding (chrysotile)</li> </ul>	62
<b>12</b>	Shed	- Asbestos Panels (chrysotile and/or crocidolite)	2
<b>13</b>	House	<ul style="list-style-type: none"> <li>- Asbestos Attic Insulation (Actinolite)</li> <li>- Fibreglass Insulation (Actinolite contaminated)</li> <li>- Asbestos Panels (chrysotile and/or crocidolite)</li> </ul>	20

<sup>(1)</sup> **AEC = Area of Environmental Concern.**

<sup>(2)</sup> **Reference: Remedial Action Plan. Former Weather Station Nottingham Island, Nunavut. April 2013. EBA, A Tetra Tech Company.**

<sup>(3)</sup> **Reference: Phase III ESA. Nottingham Island, Nunavut. January 2013. EBA, A Tetra Tech Company.**