



## Addendum 3

**Project Title:** Emergency Generator Installation  
Building 56  
Central Experimental Farm (CEF), Ottawa (Ontario)

**Solicitation No:** 13-1427

March 18, 2014

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents

---

### **INVITATION TO TENDER**

**1. At Front Page “Invitation to Tender”:**

**Delete:** Wednesday March 19

**Insert:** Friday March 21

### **SPECIFICATIONS**

**1. At Section 26 32 14 “Diesel Generator”:**

**Delete Article 2.1.1.2 in its entirety**

**Replace with:** Engine must meet the following standard: U.S. EPA Non-road Source Emissions Standards, 40 CFR89, Tier 2 system.

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**