

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Colins Bay - Central Heating Plant	
Solicitation No. - N° de l'invitation EQ734-142152/A	Amendment No. - N° modif. 009
Client Reference No. - N° de référence du client R.039321.001	Date 2014-03-26
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-3-36081 (039)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-04-01	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hassell, Bob	Buyer Id - Id de l'acheteur pwl039
Telephone No. - N° de téléphone (416) 590-8270 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Correctional Services Canada Collins Bay Institution 1455 Bath Road Kingston, Ontario K7M 7W9	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Q19 Section 23 52 00, 2.13.2 specifies boiler controls interface with the central control room computer system. Section 23 52 00, 2.14.1 specifies that all data points from the boiler system to be tied into the existing EMCS. There is a Schneider Modicon PLC system in the control room and Johnson Controls Metasys EMCS at this site. Is the intent to have the specified remote control and surveillance boiler system points interconnected with the Schneider PLC and Metasys EMCS?

A19 The intent of the project is to maintain the existing Schneider system to monitor the boiler system.

Q20 in reference to section 23 52 00, paragraphs 2.10, 2.11, 2.12 and 2.13, although we do not question the qualities of the system upon which the specification has been written around (i.e. Autoflame), it does come with numerous features that add to the cost and are not necessary to achieve an efficient and reliable burner/boiler operation. Would PWGS be open to alternate, more cost effective, boiler/burner systems that would provide all the basic requirements of the specification but without some non-critical features (example: Siemens LMV52)?

A20 Bidders shall include all specified items in tender price.