



**Royal Canadian Mounted Police**  
**Gendarmerie royale du Canada**

**RETURN BIDS TO :**

**RETOURNER LES SOUMISSIONS :**

**Bid Receiving Unit / Grope de la réception des soumissions**

Procurement and Contracting Services  
 73 Leikin Drive,  
 Visitor Center - Building M1  
 Mailstop # 15  
 Ottawa, ON K1A 0R2

Attn: Megan McCoy (613) 843-3798

**AMENDMENT TO THE INVITATION TO TENDER**

**Royal Canadian Mounted Police**

We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services and construction listed herein and on any attached sheets at the price(s) set out therefore.

**MODIFICATION À L'APPEL D'OFFRES**

**Gendarmerie royale du Canada**

Nous offrons par la présente de vendre à Sa Majesté I Reine du chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments – Commentaries

**Vendor/Firm Name and Address**

**Raison sociale et adresse du fournisseur/de l'entrepreneur**

Telephone No. – No de téléphone:

( )

Facsimile No. – No de télécopieur:

( )

<b>Title-Sujet</b> RCMP B Block Redevelopment		
<b>Solicitation No. – No. de l'invitation</b> 201405073	<b>Amend. – Modif.</b> No. : 7	<b>Date</b> March 26, 2014
<b>Client Reference No. - No. de Référence du Client</b> 201405073		
<b>GETS Reference No. – No de Référence du SEAG</b> 201405073		
<b>Solicitation Closes – L'invitation prend fin</b> <b>at - à 2 :00 pm EST</b> <b>on - le March 31st, 2014</b>		
<b>F.O.B. - F.A.B.</b> Destination		
<b>Address Enquiries to: - Adresser toute questions à :</b> Eric Glynn – Manager - Procurement		
<b>Telephone No. - No de téléphone</b> 613-843-5533	<b>Fax:</b> 613-825-0082	
<b>Destination of Goods - Destinations des biens:</b> See Herein		
<b>Instructions : See Herein / Voir aux présentes</b>		
<b>Delivery Required – Livraison exigée:</b> See Herein		
<b>Name and Title of person authorized to sign on behalf of Vendor/Firm.</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur</b>		



**Royal Canadian Mounted Police**

**Gendarmerie royale du Canada**

Amendment #7 of Solicitation 201405073 has been issued to provide Addendum #5 to the Specifications and Drawings.

---

**ADDENDUM NUMBER: FIVE**

**ISSUED BY: SEPW Architecture Inc.**  
109 - 3725 Pasqua St., Regina, SK S4S 6W8  
PH. (306) 569-2255

**PROJECT: SHARED LEARNING FACILITY**  
**REGINA, SK**

---

This Addendum forms part of the Contract Documents and amends the original Drawings and Specifications dated 2014-01-17, previous Addenda if applicable and as noted below. This Addendum consists of 1 page.

Ensure that all parties are aware of all items included in this Addendum.

**A5-1 REF. SECTION 02 41 99, DEMOLITION FOR MINOR WORKS**

2.7 GENERAL CLARIFICATION: The General Contractor shall coordinate the work of their asbestos remediation sub-contractor to determine the method for removal of the existing bulkheads to allow for the remediation of the asbestos on pipe elbows and to mitigate the risk of damaging the existing pipe insulation. The pipe elbows are located below the floor levels, within the bulkhead. There are two pipes serving each heating convector cabinet located at each window location.

Based on limited visual observations, the condition of the asbestos insulation on the pipe elbows appears to be good and undisturbed. However, should the contractor discover existing material that resembles asbestos on the top surface of the soffit within the existing bulkheads they shall stop work and notify the Departmental Representative immediately. The Departmental Representative will have that material tested and determine a course of action.

As per sentence 2.7.6 remediation locations are noted on drawings.

**END OF ADDENDUM NO. 5**