

**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:**

**Bid Receiving
PWGSC
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5
Bid Fax: (905) 615-2095**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Issuing Office - Bureau de distribution
Public Works and Government Services Canada
Ontario Region
33 City Centre Drive
Suite 480
Mississauga
Ontario
L5B 2N5

| | |
|---|--|
| Title - Sujet Electric Cable | |
| Solicitation No. - N° de l'invitation W0113-130163/A | Amendment No. - N° modif. 002 |
| Client Reference No. - N° de référence du client W0113-130163 | Date 2014-04-01 |
| GETS Reference No. - N° de référence de SEAG PW-\$TOR-033-6568 | |
| File No. - N° de dossier TOR-3-36302 (009) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-04-23 | Time Zone Fuseau horaire Eastern Daylight Saving Time EDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Boulet, Kieta | Buyer Id - Id de l'acheteur tor009 |
| Telephone No. - N° de téléphone (905) 615-2078 () | FAX No. - N° de FAX (905) 615-2060 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: Department of National Defence Construction Engineering Officer 16 Ramillies Rd (Bldg P-154) Bordon, ON L0M 1C0 | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

AMENDMENT 002 MAKES CHANGES TO THE CONTRACTING AUTHORITY, THE CABLE DESCRIPTION, AND ANSWERS A QUESTION.

1. On page 1, "Address Enquiries to":

Delete: Martin, Lesley (905) 615-2076

Insert: Boulet, Kieta (905) 615-2078

2. At Part 4, Article 1, Clause 1.1.1 Mandatory Technical Criteria:

Delete: in its entirety

Insert:

1.1.1 Mandatory Technical Criteria

| Item # | Mandatory Criteria |
|--------|---|
| M1 | <p>The bidder must provide documentation demonstrating that their proposed 2/0 awg, Stranded Copper, 15 KV Primary, Full Concentric neutral, TRXLP, jacketed, Underground Distribution Cable (UD) meets the following minimum specifications:</p> <ol style="list-style-type: none"> 1. Conductor: Copper, size 2/0 AWG; 2. Semi Conductor: Cross-link polyethylene strand shield; 3. Primary Insulation: Tree-retardant Cross-linked Polyethylene (TR-XLP); 4. Insulation Level: 100%; 5. Full Concentric Neutral: Copper wires applied helically over the insulation shield equivalent to 100% full capacity; 6. Jacket: Extruded Linear Low Density Polyethylene (LLDPE) rated minus 40 degrees Celsius 7. Minimum Temperature: 90 degrees Celsius; |

3. At Part 6, Article 5, Clause 5.1 Contracting Authority:

Delete:

Name: Lesley Martin

Title: Supply Team Leader

Telephone: 905-615-2076

E-mail address: Lesley.Martin2@pwgsc.gc.ca

Insert:

Name: Kieta Boulet

Title: Supply Specialist

Telephone: 905-615-2078

E-mail address: Kieta.Boulet@pwgsc-tpsgc.gc.ca

4. At ANNEX A - REQUIREMENT:**Delete:** In its entirety**Insert:****ANNEX A
REQUIREMENT**

The Contractor must supply and deliver 3000 meters of 2/0 awg, Stranded Copper, 15KV Primary, Full Concentric neutral, TRXLP, jacketed, Underground Distribution Cable (USD) for use in conduit, direct buried applications or where exposed to sunlight, to the BCE Municipal Services Section.

The cable must have the following minimum specifications:

1. Conductor: Copper, size 2/0 AWG;
2. Semi Conductor: Cross-link polyethylene strand shield;
3. Primary Insulation: Tree-retardant Cross-linked Polyethylene (TR-XLP);
4. Insulation Level: 100%;
5. Full Concentric Neutral: Copper wires applied helically over the insulation shield equivalent to 100% full capacity;
6. Jacket: Extruded Linear Low Density Polyethylene (LLDPE) rated minus 40 degrees Celsius
7. Minimum Temperature: 90 degrees Celsius;
8. Must be on a maximum 72" wood reel
9. Must be manufactured in accordance with the latest edition of the following reference:
 - i. CAN/CSA (CSA International) C68.3-13, 5-46 KV Shielded and Concentric Neutral Power Cable for Distribution Utilities

5. At ANNEX B - BASIS OF PAYMENT:**Delete:** In its entirety**Insert:****ANNEX B
BASIS OF PAYMENT**

Firm unit prices in Canadian funds including Canadian customs duties, excise taxes, and F.O.B destination. The total amount of Goods and Services Tax (GST) or Harmonized Sales Tax (HST) is to be shown separately, if applicable.

| Item # | Description | Quantity | Firm Unit Price |
|--------|---|----------|-----------------|
| 1 | 3000 meters of 2/0 awg, Stranded Copper, 15KV Primary, Full Concentric neutral, TRXLP, jacketed, Underground Distribution Cable (USD) | 1 | \$ |
| 2 | Delivery | 1 | \$ |

Total Evaluated Cost \$_____

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED

Solicitation No. - N° de l'invitation

W0113-130163/A

Client Ref. No. - N° de réf. du client

W0113-130163

Amd. No. - N° de la modif.

002

File No. - N° du dossier

TOR-3-36302

Buyer ID - Id de l'acheteur

tor009

CCC No./N° CCC - FMS No/ N° VME

QUESTION:

Q1. Can you please confirm if your spec is requiring a Full Concentric Neutral or a 1/3 Concentric Neutral?

A1. Full Concentric Neutral cable and the neutral is to be made up of individual 12 AWG wires.