

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #2 - Market	UH-1-2	Food Court East	Gas fired Unit Heater	Reznor	UDAP225	BKK7943N26266X	Annual	Inspection Done Jan 2012
Building #2 - Market	UH-2-2	Market	Gas fired Unit Heater	ITT	BLO-400	C794584	Annual	Inspection Done Jan 2012, A-46 belt
Building #2 - Market	UH-3-2	Market	Gas fired Unit Heater	Reznor	UDPOB400	B1A7943N83853X	Annual	Inspection Done Jan 2012
Building #3 - Market	UH-1-3	Market	Gas fired Unit Heater	Reznor	B250-E	A2C66Q3N03517TE	Annual	Inspection Done Jan 2012
Building #3 - Market	UH-2-3	Market	Gas fired Unit Heater	Reznor	B250-E	A2C66A3N03515TE	Annual	Inspection Done Jan 2012, A48 Belt
Building #3 - Market	UH-3-3	Market	Gas fired Unit Heater	Modine	PDP250AE0130	3001090909451--9694	Annual	Inspection Done Jan 2012
Building #4 - Market	UH-1-4	Market	Gas fired Unit Heater	Modine	PDP400AE0130	18010905092410-2987	Annual	Inspection Done Jan 2012
Building #4 - Market	UH-2-4	Market	Gas fired Unit Heater	Reznor	B400	A2C66Q3N03518TE	Annual	Inspection Done Jan 2012
Building #4 - Market	UH-3-4	Market	Gas fired Unit Heater	Reznor	B250-E	A2C66Q3N03518TE	Annual	Inspection Done Jan 2012
Building #7 - Market	UH-1-7	Market	Gas fired Unit Heater	Modine	BP250AE2831	15101052044697	Annual	Inspection Done Jan 2012, A47-Belt
Building #7 - Market	UH-2-7	Market	Gas fired Unit Heater	Modine	B250-E	A2C66Q3N03519TE	Annual	Inspection Done Jan 2012, A49-Belt

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #27	AC-1-27	Fdn of Cdn Artists	Heat/Cool Rooftop Unit	Carrier	48TCE07A2A5A 0A0A	4013C82418	Quarterly	Foundation of Cdn Artists. Qty 4-16x16x2 TAS- NEW UNIT OCT 2013
Building #27	EF-2-27	Mech Room	Exhaust Fan	Penn	Domex	A010	Semi-Annual	(CMHC) serves Mech room
Building #27	EF-1-27	Mech Room	Exhaust Fan	Penn	Domex	XR-60	Semi-Annual	(CMHC) serves Mech room

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #34	F-1-34	Bldg 34	Supply Air Fan	Eng Air	XE160HBMAES/S	9904082	Quarterly	MUA Unit
Building #34	F-2-34	Bldg 34	Supply Air Fan	Eng Air	XE160HBMAES/S	9904083	Quarterly	MUA Unit

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #39 - Net Loft	AC-1-39-1620-1610	Kingsmill 1620-1610	Heat/Cool Rooftop Unit	Lennox	GCS16-953-200-6Y	5694CO3143	REMOVED	REMOVED
Building #39 - Net Loft	AC-2-39-80	Amity 80	Heat/Cool Rooftop Unit	Lennox	GCS16-1353-270-7Y	5693K01160	REMOVED	REMOVED
Building #39 - Net Loft	AC-3-39-90	Paper 90	Heat/Cool Rooftop Unit	Trane	WCC036F300BD	N071KFF1H	REMOVED	REMOVED
Building #39 - Net Loft	AC-4-39-120	120	Heat/Cool Rooftop Unit	BDP	548CPX036000AEAA	1695G20229	REMOVED	REMOVED
Building #39 - Net Loft	RTU#3- NEW UNIT		Heat/Cool Rooftop Unit	Trane	Multizone-M#YCH092F3RHA04C OOA	1317118926	Quarterly	NEW UNIT- replaced AC#1-AC#4. Filters: 4-20x25x2 TAS
Building #39 - Net Loft	AC-5-39-111-130-110	111-130-110	Heat/Cool Rooftop Unit	Lennox	GCS16-1353-270-7Y	5694B01082	REMOVED	REMOVED
Building #39 - Net Loft	MUA-1-39-1649	1649	Make-Up Air Unit	Eng Air	S-150-O	S20809-HV-1	Quarterly	2-20x25x2 media
Building #39 - Net Loft	AC-6-39-1645	1649	Heat/Cool Rooftop Unit	Pace	A12-12FC	3436244	Quarterly	4-20x25x2 TAS
Building #39 - Net Loft	DC-1-39	South Door	Air Curtain	MiniVeil	MK-2-48E	11481	Semi-Annual	
Building #39 - Net Loft	DC-2-39	East Door	Air Curtain	MiniVeil	MK-2-48E	11480	Semi-Annual	
Building #39 - Net Loft	DC-3-39	West Door	Air Curtain	MiniVeil	MK-2-48E	11478	Semi-Annual	
Building #39 - Net Loft	DC-4-39	North Door	Air Curtain	MiniVeil	MK-2-48E	11479	Semi-Annual	
Building #39 - Net Loft	SP-1-39-200-250	200-250	Split AC Unit (condenser)	Lennox	HS29-090-3Y	5605D05512	Quarterly	
Building #39 - Net Loft	EF-1-39	Net Loft	Exhaust Fan	Penn	Domex	N/A	Semi-Annual	
Building #39 - Net Loft	AHU-1-39-200-250	200-250	Split AC Unit (evaporator)	Lennox	N/A	N/A	REMOVED	REMOVED

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #40 - Net Loft	EF-1-40	Net Loft	Exhaust Fan	Penn	Domex	AB-35	Semi-Annual	
Building #40 - Net Loft	AC-1-40-150	150	Heat/Cool Rooftop Unit	Bryant	555ANX024000AAAD	1496G40023	REMOVED	REMOVED
Building #40 - Net Loft	AC-2-40-140	140	Heat Pump Unit	Bryant	655ANX036000AABF	2496G41177	REMOVED	REMOVED
#40 - Net Loft	RTU#2-NEW		Heat/Cool Rooftop Unit	Trane	YCH092F3RHA04COOA	131711790L	Quarterly	NEW UNIT. Filters: 4-20x25x2 TAS
#40 - Net Loft	RTU#4-NEW		Heat/Cool Rooftop Unit	Trane	YCD420BELK24A2DC50 BC	C13C01330	Quarterly	NEW UNIT. Filters: 16-16x20x2 TAS
#40 - Net Loft	RTU#5-NEW		Heat/Cool Rooftop Unit	Trane	YCD420BELK24A2DC50 BC	C13C01331	Quarterly	NEW UNIT. Filters: 16-16x20x2 TAS
#40 - Net Loft	UH#1	John Notter Studio	Gas Fired UH	Lennox	LF24-100A-1	6394A51765	Semi-Annual	
#40 - Net Loft	UH#2	Granville Island Glass	Gas Fired UH	Lennox	LF24-100A-1	6392M55195	Semi-Annual	
Building #40 - Net Loft	AC-3-40-Lobby	Lobby	Heat/Cool Rooftop Unit	Lennox	GCS16-1353-270-7Y	5693K01179	REMOVED	REMOVED
Building #40 - Net Loft	AC-4-40-50-60-70	40-50-60-70	Heat/Cool Rooftop Unit	Lennox	GCS16-1353-270-7Y	5694C02195	REMOVED	REMOVED
Building #40 - Net Loft	SP-1-40-1650	1650	Split AC Unit	Fujitsu	AOU15RLQ	GVN004187	REMOVED	REMOVED
Building #40 - Net Loft	AC-5-40-1640-1650	1640	Split AC Unit	Lennox	GCS16-953-200-6Y	5694C03321	REMOVED	REMOVED
Building #40 - Net Loft	EF-2-40-S1		Exhaust Fan	Penn	Domex	BB45	Semi-Annual	
Building #40 - Net Loft	EF-3-40-1640	1640	Exhaust Fan	Greenheck	N/A	N/A	Semi-Annual	Belt (HM-25)
Building #40 - Net Loft	EF-4-40	Net Loft	Exhaust Fan	Greenheck	N/A	N/A	Semi-Annual	Belt- HM-22

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #41 - Net Loft (Upper Roof)	AC-5-41-211 WEST OFFICES	West Offices	Heat/Cool Rooftop Unit	York	D7CG036N07925A	NCNM061447	Quarterly	12-23-2012- New stat installed. Filters: 2-14x20x2 and 1-14x25x2 TAS
Building #41 - Net Loft (Upper Roof)	AC-4-41-211- RECEPTION	Reception	Heat/Cool Rooftop Unit	York	DM102N15B2AAA3C	NFNM080762	Quarterly	12-23-2012- New stat installed. Filters: 4-20x25x2 TAS
Building #41 - Net Loft (Upper Roof)	AC-3-41-211-EAST OFFICES	East Offices	Heat/Cool Rooftop Unit	York	D7CG048N09925A	NGNM085538	Quarterly	12-23-2012- New stat installed. Filters: 2-14x20x2 and 1-14x25x2 TAS
Building #41 - Net Loft (Upper Roof)	MUA-1-41-10-20-30-40	10-20-30-40	Make-Up Air Unit	Eng Air	S-350-OVF1	5870-3	REMOVED	REMOVED
Building #41 - Net Loft (Upper Roof)	RTU#1-NEW UNIT	10-20-30-40	Heat/Cool Rooftop Unit	Trane	YHC092F3RHA02QP	131711799L	Quarterly	Hallway Unit. NEW UNIT. Filters: 4-20x25x2 TAS
Building #41 - Net Loft (Upper Roof)	MUA-2-41- 203, 201, 301	203-201-301	Make-Up Air Unit	Eng Air	S-300-OVF1	5870-1	Quarterly	12-28-2012- Pulled new common wire to stat and balnced airflow to (2) offices. Filters: 4-16x25x2 media
Building #41 - Net Loft (Upper Roof)	SP-1-41-211- BOARDROOM	Boardroom	Split AC Unit (condenser)	Mitsubishi	PU24EK	94E01382C	Quarterly	washable filters
Building #41 - Net Loft (Upper Roof)	SP-2-41-1660	Net Loft- Upper Roof	Split AC Unit (condenser)	Fujitsu	AOV24CL	DDN000940	Quarterly	washable filters
Building #41 - Net Loft (Upper Roof)	EF-1-41	Net Loft- Upper Roof	Exhaust Fan	Centri Maste	PNN245H	NTB328711	Semi-Annual	
Building #41 - Net Loft (Upper Roof)	EF-2-41	Net Loft- Upper Roof	Exhaust Fan	EH Price	CBE-14-4	8843	Semi-Annual	

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #70 - Performance Works	MUA-1-70	Theatre	Make-Up Air Unit	Eng Air	DJ-100	18521-AH-2	Quarterly	Industrial Heater (Theatre) grease bearings & motor bearings
Building #70 - Performance Works	EF-1-70	West	Exhaust Fan	Penn	Dynafan (west)	LC12X	Semi-Annual	West Theatre
Building #70 - Performance Works	EF-2-70	East	Exhaust Fan	Penn	Dynafan (east)	LC12A	Semi-Annual	East Theatre
Building #70 - Performance Works	EF-3-70	Bathroom	Exhaust Fan	Penn	ZPR0188	06AB42711	Semi-Annual	Bathroom fan dual shaft
Building #70 - Performance Works	HWT-1-70	Kitchen	Hot Water Tank	Ruud	EGS120C-18	0992L83877	Semi-Annual	Kitchen
Building #70 - Performance Works	MUA-2-70	Lobby	Make-Up Air Unit	Eng Air	DJ-40	18521-AH-1	Quarterly	Lobby - grease bearings and motors

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #89 Festival House	AC-1-89	1st/2nd Floor (South)	Heat/Cool Rooftop Unit	Carrier	48TJE006501GA	4298G20856	Quarterly	1st/2nd floor south
Building #89 Festival House	AC-2-89	Ground Floor North	Heat/Cool Rooftop Unit	Carrier	48SS042100531AA	3198G10707	Quarterly	Ground floor north
Building #89 Festival House	AC-3-89	Top Floor S.W.	Heat/Cool Rooftop Unit	Carrier	48TJE008-521GA	0299G30190	Quarterly	Top floor southwest. This unit requires a new Heat exchanger, burner plate, flame electrode/sensor.- COMPLETE DEC 9, 2011 REF T/S#74227/#74295
Building #89 Festival House	AC-4-89	Top Floor N.W	Heat/Cool Rooftop Unit	Carrier	48TJE008-511GA	3397G30870	Quarterly	Top floor northwest
Building #89 Festival House	AC-5-89	2nd Floor, PTC Library	Split AC	Mitsubishi	MUH15NNV1	7000049T	Quarterly	2nd floor PTC library
Building #89 Festival House	AC-6-89	3rd Floor Booth	Split AC	Mitsubishi	MUH12NNV1	7000082T	Quarterly	3rd floor booth

Building #	Tag	Serves	Type	Make	Model	Serial#	INSP	Comments
Building #93 - Waterfront Theatre	EF-1	South Side	Exhaust Fan	NO TAG	N/A	N/A	Semi-Annual	South- Upper Roof
Building #93 - Waterfront Theatre	EF-2	N.E Side	Exhaust Fan	NO TAG	N/A	N/A	Semi-Annual	Northeast- Upper Roof
Building #93 - Waterfront Theatre	EF-3	N.W Side	Exhaust Fan	NO TAG	N/A	N/A	Semi-Annual	Northwest- Upper Roof
Building #93 - Waterfront Theatre	EF-5	Ground Level	Exhaust Fan	NO TAG	N/A	N/A	Semi-Annual	Wall mount - East wall ground level
Building #93 - Waterfront Theatre	EF-4	Lower Roof	Exhaust Fan	Penn	Domex	XQ82	Semi-Annual	Lower Roof
Building #93 - Waterfront Theatre	AC-1-93	Upper Theatre	Heat/Cool Rooftop Unit	Trane	YCD150D3HAAA	248100166D	Quarterly	Upper Theatre- DANGER- TECH SAFETY- Disconnect switch installed backwards, new economizer filter frames needed. BC gas code- all units to have gas regulators installed. Sundawn to supply and install econ frames and supply and install regulator- COMPLETE
Building #93 - Waterfront Theatre	AC-2-93	Lounge	Heat/Cool Rooftop Unit	Trane	YCC030F1MOBH	25151781H	Quarterly	Lounge- Condenser coil need to be combed out as fins are damaged. BC gas code- all units to have gas regulators installed. Sundawn to comb out coil and supply and install regulator- COMPLETE
Building #93 - Waterfront Theatre	AC-3-93	Upper Dressing Room	Heat/Cool Rooftop Unit	Trane	YSC060A3RHA13D OB0000	304101040L	Quarterly	Upper Dressing Room. Condenser coil need to be combed out as fins are damaged. BC gas code- all units to have gas regulators installed. Sundawn to comb out coil and supply and install regulator- COMPLETE

Building #	Tag	Serves	Type	Make	Model	Serial#
	34 EF-1-20		Exhaust Fan	Baldor	EM3313T-5	37F614T523