



Addendum / Addenda

No./N^o
1

| | | |
|---|--|---|
| Project Description / Description de projet U-85 CNG Filling & Electrical Charging Systems | | |
| Solicitation No./ No de sollicitation 14-22017 | Project No./N ^o de projet U85-3903 | W.O. No./N ^o d'ordre de travail A1-004334-11 |
| Departmental Representative / représentant ministériel Don Seabrook | | Date April 28, 2014 |
| <p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p> | | <p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p> |

Electrical

1. The site plan shown in detail 2/E01 did not print. Replace drawing 3903-E01 with attached drawing.
2. Concrete type for light pole base shown on detail 4/E01 to be 35MPa, 8% entrained air.
3. On detail 1/E02 delete reference to soils consultant.