

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British Columbia  
V6Z 0B9  
Bid Fax: (604) 775-9381

## **SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

### **Comments - Commentaires**

**Vendor/Firm Name and Address**  
**Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Issuing Office - Bureau de distribution**  
Public Works and Government Services Canada -  
Pacific Region  
800 Burrard Street, Room 219  
800, rue Burrard, pièce 219  
Vancouver  
British C  
V6Z 0B9

<b>Title - Sujet</b> Aeration Tower Modifications	
<b>Solicitation No. - N° de l'invitation</b> F1700-130721/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> F1700-130721	<b>Date</b> 2014-04-28
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$PWY-019-7239	
<b>File No. - N° de dossier</b> PWY-4-37009 (019)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-05-06</b>	<b>Time Zone</b> Fuseau horaire Pacific Daylight Saving Time PDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Ngan, Ken (PWY)	<b>Buyer Id - Id de l'acheteur</b> pwy019
<b>Telephone No. - N° de téléphone</b> (604) 658-2755 ( )	<b>FAX No. - N° de FAX</b> (604) 775-6633
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b> DFO - Kitimat River Hatchery - Kitimat, BC	

**Instructions: See Herein**

**Instructions: Voir aux présentes**

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm (type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

---

This solicitation amendment 004, (Addendum No. 1) is raised to provide changes to the completion date of work, and to provide responses to questions received.

All other terms and conditions remain unchanged.

Please find following Addendum No. 1

**ADDENDUM NO. 1**  
**KITIMAT RIVER HATCHERY AERATION TOWER MODIFICATIONS**

Due to longer than anticipated equipment lead times, the 12 week contract period will be extended to a 65 week contract period. This will provide the contractor with the opportunity to stage equipment on site until a work window presents itself the following year. The annual working window for the aeration tower remains unchanged and occurs between June 1<sup>st</sup> and July 16<sup>th</sup>. Major modifications to the aeration tower will not be permitted until June 1<sup>st</sup> of 2015.

Upon award of contract, the contractor is to provide a detailed project schedule which outlines when material will be on site and the construction sequence. No mobilization or demolition work will be permitted until the schedule has been reviewed by the departmental representative.

Department supplied equipment consists of the aeration columns, weir slide gates, and weir slide gate actuators. The contractor is responsible for the installation and commissioning, per plan and specification, of the aeration columns, weir slide gates, and weir slide gate actuators. This includes, but is not limited to cycling the gates, setting actuator torque limits and setting gate travel limit switches.

Extending the contract to a 65 week contract period will ensure minimal risk to fish rearing operations and minimize the risk of an operational imperative.

End of Addendum No. 1

Q1.) Request for Fibergrate to bid FRP as an alternative material for the areas listed below.

The solution is a substitution of FRP Handrail, Ladders, Grating & Structural member's vs Aluminum or Stainless Steel as described in bid documents. The scope of the work is as follows:

**Fibergrate Request:**

· FRP Grating / Supports / Weir Plates DWG's S1, S2, M1 & M4

A1.) Contractors should bid as per the specifications and drawings. Determination of whether or not substitutions will meet project specifications will be determined by the departmental representative after award of contract. In addition, the grating underneath the aeration columns acts as a structural support and must meet the load rating of the grating specified on sheet S1, while not exceeding a thickness of 2".