

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Aeration Tower Modifications	
Solicitation No. - N° de l'invitation F1700-130721/A	Amendment No. - N° modif. 004
Client Reference No. - N° de référence du client F1700-130721	Date 2014-04-28
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7239	
File No. - N° de dossier PWY-4-37009 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-05-06	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: DFO - Kitimat River Hatchery - Kitimat, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Les documents français seront disponibles sur demande.

This solicitation amendment 004, (Addendum No. 1) is raised to provide changes to the completion date of work, and to provide responses to questions received.

All other terms and conditions remain unchanged.

Please find following Addendum No. 1

ADDENDUM NO. 1
KITIMAT RIVER HATCHERY AERATION TOWER MODIFICATIONS

Due to longer than anticipated equipment lead times, the 12 week contract period will be extended to a 65 week contract period. This will provide the contractor with the opportunity to stage equipment on site until a work window presents itself the following year. The annual working window for the aeration tower remains unchanged and occurs between June 1st and July 16th. Major modifications to the aeration tower will not be permitted until June 1st of 2015.

Upon award of contract, the contractor is to provide a detailed project schedule which outlines when material will be on site and the construction sequence. No mobilization or demolition work will be permitted until the schedule has been reviewed by the departmental representative.

Department supplied equipment consists of the aeration columns, weir slide gates, and weir slide gate actuators. The contractor is responsible for the installation and commissioning, per plan and specification, of the aeration columns, weir slide gates, and weir slide gate actuators. This includes, but is not limited to cycling the gates, setting actuator torque limits and setting gate travel limit switches.

Extending the contract to a 65 week contract period will ensure minimal risk to fish rearing operations and minimize the risk of an operational imperative.

End of Addendum No. 1

Q1.) Request for Fibergrate to bid FRP as an alternative material for the areas listed below.

The solution is a substitution of FRP Handrail, Ladders, Grating & Structural member's vs Aluminum or Stainless Steel as described in bid documents. The scope of the work is as follows:

Fibergrate Request:

· FRP Grating / Supports / Weir Plates DWG's S1, S2, M1 & M4

A1.) Contractors should bid as per the specifications and drawings. Determination of whether or not substitutions will meet project specifications will be determined by the departmental representative after award of contract. In addition, the grating underneath the aeration columns acts as a structural support and must meet the load rating of the grating specified on sheet S1, while not exceeding a thickness of 2".