



**RETURN BIDS TO:
RETOURNER LES SOUMISSIONS A:
Bid Receiving/Réception des
sousmissions**

**RCMP / GRC
Procurement & Contracting services
c/o Commissionaires, F Division
6101 Dewdney Avenue
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:
(306) 780-3466**

**SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION**

**The referenced document is hereby
revised; unless otherwise indicated, all
other terms and conditions remain the
same.**

**Ce document est par la présente révisé;
sauf indication contraire, les modalités
de l'invitation demeurent les memes.**

Comments - Commentaries

**Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur**

Facsimile No. - No de télécopieur:

Telephone No. - no de téléphone:

Title-Sujet Roof Remediation, Depot, Regina, SK	
Solicitation No. - No. de l'invitation M5000-5-0197/A	Date 01 May 2014
Amendment No. - No modif. 02	
Client Reference No. - No. De Référence du Client 827488	
GETS Reference No. - No. de Référence de SEAG PW-14-00631570	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm Central Standard Time on - le 06 May 2014	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Bonny Manz, Senior Contracting Officer	
Telephone No. - No de téléphone (306) 780-3352	Fax No. - N° de FAX: (306) 780-3466
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police 5600 -11th Avenue Regina, SK S4P 3J7	
This document does not contain a PERSONNEL SECURITY Clearance requirements	
Delivery Required - Livraison exigée:	Delivery Offered - Livraison proposée
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



The purpose of this amendment is to add an Addendum as an attachment, with the heading "ARCHITECTURAL"; and answer the following questions:

Q1. Could you please confirm if there is a laydown area for a site office and storage container near the work area?

A1. *There will be an area for laydown, relatively close to the work site. The Site Office area may not be near the work area.*

Q2. Does the City of Regina require a building permit to be issued for the project? If so, what would be the turn around to get one approved?

A2. *Please see SACC Clause R2810D, Item GC1.8 regarding the contractor's responsibilities. The City would need to be contacted to answer the second part of this question.*

Q3. Is the Facia Vent Grill specified at 01100 2.4.5 the same Grill specified at 3.11.1? Metal ducting is to be installed in the specification, the detail 6/A3 mentions to maintain existing air space. Could you please clarify which or both are desired.

A3. *Yes, the grille is specified under 2.4.5 as the product designation with 3.11.1 noting the installation (execution) requirements. Both the grille and t-duct are required at each location/installation point.*

Q4. Could you please confirm if a Bid Bond is required and if so, is it 10% or 20%?

A4. *Please see SACC Clause R2710T, Item GI08. A Bid Bond or Bid Security is required, and it must be at least 10% of the bid amount.*