



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
P.O. Box 900
100 Hawk Avenue
Banff, Alberta T1L 1K2
Bid Fax: (403) 762-5057**

AMENDMENT TO
INVITATION TO TENDER
APPEL D'OFFRES

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Banff Field Unit
P.O. Box 900
Banff Alberta T1L 1K2

Title-Sujet Banff Legacy Trail Flood Damage Repairs		Date May 12, 2014
Solicitation No. - No. de l'invitation 5P421-15-0018		Amendment No. 001
Solicitation Closes L'invitation prend fin – at – á 02:00 PM on – le May 22, 2014		Time Zone Fuseau horaire - Mountain Time
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rose Marino		
Telephone No. - No de téléphone (403) 760-1319	Fax No. – No de FAX: (403) 762-5057	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Banff National Park See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date



Amendment 001

This amendment is raised to make the following changes to the tender document:

Question 1. Section 01 11 00, 1.02.1 describes replacement of the culvert with a precast concrete box culvert, but there are no drawings or details for a box culvert and there is no line item for the box culvert.

Answer 1. The original plan was to use a box culvert instead of CSP culverts. It was then changed to reflect what is now in the drawings. Please direct all references to a box culvert as changed to reflect the culverts shown on the drawings

Q2. Section 01 11 00, 1.02.1 also describes repair of the Carrot Creek Pedestrian bridge, but there are no details or line item for that work.

A2. All references to Carrot Creek bridge should be removed tender.

Q3. Section 01 11 00, 1.04 describes work covered by the contract documents, but does not mention the above box culvert or Carrot Creek.

A3. Remove all references to box culvert or Carrot Creek Bridge

Q4. Section 01 11 00, 1.06.1 states all work to be complete by July 30, 2014, but Section 01 32 16.06, 1.06 has different dates. Which is correct?

A4. The correct date should be July 30, 2014. The dates shown in Section 01 32 16.16 are incorrect. Also, in the same section - 01 32 16.16, 1.04.3, the spec asks for the schedule to be broken into three sections. Change the .2 reference to the Cascade Junction Culverts and Link Trail and delete .3 - Carrot Creek Bridge repairs.

Q5 Why is it a requirement that the Contractor shall have a Certificate of Recognition (COR) or Registered Safety Plan (RSP) including a site specific Health and Safety Plan acceptable to the Departmental Representative.

A5. Remove the requirement for a Certificate of Recognition (COR) or Registered Safety Plan (RSP). Only to submit a site specific safety plan.

All other terms, clauses and conditions remain unchanged.