

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions
- TPSGC
11 LaurierSt./ 11, rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau
Québec
K1A 0S5
Bid Fax: (819) 997-9776

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

This document contains a security requirement.

Ce document contient une condition de sécurité

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Maintenance & Professional Consulting Services
Division (FK)
11 Laurier St./ 11, rue Laurier
3C2, Place du Portage, Phase III
Gatineau
Québec
K1A 0S5

Title - Sujet Fire Alarm/Sprinkler - Maint. Contr	
Solicitation No. - N° de l'invitation EJ196-141167/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client 20141167	Date 2014-05-13
GETS Reference No. - N° de référence de SEAG PW-\$\$FK-289-64993	
File No. - N° de dossier fk289.EJ196-141167	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-05-21	Time Zone Fuseau horaire Eastern Daylight Saving Time EDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Maquiling(fk div), Amalia O.	Buyer Id - Id de l'acheteur fk289
Telephone No. - N° de téléphone (819) 956-5978 ()	FAX No. - N° de FAX (819) 956-3600
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This solicitation amendment 001 is issued 1) to revise the Statement of Work (SOW) and 2) to answer questions raised by potential bidders.

1) Delete SOW in its entirety and replace with the attached.

2) Questions and Answers

Q1 During our site visit, one individual ask how many personnel is required on site during annual inspections

A1 The contract requires for two personnel on site for annual inspections.

Q2 During our site visit, one individual ask how many personnel is required on site during monthly inspections

A2 One personnel with dual training, certified Sprinkler and Fire Protection Installer with Canadian Fire Alarm Association (CFAA) certification, otherwise they would require two personnel one with each certification.

Q3 What are the current on site procedures by the current service provider. Could you provide a copy of all the last water test and all inspection reports regarding the items listed below.

1.6.5.3 Water generated from the back-flush of the sprinkler system must be disposed in accordance with Municipal, Provincial and Federal requirements

1.6.5.4 Disposal of water generated from back-flush of the sprinkler system into waterways, storm or sanitary sewers is prohibited, unless specific approval to discharge into the sanitary sewer is provided by the municipality. Transportation of this liquid waste by a licensed hauler and disposal to an approved wastewater treatment facility may be required.

1.6.5.5 Fire protection, including portable water being utilized for fire protection system testing, must be de-chlorinated via de-chlorination equipment etc..items 1 to 4

2.3.2.1

1) Five year inspection reports

2.3.2.2 1)2)

A3 Currently, there are no permits required for the disposal of water-based fire protection water for inspections or service. The current equipment inventory does not include building fire pumps, therefore, the deployment of de-chlorination equipment would not be required for this contract.
Unable to send confidential water-based fire protection reports

No other changes apply