



Addendum / Addenda

No./N^o
4

Project Description / Description de projet U-85 CNG Filling & Electrical Charging Systems		
Solicitation No./ No de sollicitation 14-22017	Project No./N ^o de projet U85-3903	W.O. No./N ^o d'ordre de travail A1-004334-11
Departmental Representative / représentant ministériel Don Seabrook		Date May 14, 2014
<p>Notice: This addendum shall form part of the tender documents and all conditions shall apply and be read in conjunction with the original plans and specifications.</p>		<p>Nota: Cet addenda fait partie intégrale des dossiers d'appel d'offres; toutes les conditions énoncées doivent être lues et appliquées en conjonction avec les plans et les devis originaux.</p>

Site/ General Clarification

1. No barbed wire required- Fence to be 2.44M (8ft- 0in) in total height.
2. Corner posts to be 4-1/2" diameter (4" NPS pipe size) and intermediate posts to be 3-1/2" diameter (3" NPS pipe size). Provide all required connections to suit
3. Intermediate posts and corner posts shall be schedule 40, hot dipped, zinc coated to ASTM A53/A53M-02.