

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
PO Box 1408 , Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1
Bid Fax: (204) 983-0338

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Western Region
P.O. Box 1408, Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3C 2Z1

Title - Sujet Elevator Long Term Maintenance	
Solicitation No. - N° de l'invitation E0208-141914/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client PWGSC	Date 2014-05-14
GETS Reference No. - N° de référence de SEAG PW-\$PWZ-211-8965	
File No. - N° de dossier PWZ-3-36316 (211)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-05-26	Time Zone Fuseau horaire Central Daylight Saving Time CDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Wiebe, Amanda	Buyer Id - Id de l'acheteur pwz211
Telephone No. - N° de téléphone (204) 983-7032 ()	FAX No. - N° de FAX (204) 983-7796
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This solicitation amendment is raised to address all clarifications and questions as a result of a site visit held on May 6, 2014:

Clairification was provided as follows:

- Annex A - 2.6.1.1 and 2.6.1.2 Exclusions

Causes beyond the Contractor's control would be things like floods, fire etc. Not if a manufacturer's part breaks, etc.

- Annex A - 2.11 - Repairs

The contractor must immediately inform the Technical Authority in writing of the need for repairs that are excluded from the contract. This will enforced stringently.

- Annex A - 2.12 – Cleaning and Painting

Painting will be done within 1 year of contract commencement and every five years thereafter.

- Annex A - Section 2-Particular Requirements

Contractor must complete the update log/elevator maintenance book prior to leaving.

Questions and Answers:

Question #1: Will a programming tool be supplied?

Answer #1: No, all programming can be done by via the computer, now on site.

Question #2: Do we have drawings?

Answer #2: Yes, the O&M Manuals are current and have all the up to date schematics.

Question #3: Is the hydraulic elevator included in the contract?

Answer: No, only the 2 main foyer passenger elevators are included in this contract.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME.