



### Q&A #3

**Date:** May 22, 2014

**Project:** 01B46-14-0028- Plans and specifications preparation and site supervision for the reroofing of section N. 9 and N. 11.

---

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Please note: In order to provide the integrity of the questions that AAFC has received from bidders, you will find in this document the questions in the language that they were asked.

---

#### **Questions and answers:**

Q1. Is the AMCQ certificate of guarantee required?

A1. No

Q2. Is the skylights waterproofing included in the Architect's mandate?

A2. No. However, the waterproofing of the roof curb under the skylight will need to be ensured.

Q3. Are there any electrical conduits on the roof?

A3. No.

Q4. If a Mechanical Engineer needs to be hired regarding the chiller on the roof, who will bear the cost?

A4. The Architectural firm is responsible to hire, at its own cost, any sub-consultants required.

---

**ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED**