

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

THIS AMENDMENT IS RAISED TO ANSWER
QUESTIONS 1-3 FROM POTENTIAL BIDDERS.
SEE HEREIN.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9

Title - Sujet LOW PRESSURE STEAM BOILER	
Solicitation No. - N° de l'invitation W010S-15D006/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client W010S-15-D006	Date 2014-06-09
GETS Reference No. - N° de référence de SEAG PW-\$HAL-220-9281	
File No. - N° de dossier HAL-4-73020 (220)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-07-16	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Dunphy, Nancy	Buyer Id - Id de l'acheteur hal220
Telephone No. - N° de téléphone (902) 496-5481 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This Amendment 001 is raised to answer potential bidders questions as follows:

Q1

Could you please forward specifications and drawings to us for this project.

A1

See attached cut-away view.

Q2

What is the voltage for the power to boilers, as well as the gas supply pressure to the boiler?

A2

The voltage could be 20 volts two phase or 600 volts three phase.

The burner gas pressure would be 21 PSI in to the Bldg. and 3-4 PSI to burner.

Q3

Is this burner low/high/low firing, or full modulation?

A3

The burner is full modulation.

All other terms and conditions remain unchanged

CUT-AWAY VIEW

