



**RETURN BIDS TO:  
RETOURNER LES SOUMISSIONS A:  
Bid Receiving/Réception des  
sousmissions**

**RCMP / GRC  
Procurement & Contracting services  
c/o Commissionaires, F Division  
6101 Dewdney Avenue  
Regina, SK S4P 3K7**

**Facsimile Number for Amendments:  
(306) 780-3466**

**SOLICITATION AMENDMENT  
MODIFICATION DE L'INVITATION**

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les memes.

**Comments - Commentaries**

**Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur**

**Facsimile No. - No de télécopieur:**

**Telephone No. - no de téléphone:**

Title-Sujet Room Renovations in D Block, Second Floor, Depot, Regina, SK	
Solicitation No. - No. de l'invitation M5000-5-0880/A	Date 09 June 2014
Amendment No. - No modif. 01	
Client Reference No. - No. De Référence du Client 206496	
GETS Reference No. - No. de Référence de SEAG PW-14-00639252	
Solicitation Closes -L'invitation prend fin at - à 2 :00 pm <b>Central Standard Time</b> on - le 18 June 2014	
F.O.B. - F.A.B. Destination	
Address Enquiries to: - Adresser toutes questions à: Teresa Hengen, Contracting Officer	
Telephone No. - No de téléphone (306) 780-8179	Fax No. - N° de FAX: (306) 780-3466
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: Royal Canadian Mounted Police 5600 -11 <sup>th</sup> Avenue Regina, SK S4P 3J7	
This document does not contain a <b>PERSONNEL SECURITY</b> Clearance requirements	
Delivery Required - Livraison exigée: See Herein Voir aux présentes	Delivery Offered - Livraison proposée See Herein Voir aux présentes
Name and title of person authorized to sign on behalf of Vendor/Firm Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur	



The purpose of this amendment is to provide a list the companies that attended the site visit:

Q1. Is there an environmental report available for the building?

A1. **No**

Q2. Could you please provide the list of contractors which attended the mandatory site visit?

A2. **Yes, site visit attendees:**

Luxury Mechanical

Quorex Construction

MPM Construction

The Floor Show

Westridge

Caltec Flooring

North 40

Express Electric

KMC Mechanical

James Johnson Enterprises

KD Mechanical

Associated Asbestos

ICM

Bath Fitter

CK Painting

Q3. The plans for the tender received have no dimensions for Living Units, Storage Room, Lounge or hallway. Did we miss this at our end or is there more information coming? It would not be impractical to provide a competitive price without at least some rough dimensions to supply to our subcontractors for their price

A3. **No, refer to section 2 and the opportunity to measure everything was offered during the site visit.**

Q4. It would appear the Rad Cover & Head Board are all one piece. With swing doors & lower grill location to be included in construction of this millwork. Are we missing some of the package or is there more design information to follow?

Q4. **There is no more information to follow as per Annex 1, headboard section and section 9.3.11 in the sow.**

Q5. It would appear all living unit washrooms receive a new counter & sink? We cannot locate any millwork drawing for the construction of this counter top. Could you please forward if you have this information?

A5. **No, it was the contractors' responsibility to take measurement during site visit.**

Q6. Can you confirm if Room 248 is a storage room or a personal living unit? It is marked up on plans as both?

Q6. **It is a personal living unit**

Q7. Is there a finish detail to rooms 227 & 237? Or is that not part of the scope of work?

A7. **Yes they are part of the sow, they are both storage rooms**

Q8. Is there the opportunity to work a 10 hour day or longer with a 6-7 day work week to allow for a quicker completion for the project?

A8. **The schedule will be discussed at the start-up meeting after the contract is awarded, but as long as we have a commissionaire available on site, it shouldn't be a problem.**



Q9. Is there an area near the main entrance for demolition bin placement?

**A9. Yes, location to be discussed at the start-up meeting after the contract is awarded.**

Q10. Is there a location on site to locate a small site office, first aid station, one unit & 20' storage container?

**A10. An office and a first aid station could be set up on the second floor and the location could be decided by the contractor as long as it does not delay the completion of the room. Yes, location of storage container to be discussed at the start-up meeting after the contract is awarded.**

Q11. Just to confirm, one personal living unit is to be completed first for review by client. Can we assume the demolition & other work will continue on at the same time as the mock up unit is being complete and reviewed?

**A11. No, if referring to section 9.4.13, this is for the ceramic tile only.**

Q12. Does the washroom tile floor require an anti-cracking membrane installed on concrete floor before ceramic tile is installed?

**A12. No**

Q13. Is the paint colors to the walls & ceilings and in the lounge the same as the hallway?

**A13. Yes**