



# TENDER AMENDMENT

## RETURN BIDS TO:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3  
Bid Fax: (403) 292-4475

The referenced document is hereby amended: unless otherwise indicated, all other terms and conditions of the contract remain the same.

## Issuing Office:

Parks Canada Agency  
635 – 8 Avenue S.W., Suite 1300  
Calgary, AB T2P 3M3

# MODIFICATION D'APPEL D'OFFRES

## RETOURNER LES SOUMISSIONS À :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300,  
Calgary, AB T2P 3M3  
N° de télécopieur pour soumissions : (403) 292-4475

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

## Bureau de distribution :

Agence Parcs Canada  
635 – 8 Avenue S.O., pièce 1300  
Calgary (AB) T2P 3M3

<b>Title:</b> Highway 93 South Asphalt Paving in Kootenay National Park, BC		
<b>Sujet :</b> Asphaltage de la route 93 Sud en Parc national Kootenay, BC		
<b>Solicitation No.: / N° de l'invitation :</b> 5P420-14-5037/A- REVISION#1	<b>Amendment No.: / N° de modification de l'invitation :</b> 04	<b>Date:</b> June 17, 2014  <b>Date :</b> 17 juin 2014
<b>GETS Reference No.: / N° de référence de SEAG :</b> PW-14-00639806		
<b>Solicitation Closes: / L'invitation prend fin :</b>		
<b>At:</b> 02:00 PM	<b>On:</b> June 24, 2014	<b>Time Zone:</b> Mountain Daylight Time (MDT)
<b>À :</b> 14h00	<b>Le :</b> 24 juin 2014	<b>Fuseau horaire :</b> Heure Avancée des Rocheuses (HAR)
<b>Address Inquiries to: / Adresser toute demande de renseignements à :</b> Adam Krisch		
<b>Telephone No.: / N° de téléphone :</b> (403) 292-4560	<b>Fax No.: / N° de télécopieur :</b> (403) 292-4475	<b>Email Address: / Courriel :</b> <a href="mailto:adam.krisch@pc.gc.ca">adam.krisch@pc.gc.ca</a>

## TO BE COMPLETED BY THE BIDDER (type or print)

<b>Vendor/Firm Name</b>	
<b>Address</b>	
<b>Name of person authorized to sign on behalf of the Vendor/Firm</b>	
<b>Title</b>	
<b>Signature</b>	<b>Date</b>



**This amendment is raised to respond to bidder questions.**

**1. Question:**

Regarding Section 32 12 16, Asphalt Concrete Pavement:

1. 1.2.1.3 mentions 60mm thickness overlay per Table 2014-1. There is no 60mm overlay noted in the Table.
2. 1.2.2 states that the aggregate shall be obtained from outside the park. Should this paragraph be deleted or reference the aggregate produced in Settler Pit?

The Environmental Assessment Screening Report Amendment refers to crushing 24 hours per day. Will this be permitted or required for this project?

**Answer:**

1. **Delete:** Section 32 12 16 Item 1.2.1.3 "Supply and placement of Hot Mix Asphalt Concrete Pavement Type H1 overlay. Thickness shall be 60mm (average) thickness. Refer to Table 2014-1-Kootenay National Park, for details."  
  
**Insert:** Section 32 12 16 Item 1.2.2 "Asphalt aggregate used shall consist of AT Designation Class 16 Asphalt Aggregate crushed in Settler's Pit by the contractor in accordance with AT Standard Specifications for Highway Construction 2010 Section 3.2 - Aggregate Production and Stockpiling."
3. **Delete:** Section 32 12 16 Item 1.3.3 "Preparing an asphalt mix design (including anti-stripping test) for aggregate purchased from Parks Canada or from outside the park shall be considered incidental to "Unit Price Item 2 - Asphalt Concrete Pavement" and no additional payment will be measured for payment."  
  
**Insert:** Section 32 12 16 Item 1.3.3 "Preparing an asphalt mix design (including anti-stripping test) for aggregate crushed in Settler's Pit shall be considered incidental to "Unit Price Item 3 - Class 1 Asphalt Pavement KNP: 93S km 52.0 - km 62.0" and no additional payment will be made."
4. **Delete:** Section 32 12 16 Item 1.3.4 "Producing AT Designation Class 16 Asphalt Aggregate outside the park in accordance with AT Standard Specifications for Highway Construction 2010 Section 3.2 - Aggregate Production and Stockpiling shall be considered incidental to "Unit Price Item 2 - Asphalt Concrete Pavement" and no additional payment will be measured for payment."  
  
**Insert:** Section 32 12 16 Item 1.3.4 "Producing AT Designation Class 16 Asphalt Aggregate by crushing in Settler's Pit in accordance with AT Standard Specifications for Highway Construction 2010 Section 3.2 - Aggregate Production and Stockpiling shall be measured for payment under "Unit Price Item 1A - Crushing, hauling and stockpiling of Designation 1 Class 16 asphalt aggregates in Settler's Pit".
5. **Delete:** Section 01 11 00 Item 1.5.2 "The Contractor shall supply aggregates and produce asphalt concrete pavement."  
  
**Insert:** Section 01 11 00 Item 1.5.2 "The Contractor shall crush aggregates in Settler's Pit and produce asphalt concrete pavement."
6. **Delete:** Section 01 11 00 Item 1.7.2.5 "The Contractor will be permitted to setup an asphalt plant at Settler's Pit, Kootenay NP as directed by the Departmental Representative."  
  
**Insert:** Section 01 11 00 Item 1.7.2.5 "The Contractor will be permitted to setup a crusher and an asphalt plant at Settler's Pit, Kootenay NP as directed by the Departmental Representative."
7. The EIA addresses crushing in Settler's Pit and is applicable to this contract.



**Bidders are reminded that:**

The Invitation to Tender document for tender 5P420-14-5037/A titled *Highway 93 South Asphalt Paving in Kootenay National Park, BC* and dated June 06, 2014 is replaced with an updated Invitation to Tender document dated and issued June 12, 2014 numbered 5P420-14-5037/A-REVISION#1.

**Bidders MUST submit bids with the Invitation to Tender document dated June 12, 2014 numbered 5P420-14-5037/A-REVISION#1.**

***All other terms and conditions remain the same.***