



Q&A #1

Date: June 17, 2014

Project: 01B46-14-0040- Fire Stopping Materials and Fire Damper installation in fire Rated Separations

Bidders must make sure that their bids are based on the latest version of the tender documents published and take into consideration the following amendments and information, including any information provided on amendments or Q&As previously published for this project.

Bidders that do not comply with this requirement will be discarded.

Please note: In order to provide the integrity of the questions that AAFC has received from bidders, you will find in this document the questions in the language that they were asked.

Modification to the closing date:

Invitation to tender, solicitation closing:

Replace:

Wednesday, June 25, 2014 at 2:00PM, EDT

By:

Thursday, July 3rd, 2014 at 2:00PM, EDT

Questions and answers:

- Q1. Are specifications available?
- A1. Yes. Specifications will be available on Buyandsell.gc.ca as an attachment.
- Q2. How will the scheduling for building systems shutdowns be arranged?
- A2. AAFC will coordinate building systems shutdowns as necessary.
- Q3. Is painting of fire stopping material required in public areas?
- A3. Painting of fire stopping material is not required in mechanical shafts or in places not normally visible in corridors, such as the underside of penthouse floor decking.
-

ALL OTHER TERMS AND CONDITIONS REMAIN UNCHANGED