


A GENERATOR ROOM & MECHANICAL ROOM POWER
1:50



B MECHANICAL MEZZANINE POWER
1:50

GENERAL NOTES:

- DISCONNECTION OF MECHANICAL EQUIPMENT WILL BE PHASED. COORDINATE WORK WITH THE MECHANICAL CONTRACTOR ON SITE.
- REMOVE ALL REDUNDANT CONDUCTORS AND RACEWAYS BACK TO SOURCE.

KEY NOTES:

- NEMA 3R JUNCTION BOX COMPLETE WITH SECURED COVER. JUNCTION BOX TO BE EQUIPPED WITH A BARRIER TO SEPARATE DIFFERENT SOURCES OF VOLTAGE.
- EXISTING DDC PANEL. COORDINATE WORK WITH MECHANICAL CONTROLS CONTRACTOR ON SITE.
- HEAT TRACE CONNECTION. COORDINATE WORK WITH MECHANICAL CONTRACTOR ON SITE.
- RELOCATE TWO STARTERS, TWO DISCONNECT SWITCHES, AND ALL ASSOCIATED CONDUIT, CONDUCTORS, AND JUNCTION BOXES, AND INSTALL ADJACENT TO EXISTING PANELBOARD DP1-BB1. COORDINATE WORK WITH MECHANICAL CONTRACTOR ON SITE.



Revision/	Description/Description	Date/Date
C	ISSUED FOR TENDER	14/05/02
B	100% SUBMISSION	14/01/04
A	95% SUBMISSION	13/12/13

Client/client
AGRICULTURE AND AGRI-FOODS CANADA

Project title/Titre du projet
PARC AGASSIZ AGASSIZ, B.C.
ATES SYSTEM REPLACEMENT

Approved by/Approuvé par
T. WONG
Designed by/Concept par
K. BRZICA
Drawn by/Dessiné par
A. GHARAPETIAN
PWGSC Project Manager/Administrateur de Projets TPSGC
T. DUNPHY
PWGSC, Architectural and Engineering Resources Manager/
Ressources Architectural et de Directeur d'ingénierie, TPSGC
P. FUNG

Client/client
Drawing title/Titre du dessin
MECHANICAL ROOM AND MECHANICAL MEZZANINE POWER AND MCC ELEVATIONS

Project No./No. du projet	Sheet/Fauille	Revision no./La Révision no.
R.054815.001	E2.04-1 OF	C

