

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 1T3
Bid Fax: (902) 496-5016

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Acquisitions
1713 Bedford Row
Halifax, N.S./Halifax, (N.É.)
B3J 3C9

Title - Sujet OFFICE FURNITURE-4th Floor Demo	
Solicitation No. - N° de l'invitation E0225-142334/A	Amendment No. - N° modif. 006
Client Reference No. - N° de référence du client 20142334	Date 2014-06-23
GETS Reference No. - N° de référence de SEAG PW-\$HAL-219-9259	
File No. - N° de dossier HAL-4-73003 (219)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-07-02	Time Zone Fuseau horaire Atlantic Daylight Saving Time ADT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Richard, Linda K.	Buyer Id - Id de l'acheteur hal219
Telephone No. - N° de téléphone (902) 496-5261 ()	FAX No. - N° de FAX (902) 496-5016
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

AMENDMENT 006

This solicitation is amended to reflect the following.

1. Bid Closing Date

Delete: June 26, 2014 2:00 p.m. ADT

Insert: July 2, 2014 2:00 p.m.

Regarding: Items 10, 11, 12 Demountable Wall Systems

2. 1. General - 1.2

Delete: In its entirety

Insert: The assembly shall include, but not be limited to, wall panels complete with ceiling and base trims, door frames complete with hardware, clear glass panels, electrical outlets and switches where indicated on drawings, complete with in-feeds and harnesses for power and data access and operation.

3. 1. General - 1.5

Delete: In its entirety

Insert: Solid walls to have a paint finish.

4. 1. General - 1.12

Question: Continuous vertical connector. Our attachment uses an integrated sound and light seal within the frame assembly that allows for access to the slots without the need to "field cut, eliminating the need for the vertical connector."

Answer: An integrated sound and light seal is acceptable.

5. 1. General - 1.18

Question: Continuous base: We use a separate base between each wall panel. This allows for the full reconfiguration of our wall system, including being able to reposition doors and door frames without the need to fully remove the system."

Answer: A modular base is acceptable.

6. 1. General - 1.20

Question: Electrics: Our modular electrical system is installed on-site is not “factory-installed.” This allows for full flexibility including the ability to be changed or reposition during installation.

Answer: The electrical installation as described is fine.

7. 6. Warranty - 6.1

Delete: In its entirety

Insert: Product shall be covered under a 10 year warranty covering all parts and components including but not limited to modular electrics, doors and surfaces.

8. 5. Certifications - 5.2

Delete: In its entirety

Insert: Solid painted wall units to have a Class B rating in accordance with ATSM E84 “Standard Test Methods of Surface Characterists of Building Materials.”

9. 5. Certifications - 5.8

Delete: In its entirety

10. 5. Certifications - 5.4

Delete: In its entirety

Insert: Solid wall units are available with a minimum 40 STC and glass panels are available with a minimum of 31 STC in accordance with ASTM E 90-90 “Method for Laboratory Measurements of Airborne Sound Transmission Loss of Building Partitions.”

11. 5. Certifications - 5.9

Delete: In its entirety

12. 5. Certifications - 5.6

Question: Please advise if the Canadian Electrical Code CSA standards are acceptable for electrical components.

Answer: CSA standards are acceptable.

13. 5. Certifications - 5.7

Delete: In its entirety

14. 1. General Sections 1.20 and 5.6

Question: Could you please provide drawings that indicate where the electrics will be required.

Answer: At this time the partitions do not require electrical. Power and data will be accessed through base building walls.

15.

Question: Please advise whether the glazed sections are to be single glazed or double glazed.

Answer: Glazed panels shall be double glazed.

16.

Question: Can the client please confirm if locks are required on the doors for the demountable walls.

Answer: Yes, locks will be required for the doors in the demountable walls.

17. AutoCad Drawings

Question: Could you please provide AutoCad plans of the space?

Answer: We will make them available after the tender close to the successful bidder(s).

All other terms and conditions remain unchanged.

Solicitation No. - N° de l'invitation

E0225-142334/A

Amd. No. - N° de la modif.

006

Buyer ID - Id de l'acheteur

hal219

Client Ref. No. - N° de réf. du client

20142334

File No. - N° du dossier

HAL-4-73003

CCC No./N° CCC - FMS No/ N° VME
