

Solicitation No. – N° de l’invitaion  
EA011-150313/A

Amd. No. - N° de la modif.  
2

Buyer ID – Id de l’acheteur  
pwd008

Client ref. No. - N° de ref. du client  
20150132

File No. N° du dossier  
PWD-4-37025

CCC No./N° CCC – FMS No/N° VME

---

ADDENDUM NO. 1

R.066776.001 – Segment “A” Repaving, Gros Morne National Park, NL

\*\*\*\*\*

**THE FOLLOWING AMENDMENT TO THE BID DOCUMENTS IS EFFECTIVE IMMEDIATELY. THE  
ADDENDUM SHALL FORM A PART OF THE CONTRACT DOCUMENTS.**

\*\*\*\*\*

SPECIFICATION

- .1 Section 34-71-13 – Steel W-Beam Guiderail – Replace Clause 2.1.1.1 with the following:  
**Steel rail and terminal sections: to AASHTO M180. Class B (3.5 mm think), Type I zinc coated.**
- .2 Section 01-11-00 – General Instructions – Replace Clause 1.1.7 with the following:  
**Owner-supplied stockpiles of crushed aggregate and blasted rock, suitable for further processing, are available for use at the Contractor’s discretion on and after August 10, 2014. Stockpiles are located at Rocky Barachois Pit. (Approximately 15.8 km North of the South Park Boundary). Refer to Section 31-05-17 – Aggregates: General.**
- .3 Section 31-05-17 – Aggregates: General – Replace Clause 1.3.1 with the following:  
**Owner-supplied stockpiles of crushed aggregate and blasted rock, suitable for further processing, are available for use at the Contractor’s discretion, without recourse to the owner, on and after August 10, 2014. Stockpiles are located at Rocky Barachois Pit. (Approximately 15.8 km North of the South Park Boundary). Obtain permission from Parks Canada Asset Manager prior to inspection of owner-supplied stockpiles.**

**By submission of its bid, the Bidder confirms that it has read and understands the requirements expressed in all addenda and has included all costs of these requirements in its Total Bid Amount.**

**All other Terms and Conditons remain unchanged.**

\*\*\*\*\*