

# Agriculture and Agri-Food Canada (AAFC)

# Project Title: LIGHTING RETROFIT T12 TO T8 FLUORESCENT FIXTURES CONVERSION

Research Farm Normandin Normandin, Québec


Tenders must be received by: 2:00 PM, Eastern Daylight Time

On July 16<sup>th</sup>, 2014 at the following address:

Agriculture and Agri-Food Canada


Corporate Management Branch Assets Team – Eastern Service Centre **TENDER RECEIVING UNIT** 2001 University St., Suite 671-TEN Montreal, QC H3A 3N2

Note: Tenders received at a location other than this one will be rejected.



## Table of Contents

Part I	Additional Instructions
Appendix A	Instructions to Bidders (AAFC/AAC5319)
Appendix B	Special Instructions to Bidders (AAFC/AAC5318)
Appendix C	Bid and Acceptance Form (AAFC/AAC5312)
Appendix D	General Conditions for Minor Works (AAFC/AAC5316)
Appendix E	Technical Specifications and Plans: building lighting plans (E1, E3, E4, E11, E15, E17, E20, E24 and E30).
Appendix F	Insurance Terms (AAFC/AAC5315)
Appendix G	Form A - Subcontracting



#### PART I. ADDITIONAL INSTRUCTIONS

#### Al 1. Definitions

- Tenderers/Bidders: Individual or Firm responding to the request for tender.
- Contracting Authority: is the individual within Agriculture and Agri-Food Canada (AAFC) who is responsible of the integrity and the transparency of the competitive tender process. The Contracting Authority is also responsible for the issuance of the contract and any amendment related to it.
- *Project Manager.* is the individual within AAFC who is responsible for all matters concerning the technical content of the Work under the awarded contract.

#### Al 2. <u>Context</u>

The project generally consists of converting T12 fluorescent lighting fixtures to T8 (4' lamps). Ballasts, lamps and sockets will be replaced.

#### Al 3. Site Visit

A site visit is scheduled for <u>Wednesday</u>, <u>July 9<sup>th</sup></u>, <u>2014 at 09:00AM</u> at the **Research Farm Normandin** located at 1468 St-Cyrille, Normandin, Québec, G8M 4K3. Tenderers are requested to be present at the reception desk at least 10 minutes prior to the meeting. No other pre-tender meeting will be scheduled during the tender process.

Attendance by interested tenderers is not mandatory. However, the tenderer has the responsibility to ascertain he/she has knowledge of all the facts and information on the nature and provision of the work requested. Lack of knowledge of the conditions will not be a valid excuse accepted for the inability to satisfactorily meet the services required.

#### AI 4. <u>Requests for information</u>

All requests for information regarding this call for tenders MUST be presented in <u>writing</u> and sent exclusively to the *Contracting Authority* identified below, as soon as possible during the tender period and no later than five (5) working days before the end of this period, in order to allow sufficient time to answer. Inquiries received after that time might not be answered prior to the tender closing date.

Contracting Authority:

Saad Ibrahimy Agriculture and Agri-Food Canada 2001 University Street, 671 -TEN Montreal, Quebec Telephone: 514 315-6140 Facsimile: 514 283-3143 Email: saad.ibrahimy@agr.gc.ca



#### AI 5. <u>Revision of Tenders (Modification to Clause IB10, Appendix A)</u>

The following paragraph shall be added after paragraph 1):

"...However, any indication of tender price modification **shall not reveal** the amount of the original or the revised total tender. Any indication of the old or the new total tender will get the often discarded automatically."

#### AI 6. <u>Receipt of Tenders</u>

Sealed tenders will be received at the following address:

Agriculture and Agri-Food Canada Assets Team - Eastern Service Centre Tender Receiving Unit 2001 University Street, suite 671-TEN Montreal, Quebec, H3A 3N2

AAFC will not necessarily accept the lowest tender nor any tender, in whole or in part.

#### AI 7. <u>Presentation of Tenders</u>

Tenderers must submit their tenders, in a sealed envelope marked <u>"Tender - Confidential"</u> as well as the project reference number: **01B46-14-0056**.

#### Al 8. <u>Contractual Documents</u>:

The following documents will form part of any resulting contract:

- Appendix C Bid and Acceptance Form (AAFC/AAC5312)
- Appendix D General Conditions for Minor Works (AAFC/AAC5316)
- Appendix E Technical Specifications
- Appendix F Insurance Terms (AAFC/AAC5315)
- Appendix G Form A Subcontracting



#### Al10. T4-A

The Contractor shall complete and submit this T4-A Certification within fourteen (14) days of Notification of Contract award and within fourteen (14) calendar days immediately following any change to the information already provided under the Contract. Failure to provide this information or failure to provide the correct information shall result a fundamental breach of the Contract.

- 1. The Contractor shall enter a [x] in one of the boxes below opposite the description that best describe its status.
- A business incorporated either federally or provincially;
- An unincorporated business, either as a sole proprietor or a partnership; or
- An individual.

#### Note. The information provided in section 2 must correspond with that provided in Section 1.

Corporate or unit Business or indiv	ncorporated vidual's name:		
Street Name or E	Box Number:		
City, Town or Vil	lage:		
Province:			
Postal Code:			
E-mail address:			
	tor shall complete section 2(a) or 2(b) or 2(c),	whichever is applicable to its	situation.
a)	lf incorporated: Business Number (BN) GST/HST Number: T2 Corporation Tax Number (T2N)	; ;	, or
b)	If unincorporated: Business Number (BN) GST/HST Number: T2 Corporation Tax Number (T2N) Note: The Unicorporated Business Nam the Revenue Canada Business Number or		, or , whichever is applicable
c)	If individual: Business Number (BN) GST/HST Number: T2 Corporation Tax Number (T2N) Note: The Individual's Name must be the Insurance Number.	, , same as the name associated	, or , whichever is applicable

3. WE HEREBY CERTIFY that I/WE have examined the information provided above, including the legal name, address and Revenue Canada identifier (SIN, BN, GST/HST No., T2N), as applicable, and that it is correct and complete, and fully discloses my/our identification.

Signature of Contractor


Title of Signatory

Date



Appendix "A"

# INSTRUCTIONS TO BIDDERS



# **INSTRUCTIONS TO BIDDERS**

- IB01 Completion of Bid
- IB02 Identity or Legal Capacity of the Bidder
- IB03 Applicable Taxes
- IB04 Tax to Be Included
- IB05 Capital Development and Redevelopment Charges
- IB06 Registry and Pre-qualification of Floating Plant
- IB07 Listing of Subcontractors and Suppliers
- IB08 Bid Security Requirements
- IB09 Submission of Bid
- IB10 Revision of Bid
- IB11 Acceptance of Bid
- IB12 Bid Costs
- IB13 Compliance with Applicable Laws
- IB14 Approval of Alternative Materials
- IB15 Income Tax Requirement
- IB16 Contingency Fees
- IB17 Status of the Bidder

#### IB01 Completion of Bid

- 1) The bid shall be:
  - submitted on the BID AND ACCEPTANCE FORM provided by AAFC or on a clear and legible reproduced copy of such BID AND ACCEPTANCE FORM that must be identical in content and format to the BID AND ACCEPTANCE FORM provided by AAFC;
  - (b) based on the Bid Documents listed in the SPECIAL INSTRUCTIONS TO BIDDERS;
  - (c) correctly completed in all respects;
  - (d) signed, with an original signature, by a duly authorized representative of the Bidder; and
  - (e) accompanied by any other document or documents specified elsewhere in the solicitation where it is stipulated that said documents are to accompany the bid.
- 2) Subject to paragraph 6) of IB11, any alteration to the pre-printed or pre-typed sections of the BID AND ACCEPTANCE FORM, or any condition or qualification placed upon the bid shall be cause for disqualification. Alterations, corrections, changes or erasures made to statements or figures entered on the BID AND ACCEPTANCE FORM by the Bidder shall be initialed by the person or persons signing the bid. Initials shall be original(s). Alterations, corrections, changes or erasures that are not initialed shall be deemed void and without effect.
- 3) Unless otherwise noted elsewhere in the Bid Documents, facsimile copies of bids are not acceptable.

#### IB02 Identity or Legal Capacity of the Bidder

- 1) In order to confirm the authority of the person or persons signing the bid or to establish the legal capacity under which the Bidder proposes to enter into Contract, any Bidder who carries on business in other than its own personal name shall, if requested by Canada, provide satisfactory proof of:
  - (a) such signing authority; and
  - (b) the legal capacity under which it carries on business;

prior to contract award. Proof of signing authority may be in the form of a certified copy of a resolution naming the signatory(ies) that is (are) authorized to sign this bid on behalf of the



corporation or partnership. Proof of legal capacity may be in the form of a copy of the articles of incorporation or the registration of the business name of a sole proprietor or partnership.

#### IB03 Applicable Taxes

Bidders are not to include any amounts for Applicable Taxes (Goods and Services Tax (GST), Harmonized Sales Tax (HST) or Quebec Sales Tax (QST), whichever is applicable. Any amount levied in respect of Applicable Taxes shall be billed as a separate item in a progress claim submitted by the Contractor, and shall be paid to the Contractor in addition to the amount approved by Canada for work performed under the Contract. The Contractor shall be required to remit the appropriate amount to the appropriate tax authority in accordance with the applicable legislation.

#### IB04 Tax to Be Included

1) The Contractor is not entitled to use Canada's exemptions from any tax, such as provincial sales taxes, unless otherwise specified by law. The Contractor must pay applicable provincial sales tax, ancillary taxes, and any commodity tax, on taxable goods or services used or consumed in the performance of the Contract (in accordance with applicable legislation), including for material incorporated into real property.

#### IB05 Capital Development and Redevelopment Charges

1) For the purposes of GC1.5 in the General Conditions of the Contract, only fees or charges directly related to the processing and issuing of building permits shall be included. The Bidder shall not include any monies in the bid amount for special municipal development, redevelopment or other fees or charges which a municipal authority may seek as a prerequisite to the issuance of building permits.

#### IB06 Registry and Pre-qualification of Floating Plant

 Dredges or other floating plant to be used in the performance of the Work must be of Canadian registry. For dredges or other floating plant that are not of Canadian make or manufacture, the Bidder must obtain a certificate of qualification from Industry Canada and this certificate must accompany the bid. Plant so qualified by Industry Canada may be accepted on this project.

#### IB07 Listing of Subcontractors and Suppliers

1) Notwithstanding any list of Subcontractors that the Bidder may be required to submit as part of the bid, the Bidder submitting the lowest acceptable bid shall, within 48 hours of receipt of a notice to do so, submit all information requested in the said notice including the names of Subcontractors and Suppliers for the part or parts of the Work listed. Failure to do so may result in the disqualification of its bid.

#### IB08 Bid Security Requirements

1) **NO** bid security is required for this solicitation notice.

#### IB09 Submission of Bid

1) The BID AND ACCEPTANCE FORM, duly completed, shall be enclosed and sealed in an envelope provided by the Bidder, and shall be addressed and submitted to the office designated

on the Front Page of the BID AND ACCEPTANCE FORM for the receipt of bids. The bid must be received on or before the date and time set for solicitation closing.

- Unless otherwise specified in the SPECIAL INSTRUCTIONS TO BIDDERS
  - (a) the bid shall be in Canadian currency;
  - (b) exchange rate fluctuation protection is not offered; and
  - (c) any request for exchange rate fluctuation protection shall not be considered.
- 3) Prior to submitting the bid, the Bidder shall ensure that the following information is clearly printed or typed on the face of the bid envelope:
  - (a) Solicitation/File Number;
  - (b) Name of Bidder;
  - (c) Return address; and
  - (d) Closing Date and Time.
- 4) Subject to paragraph 6) of IB11, failure to comply with paragraphs 1), 2) and 3) of IB09 shall render the bid liable to disqualification. Timely and correct delivery of bids is the sole responsibility of the Bidder.

#### IB10 Revision of Bid

2)

- 1) A bid submitted in accordance with these instructions may be revised by letter or facsimile provided the revision is received at the office designated for the receipt of bids, on or before the date and time set for the closing of the bid. The letter or facsimile shall:
  - (a) be on the Bidder's letterhead or bear a signature that identifies the Bidder;
  - (b) for the lump sum portion of a bid, clearly identify the amount of the current revision. The total aggregate sum of all revisions submitted, including the current revision, shall be shown separately; and
  - (c) for the Price Per Unit portion of a bid, clearly identify the change(s) in the Price(s) per Unit and the specific Item(s) to which each change applies. If a revision is to be applied to a specific Item that was previously amended then, in addition to the amount of the current revision, the total aggregate sum of all revisions submitted, including the current revision, for that Item shall be shown separately.
- 2) A letter or facsimile submitted to confirm an earlier revision shall be clearly identified as "CONFIRMATION ONLY" for each contemplated change.
- 3) Failure to comply with any of the above provisions shall result in the rejection of the noncompliant revision(s) only. The bid shall be evaluated based on the original bid submitted and all other compliant revision(s).

#### IB11 Acceptance of Bid

- 1) Canada may accept any bid, whether it is the lowest or not, or may reject any or all bids.
- 2) Without limiting the generality of paragraph 1) of IB11, Canada may reject a bid if any of the following circumstances is present:
  - (a) the Bidder, or any employee or subcontractor included as part of the bid, has been convicted under section 121 ("Frauds on the government" & "Contractor subscribing to election fund"), 124 ("Selling or purchasing office"), 380 ("Fraud committed against Her Majesty") or 418 ("Selling defective stores to Her Majesty") of the Criminal Code of Canada; or under paragraph 80(1)(d) ("False entry, certificate of return"), subsection 80 (2) ("Fraud against Her Majesty") or Section 154.01 ("Fraud against Her Majesty") of the Financial Administration Act,
  - (b) the Bidder's bidding privileges are suspended or are in the process of being suspended;

- (c) the bidding privileges of any employee or subcontractor included as part of the bid are suspended or are in the process of being suspended, which suspension or pending suspension would render that employee or subcontractor ineligible to bid on the Work, or the portion of the Work the employee or subcontractor is to perform;
- (d) with respect to current or prior transactions with Canada
  - (i) the Bidder is bankrupt or if, for whatever reason, its activities are rendered inoperable for an extended period;
  - evidence, satisfactory to Canada, of fraud, bribery, fraudulent misrepresentation or failure to comply with any law protecting individuals against any manner of discrimination, has been received with respect to the Bidder, any of its employees or any subcontractor included as part of its bid;
  - (iii) Canada has exercised, or intends to exercise, the contractual remedy of taking the work out of the contractor's hands with respect to a contract with the Bidder, any of its employees or any subcontractor included as part of its bid; or
  - (iv) Canada determines that the Bidder's performance on other contracts is sufficiently poor to jeopardize the successful completion of the requirement being bid on.
- 3) In assessing the Bidder's performance on other contracts pursuant to subparagraph 2)(d)(iv) of IB11, Canada may consider, but not be limited to, such matters as:
  - (a) the quality of workmanship in performing the Work;
  - (b) the timeliness of completion of the Work;
  - (c) the overall management of the Work and its effect on the level of effort demanded of the department and its representative; and
  - (d) the completeness and effectiveness of the Contractor's safety program during the performance of the Work.
- 4) Without limiting the generality of paragraphs 1), 2) and 3) of IB11, Canada may reject any bid based on an unfavourable assessment of the:
  - (a) adequacy of the bid price to permit the work to be carried out and, in the case of a bid providing prices per unit or a combination of lump sum and prices per unit, whether each such price reasonably reflects the cost of performing the part of the work to which that price applies;
  - (b) Bidder's ability to provide the necessary management structure, skilled personnel, experience and equipment to perform competently the work under the Contract; and
  - (c) Bidder's performance on other contracts.
- 5) If Canada intends to reject a bid pursuant to a provision of paragraphs 1), 2), 3) or 4) of IB11, other than subparagraph 2)(b)of IB11, Canada shall so inform the Bidder and provide the Bidder ten (10) days within which to make representations, prior to making a final decision on the bid rejection.
- 6) Canada may waive informalities and minor irregularities in bids received if Canada determines that the variation of the bid from the exact requirements set out in the Bid Documents can be corrected or waived without being prejudicial to other Bidders.

## IB12 Bid Costs

 No payment will be made for costs incurred in the preparation and submission of a bid in response to the bid solicitation. Costs associated with preparing and submitting a bid, as well as any costs incurred by the Bidder associated with the evaluation of the bid, are the sole responsibility of the Bidder.

#### IB13 Compliance with Applicable Laws

- 1) By submission of a bid, the Bidder certifies that the Bidder has the legal capacity to enter into a contract and is in possession of all valid licences, permits, registrations, certificates, declarations, filings, or other authorizations necessary to comply with all federal, provincial and municipal laws and regulations applicable to the submission of the bid and entry into any ensuing contract for the performance of the work.
- 2) For the purpose of validating the certification in paragraph 1) of IB13, a Bidder shall, if requested, provide a copy of every valid licence, permit, registration, certificate, declaration, filing or other authorization listed in the request, and shall provide such documentation within the time limit(s) set out in the said request.
- 3) Failure to comply with the requirements of paragraph 2) of IB13 shall result in disqualification of the bid.

#### IB14 Approval of Alternative Materials

1) When materials are specified by trade names or trademarks, or by manufacturers' or suppliers' names, the bid shall be based on use of the named materials. During the bid period, alternative materials may be considered provided full technical data is received in writing by the Contracting Officer at least 10 calendar days prior to the bid closing date.

#### IB15 Income Tax Requirement

1) Payments made under applicable contracts must be reported by Canada for taxation purposes. To comply with this requirement, the successful bidder shall provide to Canada immediately upon award: its legal name; address; and Revenue Canada identifier (SIN, BN, GST/HST, T2N number) as is applicable.

#### IB16 Contingency Fees

1) The Bidder declares that the Bidder has not, directly or indirectly, paid or agreed to pay, and will not, directly or indirectly, pay a contingency fee to any individual for the solicitation, negotiation or obtaining of the contract if the payment of the fee would require the individual to file a return under section 5 of the *Lobbying Act*.


#### IB17 Status of the Bidder

1) The Bidder declares that the Bidder has not been convicted of an offence, other than an offence for which a pardon has been granted, under section 121, 124 or 418 of the *Criminal Code*.



Appendix "B"

# SPECIAL INSTRUCTIONS TO BIDDERS



## SPECIAL INSTRUCTIONS TO BIDDERS

- SI01 Bid Documents
- SI02 Enquiries during the Solicitation Period
- SI03 Non-Mandatory Site Visit
- SI04 Revision of Bid
- SI05 Bid Results
- SI06 Bid Validity Period
- SI07 Construction Documents
- SI08 Personnel Security Requirements

#### SI01 BID DOCUMENTS

- 1) The following are the bid documents:
  - (a) SPECIAL INSTRUCTIONS TO BIDDERS;
  - (b) INSTRUCTIONS TO BIDDERS Form A5319-E; and,
  - (c) BID AND ACCEPTANCE FORM Form A5312-E and any attachments thereto.

Canada reserves the right to revise or amend the Bid Documents prior to the date set for opening bids. Such revisions or amendments, if any, will be announced by an addendum or addenda to the documents.


Submission of a bid constitutes acknowledgement that the Bidder has read and agrees to be bound by these documents.

#### SI02 ENQUIRIES DURING THE SOLICITATION PERIOD

1) Enquiries regarding this bid must be submitted in writing to the Contracting Officer. The Contracting Officer for the purpose of this bid is:

Saad Ibrahimy Agriculture and Agri-Food Canada 2001 University, 671 -TEN, Montreal, Quebec, H3A 3N2 Telephone : 514 315-6140, Facsimile : 514 283-3143 Email: saad.ibrahimy@agr.gc.ca

- 2) Except for the approval of alternative materials as described in IB14 of the INSTRUCTIONS TO BIDDERS, enquiries should be received no later than five (5) calendar days prior to the date set for solicitation closing to allow sufficient time to provide a response. Enquiries received after that time may not result in an answer being provided.
- To ensure consistency and quality of the information provided to Bidders, the Contracting Officer shall examine the content of the enquiry and shall decide whether or not to issue an amendment.
- 4) All enquiries and other communications related to this bid sent throughout the solicitation period are to be directed ONLY to the Contracting Officer. Non-compliance with this requirement during the solicitation period can, for that reason alone, result in disqualification of a bid.



#### SPECIAL INSTRUCTIONS TO BIDDERS (Continued)

## SIO3 NON-MANDATORY SITE VISIT

- 1) Before submitting their bid, the Contractor shall examine the jobsite, construction and storage areas, compare drawings and specifications with existing conditions, and fully satisfy themselves as to all data and matters required for the completion of the contract.
- 2) There will be a site visit on Wednesday, July, 9, 2014 at

09:00 • AM • PM Local Standard Time.

Interested bidders are to meet at:

Research Farm of Normandin 1468 St-Cyrille Street Normandin, Quebec, G8M 4K3

#### SI04 REVISION OF BID

 A bid may be revised by letter or facsimile in accordance with IB10 of the INSTRUCTIONS TO BIDDERS. The facsimile number for receipt of revisions is: 514 283-3143 .

#### SI05 BID RESULTS

 Following bid closing, bid results may be obtained from the bid receiving office by email at saad. i brahi my@agr. gc. ca

#### SI06 BID VALIDITY PERIOD

1) Canada reserves the right to seek an extension to the bid validity period prescribed in Clause 4 of the BID AND ACCEPTANCE FORM. Upon notification in writing from Canada, Bidders shall have the option to either accept or reject the proposed extension.

#### SI07 CONSTRUCTION DOCUMENTS

 The successful contractor will be provided with one paper copy of the sealed and signed drawings, the specifications and the amendments upon acceptance of the offer. Additional copies, up to a maximum of zero (0), will be provided free of charge upon request by the Contractor. Obtaining more copies shall be the responsibility of the Contractor including costs.

#### SI08 PERSONNEL SECURITY REQUIREMENTS

- 1) The successful Bidder's personnel, as well as any subcontractor and its personnel, who are required to perform any part of the work pursuant to the subsequent contract, must meet the following contract security requirements:
  - Personnel who are required to perform any part of the work must EACH hold a valid personnel security screening at the level of RELIABILITY STATUS, granted or approved by Agriculture and Agri-Food Canada. Until the security screening of the personnel has been completed satisfactorily by Agriculture and Agri-Food Canada, the Contractor/Subcontractor personnel

## SPECIAL INSTRUCTIONS TO BIDDERS (Continued)

MAY NOT perform contract work. Each of the proposed staff must complete "Security Clearance Form" (TBS 330-23E) upon request from Canada.



Appendix "C"

# **BID AND ACCEPTANCE FORM**



BID AND	ACCEPTANCE FORM	1
---------	-----------------	---

CONSTRUCTION CONTRACT - MINOR WORKS

ΤΙΛ	ME:
	Contract:
	Project: 1314143810P05
	01B46-14-0056
	Solicitation / File Number:

**Janada** 

Agriculture and Agri-Food Canada	BID CLOSING TIME:					
Assets Team - Eastern Service Centre	Wednesday ,	July	16,	2014		
TENDER RECEIVING UNIT 2001 University Street, Suite 671-TEN	Day of week	Month	Day	Year		
Montreal, QC, H3A 3N2	at $02:00$ $\bigcirc$ AM $\odot$ PM local time.					

#### DESCRIPTION OF WORKS:

LIGHTING RETROFIT T12 TO T8 FLUORESCENT FIXTURES CONVERSION

#### **INSTRUCTIONS TO BIDDERS:**

Bidders shall be governed by the following instructions:

- SPECIAL INSTRUCTIONS TO BIDDERS - Form AAFC / AAC5318-E

- INSTRUCTIONS TO BIDDERS - Form AAFC / AAC5319-E

The following additional documents form an attachment to this BID AND ACCEPTANCE FORM:

List of Subcontractors

#### OFFER AND AGREEMENT

 The undersigned bidder (hereinafter called the "Contractor") hereby offers to Her Majesty the Queen in right of Canada, as represented by the Minister of Agriculture and Agri-Food (hereinafter called "Canada"), to furnish all necessary labour, plant and material and to execute and complete in a satisfactory and workmanlike manner all the work required under this contract for the consideration of the unit or lump sum price or prices set forth in the Price Table below. The Contractor agrees that these prices include all applicable sales and other taxes. Note: Do not include GST/HST in price(s).

	PRICE TABLE							
ltem	Class of Labour, Plant, or Material	Unit of Estimated Total Measurement Quantity		Price Per Unit	Estimated Total Price			
		LUMP SUM						
pri	, th price per unit and estimated total price must be filled in for each i ices will be subject to verification by Canada. In case of variation be al price, the price per unit will be considered to be the price bid.	Total Bid						

2.	The Contractor shall complete the work by:	October	03,2014
		Month	Dav Year

3. The Contractor hereby acknowledges receipt of the following addenda to the bid documents (give number and date of each):

Addenda numbers:

4. The Contractor agrees that this offer: supersedes and cancels all communications, negotiations, and agreements relating to the work other than contained in this completed bid or any amendment incorporated by mutual agreement between the Contractor and Canada before acceptance of this Offer and Agreement; is irrevocable for 30 days after the Bid Closing Time shown hereon.

Dates:

- 5. The Contractor agrees, that the complete bid together with and subject to all the provisions contained herein shall, when accepted and executed on behalf of Canada, constitute a binding contract between the Contractor and Canada.
- 6. The following additional documents form an attachment to a binding contract:
  - 6.1 GENERAL CONDITIONS FOR MINOR WORKS Form AAFC / AAC5316-E
  - 6.2 The Fair Wages and Hours of Labour Labour Conditions. This attachment is incorporated by reference and may be accessed from the website:

## **BID AND ACCEPTANCE FORM (Continued)**

6.3 Should the TOTAL BID amount exceed \$30,000.00, the Federal Construction Contracts: Schedule of Wage Rates, for the region of the work. This attachment is incorporated by reference and may be accessed from the website:

http://www.hrsdc.gc.ca/eng/labour/employment\_standards/contracts/schedule/index.shtml.

- 6.4 Specifications
- 6.5 Insurance Terms

#### CONTRACTOR'S FULL BUSINESS NAME (Please print or type)


#### CONTRACTOR'S BUSINESS ADDRESS (for all purposes of or incidental to the contract)

Unit/Suite/Apt.	Street number	Number suffix	Street name	e					Street type	Street direction
PO Box or Route Number Municipality (City, Town, etc.)							Province	Postal code		
Telephone numl	Telephone number Ext. Facsimile number E-mail (optional)					GST/HST number				
Attested to and				day of Mon	th	,	Year			
CONTRACTOR SIGNING OFFIC	'S or, where app CER'S SIGNATI	olicable, JRE(S)	TITLE(S)				lr V	n the presence of VITNESS SIGNA	TURE(S)	
NOTE: Corpora	te Firms shall a	ffix their Corpora	ate Seal if applic	able.						
(FOR DEPART	MENTAL USE C	NLY)								
Accepted and E	xecuted on Beh	alf of Canada th	is day of	Month		' <u></u> Year	-			
SIGNATURE			TITLE				Ir	n the presence of	WITNESS SIG	GNATURE
Bid opened in	ocation		on Day of weel	K	, Month		Day	, at Year	_ O am C	)
in the presence	of									



Appendix "D"

# GENERAL CONDITIONS FOR MINOR WORKS



## TABLE OF CONTENTS GENERAL CONDITIONS FOR MINOR WORKS

#### GC 1 GENERAL PROVISIONS

- GC 1.1 Definition
- GC 1.2 Contract Documents
- GC 1.3 Assignment
- GC 1.4 Subcontracting
- GC 1.5 Laws, Permits and Taxes
- GC 1.6 Former Public Office Holders
- GC 1.7 Status of the Contractor
- GC1.8 Contingency Fees
- GC1.9 Disclosure of Basic Information

#### GC 2 ADMINISTRATION OF THE CONTRACT

- GC 2.1 Departmental Representative's Rights and Obligations
- GC 2.2 Contractor's Superintendent and Workers
- GC 2.3 Records to be Kept by the Contractor
- GC 2.4 Notices

#### GC 3 EXECUTION OF THE WORK

- GC 3.1 Material, Plant and Real Property Become the Property of Canada
- GC 3.2 Cooperation With Other Contractors
- GC 3.3 Use of the Work and Cleanup of Site
- GC 3.4 Warranty and Rectification of Defects

#### GC 4 PROTECTION, HEALTH AND SAFETY

- GC 4.1 Material, Plant and Real Property Supplied by Canada
- GC 4.2 Construction Safety

#### GC 5 TERMS OF PAYMENT

- GC 5.1 Definitions
- GC 5.2 Payment General Provisions
- GC 5.3 Progress Payments
- GC 5.4 Interest on Overdue Accounts
- GC 5.5 Payment in the Event of Termination
- GC 5.6 Final Completion
- GC 5.7 Determination of Price
- GC 5.8 Claims Against and Obligations of the Contractor or Subcontractor

#### GC 6 CHANGES IN THE WORK

- GC 6.1 Changes in the Work
- GC 6.2 Changes in Subsurface Conditions and Delays by Canada
- GC 6.3 Extension of Time


#### GC 7 DEFAULT, SUSPENSION OR TERMINATION OF CONTRACT

- GC 7.1 Taking the Work Out of the Contractor's Hands
- GC 7.2 Effect of Taking the Work Out of the Contractor's Hands
- GC 7.3 Suspension of the Contract
- GC 7.4 Termination of the Contract


#### GC 8 DISPUTE RESOLUTION

#### GC 9 INDEMNIFICATION AND INSURANCE

- GC 9.1 Indemnification
- GC 9.2 Insurance Contracts
- GC 9.3 Insurance Proceeds







## **GENERAL CONDITIONS FOR MINOR WORKS**

#### GC 1 GENERAL PROVISIONS

#### GC 1.1 Definition

- "Applicable Taxes" means the Goods and Services Tax (GST), the Harmonized Sales Tax (HST), and any provincial tax, by law, payable by Canada such as, the Quebec Sales Tax (QST) as of April 1, 2013.
- "Canada", "Her Majesty" means Her Majesty, the Queen in right of Canada;
- "Contract" means the contract documents referred to as such therein and every other document specified or referred to in any of them as forming part of the Contract, all as amended by agreement of the parties;
- "Contractor" means a person, with whom Canada enters into a Contract to do the Work;
- "Departmental Representative" means the person designated in the Contract, or by written notice to the Contractor, to act as the Departmental Representative for the purposes of the Contract, and includes a person, designated and authorized in writing by the Departmental Representative to the Contractor;
- "Material" includes all commodities, articles, machinery, equipment, fixtures and things required to be furnished in accordance with the Contract for incorporation into the Work;
- "Person" includes, unless there is an express stipulation in the Contract to the contrary, any partnership, proprietorship, firm, joint venture, consortium or corporation;
- "Plant" includes all tools, implements, machinery, vehicles, structures, equipment, articles and things that are necessary for the performance of the Contract, other than Material and those tools customarily provided by a trades person in practicing a trade;
- "Work" means everything that is necessary to be done, furnished or delivered by the Contractor to perform the Contract in accordance with the Contract Documents;

#### GC 1.2 Contract Documents

- 1. In interpreting the Contract, in the event of discrepancies or conflicts between anything in the Drawings and Specifications or Scope of Work and the General Conditions, the General Conditions govern.
- 2. In interpreting the Drawings and Specifications, in the event of discrepancies or conflicts between:
  - (a) the Drawings and Specifications, the Specifications govern;
  - (b) the Drawings, the Drawings with the largest scale govern; and
  - (c) figured dimensions and scaled dimensions, the figured dimensions govern.

#### GC 1.3 Assignment

1. This Contract shall not be assigned without the written consent of Canada.

#### GC 1.4 Subcontracting

- 1. The Contractor shall:
  - (a) not subcontract the whole or any part of the Work without the written consent of the Departmental Representative except for subcontracts specified in the Contract; and
  - (b) ensure that all subcontracts entered into at any tier shall incorporate all the terms and conditions of the Contract that can reasonably be applied thereto.



#### GC 1.5 Laws, Permits and Taxes

- 1. The Contractor shall comply with all legislative and regulatory provisions whether federal, provincial, territorial or municipal applicable to the performance of the Work and shall require compliance therewith by all of its subcontractors and suppliers at any tier as if the Work were being performed for an owner other than Canada.
- 2. Unless otherwise provided for in the Contract, the Contractor shall obtain all permits and hold all certificates and licenses required for the performance of the Work.
- 3. Applicable Taxes will be paid by Canada at time when a progress payment is being made. It is the sole responsibility of the Contractor to charge Applicable Taxes at the correct rate in accordance with applicable legislation. The Contractor agrees to remit to appropriate tax authorities any amounts of Applicable Taxes paid or due.
- 4. The Contractor is not entitled to use Canada's exemptions from any tax, such as provincial sales taxes, unless otherwise specified by law. The Contractor must pay applicable provincial sales tax, ancillary taxes, and any commodity tax, on taxable goods or services used or consumed in the performance of the Contract (in accordance with applicable legislation), including for material incorporated into real property.

## GC 1.6 Former Public Office Holders

1. No former public office holder who is not in compliance with the post-employment provisions of the Conflict of Interest and Post-Employment Code for Public Office Holders shall derive a direct benefit from the Contract.

#### GC 1.7 Status of the Contractor

- 1. The Contractor is engaged as an independent Contractor for the sole purpose of performing the Work. Neither the Contractor nor any of its personnel is engaged as an employee, servant or agent of Canada. The Contractor is responsible for all deductions and remittances required by law in relation to its employees including those required for Canada or Quebec Pension Plans, employment insurance, workers' compensation, and income tax.
- 2. The Contractor declares that the Contractor has not been convicted of an offence, other than an offence for which a pardon has been granted, under section 121, 124 or 418 of the Criminal Code.

#### GC 1.8 Contingency Fees

1. The Contractor declares that the Contractor has not, directly or indirectly, paid or agreed to pay, and will not, directly or indirectly, pay a contingency fee to any individual for the solicitation, negotiation or obtaining of the contract if the payment of the fee would require the individual to file a return under section 5 of the *Lobbying Act*.

#### GC 1.9 Disclosure of Basic Information

1. The Contractor consents, in the case of a contract that has a value in excess of \$10,000, to the public disclosure of basic information, other than information described in any of paragraphs 20(1)(a) to (d) of the Access to Information Act, relating to the contract.

## GC 2 ADMINISTRATION OF THE CONTRACT

#### GC 2.1 Departmental Representative's Rights and Obligations

- 1. The Departmental Representative shall:
  - (a) have access to the Work at all times;
  - (b) decide questions regarding what has been done or what the Contractor is required to do;
  - (c) decide questions regarding the acceptability of the quality or quantity of any Labour, Plant or Material used or consumed in the execution of the Work; and
  - (d) decide questions regarding the timing and scheduling of the Work.

#### GC 2.2 Contractor's Superintendent and Workers

1. The Contractor shall keep a competent superintendent and capable and skilled workers on the site of the Work at all times during the progress of the Work. If, in the opinion of the Departmental Representative, the superintendent or the workers are deemed to be unacceptable because of incompetence, improper conduct or security risk, they shall be removed from the site of the Work and replaced forthwith.

#### GC 2.3 Records to be Kept by the Contractor

- 1. The Contractor shall maintain and keep intact complete records relating to the Work together with all tender calls, quotations, contracts, correspondence, invoices and any payment of fees or other compensation for the solicitation, negotiating or obtaining of the contract until the expiration of two (2) years after the date that a Certificate of Completion is issued or the final invoice is paid if no Certificate of Completion is issued. The Contractor shall, upon request from the Departmental Representative, make said records available for copy, audit or inspection to any person(s) acting on behalf of Canada.
- 2. The Contractor shall cause all Subcontractors, and all other Persons or entities directly or indirectly involved with the Work, to comply with the requirements of GC 2.3.1.

#### GC 2.4 Notices

1. Any notice shall be in writing and may be delivered by hand, by courier, by registered or regular mail, or by facsimile or other electronic means that provides a paper record of the text of the notice. The notice shall be addressed to the party for whom it is intended at the address in the Contract or at the last address from which the sender has received notice in accordance with this section. Any notice shall be deemed to be effective on the day it is received at that address or four (4) days after being sent, whichever is the earlier.

## GC 3 EXECUTION OF THE WORK

#### GC 3.1 Material, Plant, and Real Property Become the Property of Canada

- 1. All Material and Plant used or consumed for the purposes of the Work shall be the property of Canada. The Material and Plant shall be used only for the purposes of the Work, and shall not be removed from the site of the Work until so approved by the Departmental Representative.
- 2. The Contractor shall be liable for all loss or damage to Material or Plant that is the property of Canada by virtue of this section.

#### GC 3.2 Cooperation with Other Contractors

- 1. The Contractor shall cooperate fully with other contractors or workers sent onto the site of the Work by the Departmental Representative.
- 2. If, at the time the Contract was executed: the Contractor could not have reasonably foreseen the sending of other contractors or workers onto the site of the Work; and, the Contractor incurs extra costs in complying with GC 3.2.1; and, the Contractor gives written notice of claim for the extra costs within ten (10) days from the date upon which the other contractors or workers were sent onto the site of the Work; then, Canada shall pay an additional amount to the Contractor, calculated pursuant to GC 5.7.

#### GC 3.3 Use of the Work and Cleanup of Site

- 1. The Contractor shall maintain the site of the Work in a tidy condition and free from the accumulation of waste material throughout the duration of the Contract.
- 2. Before the Departmental Representative issues the Certificate of Completion or approves payment of the final invoice, the Contractor shall remove all materials, tools, construction machinery, equipment, waste products and debris from the site of the Work.
- 3. Where the Work affects occupied portions of a building, the Contractor shall ensure continuity of all building services and shall ensure safe access for all persons requiring access to said building.

#### GC 3.4 Warranty and Rectification of Defects

- Without restricting any warranty or guarantee implied or imposed by law or any extended warranty specified in the Contract, the Contractor shall, upon notice from the Departmental Representative and at its own expense, rectify all defects which appear in the Work within twelve (12) months from the date of issuance of the Certificate of Completion pursuant to GC 5.6.1, or from the date of the negotiable instrument issued as final payment if a Certificate of Completion is not issued, whichever is applicable.
- 2. The notice referred to in GC 3.4.1 shall be in writing and shall include the number of days within which the defect or fault is to be rectified.
- 3. The Contractor shall transfer and assign, to Canada, any subcontractor, manufacturer or supplier extended warranties or guarantees implied or imposed by law or contained in the contract documents covering periods beyond the twelve (12) months stipulated above. Extended warranties or guarantees referred to herein shall not extend the twelve (12) month period whereby the Contractor must rectify and make good any defect or fault that appears in the work or comes to the attention of Canada.

## GC 4 PROTECTION, HEALTH AND SAFETY

#### GC 4.1 Material, Plant and Real Property Supplied by Canada

1. The Contractor, having care, custody and control of the Work and its site, shall be responsible for any loss or damage, excluding reasonable wear and tear, to any property of Canada arising out of the performance of the Work whether or not such loss arises from causes beyond the Contractor's control.

## GC 4.2 Construction Safety

1. The Contractor shall be responsible for the health and safety of all persons granted access to the site of the Work and for initiating, maintaining and supervising all safety inspections, precautions and programs in connection with the performance of the Work in accordance with the health and safety legislation in force in the Province where the Work is being performed.

## GC 5 TERMS OF PAYMENT

## GC 5.1 Definitions

For the purposes of this section:

- Payment Period means a period of thirty (30) days or such other longer period as may be agreed between the Contractor and the Departmental Representative.
- An amount is Due and Payable when it is due and payable by Canada to the Contractor in accordance with the terms of the Contract.
- An amount is Overdue when it remains unpaid after the day upon which it is due and payable.
- Date of Payment means the date of the negotiable instrument of an amount due and payable by the Receiver General for Canada.
- Fixed Price Arrangement means that part of the Contract that prescribes a lump sum as payment for performance of the Work to which it relates.
- Unit Price Arrangement means that part of the Contract that prescribes the product of a Price Per Unit multiplied by a number of Units of Measurement of a Class as payment for performance of the Work to which it relates.
- Price Table means the table set out in the BID AND ACCEPTANCE FORM.
- Bank Rate means the rate of interest established from time to time by the Bank of Canada as the minimum rate at which the Bank of Canada makes short term advances to members of the Canadian Payments Association.
- Average Bank Rate means the simple arithmetic mean of the Bank Rates in effect at 4:00 pm Eastern Time each day during the calendar month which immediately precedes the calendar month in which payment is made.
- Duration of the Work means the number of calendar days required to complete the Work, commencing on the first day following receipt by the Contractor of the fully executed Contract and ending the day on which the Departmental Representative verifies that the Work has been satisfactorily completed.

## GC 5.2 Payment - General Provisions

- 1. It is a condition precedent to Canada's obligation under GC 5.3.5 that the Contractor has made and delivered to the Departmental Representative, a statutory declaration as described in GC 5.2.2.
- 2. A statutory declaration in a form acceptable to Canada shall contain a declaration that the Contractor has complied with all lawful obligations with respect to workers and that all lawful obligations towards Subcontractors and Suppliers in respect of the Work under the Contract have been fully discharged.
- 3. A payment by Canada pursuant to this section shall not be construed as evidence that the Work is satisfactory or in accordance with the Contract.
- 4. Delay in making payment by Canada under the Contract shall not constitute a breach of Contract.

- 5. Without limiting any right of setoff or deduction given or implied by law or elsewhere in the Contract, Canada may retain from amounts payable to the Contractor under the Contract, any amount payable to Canada by the Contractor under the Contract or any other current contract.
- 6. No additional payment shall be made for delays where the cause of the delay was under the control of the Contractor.
- 7. Except as provided for in these General Conditions, the amount payable to the Contractor under the Contract shall not be increased or decreased by reason of any increase or decrease in cost of the Work brought about by any increase in the cost of Labour, Plant or Material.
- 8. In the event of a change, including a new imposition or repeal of any tax, customs or other duty, charge, or any similar imposition that is imposed under sales or excise tax legislation of the Government of Canada or any Provincial or Territorial legislation, affects the cost of the Work to the Contractor, and occurs after the date of submission by the Contractor of the Contractor's bid, the contract amount shall be adjusted by an amount equal to the increased or decreased cost to the Contractor, which amount shall be determined through a detailed examination of the Contractor's records.
- 9. It is a term of every contract providing for the payment of any money by Her Majesty that payment under that contract is subject to there being an appropriation for the particular service for the fiscal year in which any commitment under that contract would come in course of payment. Section 40, *Financial Administration Act*, R.S., 1985, c. F-11, s. 40.

## GC 5.3 Progress Payments

- 1. Where the duration of the Work is greater than thirty (30) days, the Contractor shall be entitled to receive monthly progress payments upon submitting a progress claim in a form approved by the Departmental Representative. Where the duration of the Work is less than thirty (30) days, the Contractor shall submit a progress claim after the Work is complete.
- 2. On the expiration of a Payment Period, the Contractor shall deliver to the Departmental Representative:
  - (a) a written progress claim that fully describes any part of the Work that has been satisfactorily completed and any Material that was delivered to the site of the Work but not incorporated into the Work during the Payment Period for which the progress claim relates;
  - (b) a completed and signed statutory declaration as described in GC 5.2.2; and
  - (c) in the case of the initial progress claim and the request for final payment, satisfactory evidence of compliance with workers compensation legislation that is applicable to the place of the Work.
- 3. Not later than ten (10) days after receipt of a progress claim properly submitted in accordance with GC 5.3.2, the Departmental Representative shall issue a progress report, a copy of which shall be given to the Contractor.
- 4. A progress report shall indicate the value of the part of the Work and Material described in the progress claim that, in the opinion of Canada:
  - (a) is in accordance with the Contract; and
  - (b) was not included in any other progress report related to the Contract.

- 5. Not later than thirty (30) days after the receipt by the Departmental Representative of a properly submitted progress claim and supporting documentation, Canada shall make a progress payment to the Contractor in an amount that is equal to one of the following:
  - (a) 90 percent of the value that is indicated in the progress report; or
  - (b) If the Departmental Representative is satisfied that the Work is substantially complete and is acceptable for use by Canada, 100 percent of the value of the Work and Material that is in accordance with the Contract, less amounts previously paid for under the Contract, less the amount equal to the estimated cost of completing the Work and the estimated cost of rectifying defects and faults in the Work as determined by the Departmental Representative; or
  - (c) If the Departmental Representative is satisfied that the Work is complete, 100 percent of the value of the Work that is in accordance with the Contract less amounts previously paid for under the Contract;

plus Applicable Taxes and less the aggregate of any amounts payable to or costs and damages claimed by Canada or by a Claimant against the Contractor.

- 6. The Departmental Representative reserves the right to increase or decrease the quantities submitted by the Contractor if there is a disagreement between the Contractor's invoiced quantities and the quantities shown in the records maintained at the site of the Work.
- 7. Subject to GC 5.3.8, GC 5.3.9 and GC 5.3.10, the Departmental Representative and the Contractor may, by an agreement in writing, amend a Price Per Unit as set out in the Price Table for any Class of Labour, Plant or Material provided the Certificate of Measurement shows that the Authorized Quantity of the Class of Labour, Plant or Material actually performed, used or supplied by the Contractor in performing the Work is:
  - (a) less than 85 percent of the Estimated Total Quantity; or
  - (b) in excess of 115 percent of the Estimated Total Quantity.
- 8. In no event shall the total amount of an Item set out in the Price Table that has been amended pursuant to GC 5.3.7 (a) exceed the amount that would have been Payable to the Contractor had the Estimated Total Quantity actually been performed, used, or supplied.
- 9. An amendment that is made necessary by GC 5.3.7 (b) shall apply only to the quantities that are in excess of 115 percent.
- 10. Where the Departmental Representative and the Contractor fail to agree on the amount of any adjustment to a Price Per Unit as contemplated by GC 5.3.7, the amended Price Per Unit shall be determined in accordance with GC 5.7.

#### GC 5.4 Interest on Overdue Accounts

- 1. Canada shall be liable to pay, to the Contractor, simple interest at the Average Bank Rate plus 3 percent per annum on any amount that is Overdue. The interest shall apply from the date such amount becomes Overdue until the day prior to the Date of Payment inclusively.
- 2. Interest shall be paid to the Contractor without demand on Overdue payments, except, in respect to amounts which are less than fifteen (15) days Overdue, in which case, no interest shall be paid unless the Contractor so demands.
- 3. Canada shall not be liable to pay interest where Canada is not responsible for the delay in paying the Contractor.

## GC 5.5 Payment in the Event of Termination

- 1. If the Contract is terminated pursuant to GC 7.4, Canada shall pay the Contractor:
  - (a) an amount, as agreed upon by the Contractor and the Departmental Representative, for all Labour, Plant and Material performed, used or supplied by the Contractor as at the date of termination plus
    - (i) any fully supported termination costs incurred by the Contractor, less
    - (ii) any amounts payable to or costs and damages claimed by Canada or by a Claimant, against the Contractor; or
  - (b) failing such an agreement, an amount calculated in accordance with GC 5.7.2.

## GC 5.6 Final Completion

- 1. A Certificate of Completion shall be issued to the Contractor on the date on which the Work has been completed and the Contractor has complied with the Contract and all orders and directions made pursuant thereto, all to the satisfaction of the Departmental Representative.
- 2. Where the Contract is, in whole or in part, a Unit Price Arrangement, the Departmental Representative shall, at the same time as the issuance of the Certificate of Completion, issue a Certificate of Measurement setting out the Authorized Quantities used or employed in respect of the classes and units set out in the Price Table under the BID AND ACCEPTANCE FORM and any subsequent amendments thereto, such certificate to be binding upon the Contractor and Canada.

#### GC 5.7 Determination of Price

- 1. By mutual agreement:
  - (a) where a Lump Sum Arrangement applies to the Contract or a part thereof, the price of any change shall be the aggregate estimated cost of Labour, Plant and Material that is required for the change as agreed upon in writing by the Contractor and Canada, and include an allowance for overhead, margin and the risk of undertaking the work within the stipulated amount;
  - (b) where a Unit Price Arrangement applies to the Contract or a part thereof, the Contractor and Canada may, by agreement in writing, add Items, Units of Measurement, Estimated Total Quantities and Price Per Units to the Price Table;
  - (c) a Price Per Unit referred to in GC 5.7.1 (b) shall be determined on the basis of the aggregate estimated cost of Labour, Plant and Material that is required for the additional ltem as agreed upon by the Contractor and Canada, and include an allowance for overhead, margin and the risk of undertaking the work;
  - (d) to facilitate approval of the price of the additional Item, the Contractor shall submit a cost estimate breakdown identifying, as a minimum, the estimated cost of Labour, Plant, Material, each subcontract amount, and the amount of the appropriate percentage allowance;
  - (e) if no agreement can be reached as contemplated in GC5.7.1 (a), the price shall be determined in accordance with GC 5.7.2; and
  - (f) if no agreement can be reached as contemplated in GC 5.7.1 (b) and GC 5.7.1 (c), the Departmental Representative shall determine the Class and the Unit of Measurement of the Item of Labour, Plant or Material and the Price Per Unit shall be determined in accordance with GC 5.7.2.
- 2. Following Completion of the Additional Work
  - (a) Where it is not possible to predetermine, or where there is failure to agree upon the price of a change in the Work, the price of the change shall be equal to the aggregate of:

- (i) all reasonable and proper amounts actually expended or legally payable by the Contractor in respect of the Labour, Plant and Material that fall within one of the classes of expenditure described in GC 5.7.2(b), that are directly attributable to the performance of the Contract; plus
- (ii) an allowance for profit and all other expenditures or costs equal to 10 percent of the sum of the amounts referred to in GC 5.7.2 (a)(i); plus
- (iii) interest, if any, paid by the Contractor on the amounts determined under GC 5.7.2 (a)(i) and (ii), calculated in accordance with GC 5.4.
- (b) The cost of Labour, Plant and Material referred to in GC 5.7.2 (a) shall be limited to the following categories of expenditure:
  - (i) payments to Subcontractors and suppliers;
  - (ii) wages, salaries and traveling expenses of employees of the Contractor located at the site of the Work and that portion of wages, salaries, bonuses, living and traveling expenses of personnel of the Contractor generally employed at the head office or at a general office of the Contractor provided they are actually and properly engaged on the Work under the Contract;
  - (iii) assessments payable under any statutory authority relating to workers' compensation, employment insurance, pension plan or holidays with pay, provincial health or insurance plans, environmental reviews, and GST/HST collection costs;
  - (iv) rent that is paid for Plant, or an amount equivalent to the said rent if the Plant is owned by the Contractor, that is necessary for and used in the performance of the Work, if the rent or the equivalent amount is reasonable and use of that Plant had been approved by the Departmental Representative;
  - (v) payments for maintaining and operating Plant necessary for and used in the performance of the Work, and payments for effecting repairs thereto that, in the opinion of the Departmental Representative, are necessary for the proper performance of the Contract, other than payments for any repairs to the Plant arising out of defects existing before its allocation to the Work;
  - (vi) payments for Material that is necessary for and incorporated in the Work, or that is necessary for and consumed in the performance of the Contract;
  - (vii) payments for preparation, delivery, handling, erection, installation, inspection, protection and removal of the Plant and Material necessary for and used in the performance of the Contract; and
  - (viii) any other payments made by the Contractor with the approval of the Departmental Representative that are necessary for the performance of the Contract in accordance with the Contract Documents.

## GC 5.8 Claims Against and Obligations of the Contractor or Subcontractor

- 1. The Contractor shall ensure that all its lawful obligations arising out of the performance of the Work are discharged and satisfied at least as often as the Contract requires Canada to pay the Contractor. The Contractor shall provide the Departmental Representative with a Statutory Declaration, as referred to in GC 5.2.2. If any third party claims and outstanding obligations exist under the Contract, a Statutory Declaration shall also be accompanied by letter documentation that clearly identifies the existence and condition of any third party disputed claims and outstanding obligations.
- 2. In order to discharge lawful obligations of and satisfy lawful claims against the Contractor or a Subcontractor arising out of the performance of the Work, Canada may:
  - (a) pay an amount from money that is due and payable to the Contractor pursuant to the Contract directly to the claimant against the Contractor or the Subcontractor; or
  - (b) withhold from any amount that is due and payable to the Contractor pursuant to the Contract the full amount of the claim or any portion thereof. Monies withheld for this

purpose shall not be subject to any interest payment in the event such claims are rejected.

- 3. The amount referred to in GC 5.8.2 (a) shall be that amount which the Contractor would have been obliged to pay to such claimant had the provisions of the Provincial or Territorial lien legislation, or in the province of Quebec, the law relating to mortgage, been applicable to the Work. Any such claimant need not comply with the provisions of such legislation setting out the steps by way of notice, registration, or otherwise as might have been necessary to preserve or perfect any claim for lien or mortgage which the claimant might have had.
- 4. For the purposes of GC 5.8, a claim shall be considered lawful when it is so determined:
  - (a) by a court of competent jurisdiction;
  - (b) by an arbitrator duly appointed to arbitrate the said claim; or
  - (c) by written notice delivered to the Departmental Representative and signed by the Contractor authorizing payment of the said claim(s).
- 5. A payment made pursuant to GC 5.8.2 is, to the extent of the payment, a discharge of Canada's liability to the Contractor under the Contract and may be deducted from any amount payable to the Contractor under the Contract.
- 6. GC 5.8.2 shall only apply to claims and obligations where:
  - (a) the notification of which has set forth the amount claimed to be owing and the person who by Contract is primarily liable;
  - (b) the notification or a copy of the notification was received by the Departmental Representative in writing before final payment is made to the Contractor and within one hundred and twenty (120) days of the date on which the claimant:
    - (i) should have been paid in full under the claimant's Contract with the Contractor or Subcontractor where the claim is for money that was lawfully required to be held back from the claimant; or
    - (ii) performed the last of the labour or furnished the last of the Plant or Material pursuant to the claimant's Contract with the Contractor or Subcontractor where the claim is not for money referred to in GC 5.8.6 (b)(i); and
  - (c) the proceedings to determine the right to payment for the claim shall have commenced within one year from the date that the notice referred to in GC 5.8.6 (b) was received by the Department Representative.
- 7. The Departmental Representative shall inform the Contractor in writing of receipt of any notification of claim and of the intention of Canada to withhold funds pursuant to GC 5.8.2. The Contractor may, at any time thereafter and until payment is made to the claimant, post with Canada, security in the form of a Claimant's Payment Bond acceptable to Canada and in an amount equal to the value of the said claim. Upon receipt of such security Canada shall release to the Contractor any funds which would be otherwise payable to the Contractor, that were withheld pursuant to the provisions of GC 5.8.2.

## GC 6 CHANGES IN THE WORK

## GC 6.1 Changes in the Work

- 1. Canada shall have the right to order additional Work, dispense with, or change the whole or any part of the Work described in the Drawings and Specifications or Scope of the Work.
- 2. The Departmental Representative shall decide whether anything done or not done as a result of directions given under GC 6.1.1 has increased or decreased the cost of the Work to the Contractor and where the cost of the Work has increased or decreased, the amount payable

under the Contract shall be increased or decreased by an amount calculated in accordance with GC5.7.

3. Any change in the terms of the Contract, other than changes that may be ordered by Canada or the Departmental Representative pursuant to GC 6.1.1, may be made only by agreement in writing between Canada and the Contractor.

## GC 6.2 Changes in Subsurface Conditions and Delays by Canada

- 1. No extra payment shall be made to the Contractor for any extra expense, loss or damage for any reason unless Canada shall certify that such extra expense, loss or damage is directly attributable to:
  - (a) a substantial difference between the subsurface conditions as indicated in the Drawings and Specifications or Scope of Work and the actual conditions found at the site of the Work; or
  - (b) the neglect or delay by Canada, occurring after the date of award of the Contract:
    - (i) in providing any information or the doing of any act which Canada is required
    - expressly by the Contract to do or as required by a known custom of the trade; or(ii) in suspending the Work pursuant to GC 7.3.
- 2. The Contractor shall, within ten (10) days immediately after encountering such subsurface conditions or such neglect or delay, give written notice to the Departmental Representative of a claim for such extra expense, loss or damage. Failure to provide such written notice shall render the claim null and void.
- 3. The amount of any extra payment made under this section shall be calculated in accordance with GC 5.7.
- 4. If, in the opinion of the Departmental Representative, any difference in subsurface conditions referred to in GC 6.2.1 results in a savings to the Contractor, the amount of said savings shall be deducted from the Contract Amount owing to the Contractor.

## GC 6.3 Extension of Time

- 1. Upon written application by the Contractor made before the date fixed for the completion of the Work, Canada may extend the time for completion of the Work if, in the opinion of Canada causes beyond the control of the Contractor have delayed its completion.
- 2. If the Contractor does not complete the Work by the day fixed for its completion, but completes it thereafter, the Contractor shall:
  - (a) pay all Canada's inspection costs relating to the Work incurred after the stipulated completion date; and
  - (b) compensate Canada for any loss or damage resulting from the failure by the Contractor to complete the Work by the completion date fixed by the Contract.

Unless, in the opinion of Canada, such delay was due to causes beyond the control of the Contractor or it is in the public interest to waive the whole or any part of the payment.

## GC 7 DEFAULT, SUSPENSION OR TERMINATION OF CONTRACT

## GC 7.1 Taking the Work Out of the Contractor's Hands

1. By giving notice in writing to the Contractor, Canada may take all or any part of the Work out of the Contractor's hands, and may employ such means as Canada sees fit to have the Work completed if the Contractor:

- fails to remedy any delay in the commencement or default in the execution of the Work to the satisfaction of the Departmental Representative within six (6) days of Canada giving written notice to the Contractor to do so;
- (b) defaults in the completion of any part of the Work within the time fixed by the Contract for its completion;
- (c) becomes insolvent or commits an act of bankruptcy and has neither made a proposal to its creditors nor filed a notice of intention to make such a proposal pursuant to the *Bankruptcy and Insolvency Act*;
- (d) abandons the Work;
- (e) makes an assignment contrary to GC 1.3; and or
- (f) otherwise fails to observe or perform any of the provisions of the Contract.
- 2. If the whole or any part of the Work is taken out of the Contractor's hands, the Contractor's right to any further payment that is due or accruing due under the Contract is extinguished.
- 3. The Contractor shall be liable to pay Canada, upon demand, an amount that is equal to the sum of all losses and damages incurred or sustained by Canada in respect of the Contractor's failure to complete the Work.
- 4. If the whole or any part of the Work that is taken out of the Contractor's hands pursuant to GC 7.1.1 is completed by Canada, the Departmental Representative shall calculate the amount, if any, of the holdback or progress claims that had accrued and was due prior to the date on which the Work was taken out of the Contractor's hands.
- 5. If it is determined that there is an amount that is not required for the purposes of having the Work performed or of compensating Canada for any other loss or damage incurred or sustained by reason of the Contractor's default, Canada may then pay the Contractor the amount determined not to be required pursuant to GC 7.1.4.

## GC 7.2 Effect of Taking the Work Out of the Contractor's Hands

- 1. The taking of the Work or part thereof out of the Contractor's hands pursuant to GC 7.1.1 does not operate so as to relieve or discharge the Contractor from any obligations under the Contract or imposed upon the Contractor by law except the obligation to complete the performance of that part of the Work that was taken out of the Contractor's hands.
- 2. All Plant and Material and the interest of the Contractor in all real property, licenses, powers and privileges acquired, used, provided or consumed by the Contractor under the Contract shall continue to be the property of Canada without compensation to the Contractor.
- 3. When the Departmental Representative certifies that any Plant, Material or any interest of the Contractor referred to in GC 7.2, is no longer required for the purpose of the Work, or that it is not in the interests of Canada to retain that Plant, Material or interest, it shall revert to the Contractor.

#### GC 7.3 Suspension of the Contract

- 1. Canada may, upon giving notice in writing to the Contractor, suspend the performance of the Work at any time. The Contractor shall comply with such notice immediately, subject to any conditions that may be stipulated in the notice.
- 2. If Canada suspends the Work for thirty (30) days or less the Contractor shall, subject to its remedy under GC 5.7, complete the Work when called upon to do so. If Canada suspends the

Work for a period in excess of thirty (30) days, the Contractor may request that Canada terminate the Contract pursuant to GC 7.4.

3. It is the responsibility of the Contractor to mitigate all costs during the suspension period.

#### GC 7.4 Termination of the Contract

- 1. Canada may terminate the Contract at any time by giving notice of termination in writing to the Contractor and upon receipt of such notice the Contractor shall cease all operations in performance of the Contract, subject to any conditions that may be stipulated in the notice.
- 2. Termination under GC 7.4.1 shall not relieve the Contractor of any legal or contractual obligations other than that portion of Work that remains to be completed at the time of the termination.
- 3. Payment, in event of termination under this subsection, shall be made pursuant to the provision of GC 5.5.

## GC 8 DISPUTE RESOLUTION

- 1. The Contractor may, within 10 days after the communication to the Contractor of any decision or direction referred to in GC2.1(b) and GC6.1, protest that decision or direction.
- 2. A protest referred to in GC8.1 shall be in writing, contain full reasons for the protest, be signed by the Contractor and be given to Canada.
- 3. If the Contractor gives a protest pursuant to GC8.2, any compliance by the Contractor with the decision or direction that was protested shall not be construed as an admission by the Contractor of the correctness of that decision or direction, or prevent the Contractor from taking whatever action the Contractor considers appropriate in the circumstances.
- 4. The giving of a protest by the Contractor pursuant to GC8.2 shall not relieve the Contractor from complying with the decision or direction that is the subject of the protest.
- 5. Subject to GC8.6, the Contractor shall take any action referred to in GC8.3 within 3 months after the date of the Certificate of Completion referred to in GC5.6 and not afterwards, except where it is otherwise provided by law.
- 6. The Contractor shall take any action referred to in GC8.3 resulting from a direction under GC3.4, within 3 months after the expiry of a warranty or guarantee period and not afterwards, except where it is otherwise provided by law.
- 7. Subject to GC8.8, if Canada determines that the Contractor's protest is justified, Canada shall pay the Contractor the cost of the additional labour, Plant and Material necessarily incurred by the Contractor in carrying out the protested decision or direction.
- 8. Costs referred to in GC8.7 shall be calculated in accordance with GC5.7.

#### GC 9 INDEMNIFICATION AND INSURANCE

#### GC 9.1 Indemnification

1. The Contractor shall indemnify and save harmless Canada, its servants, agents and all those for whom Canada may be, in law, responsible, from and against all claims, demands, losses, damages, costs and legal proceedings by whomever made, sustained, brought or prosecuted,

and in any manner based upon, occasioned by or attributed to the activities of the Contractor, the Contractor's employees, agents or persons for whom the Contractor is, in law, responsible for the performance or purported performance of the Contract, including an infringement or alleged infringement of a patent of invention or any other kind of intellectual property.

- 2. For the purpose of GC 9.1.1, activities include any act improperly carried out and any omission or delay in carrying out an act.
- 3. The Contractor's liability to indemnify or reimburse Canada under the Contract shall not affect or prejudice Canada from exercising any rights available to Canada at law or in equity.

#### GC 9.2 Insurance Contracts

- 1. The Contractor shall, at the Contractor's expense, obtain and maintain insurance contracts in respect of the work and shall provide evidence thereof to Canada in accordance with the requirements of the INSURANCE TERMS.
- 2. The insurance contracts referred to in GC 9.2.1 shall:
  - (a) be in a form, of the nature, in the amounts, for the periods and containing the terms and conditions specified in INSURANCE TERMS; and
  - (b) provide for the payment of claims under such insurance contracts in accordance with GC 9.3.

#### GC 9.3 Insurance Proceeds

- 1. In the case of a claim payable under a Builders Risk/Installation (All Risks) insurance contract maintained by the Contractor pursuant to GC 9.2, the proceeds of the claim shall be paid directly to Canada, and
  - (a) the monies so paid shall be held by Canada for the purposes of the Contract, or
  - (b) if Canada elects, shall be retained by Canada, in which event they vest in Canada absolutely.
- 2. In the case of a claim payable under a General Liability insurance contract maintained by the Contractor pursuant to GC 9.2, the proceeds of the claim shall be paid by the insurer directly to the claimant.
- 3. If an election is made pursuant to GC 9.3.1, Canada may cause an audit to be made of the accounts of the Contractor and of Canada in respect of the part of the work that was lost, damaged or destroyed for the purpose of establishing the difference, if any, between
  - (a) the aggregate of the amount of the loss or damage suffered or sustained by Canada, including any costs incurred in respect of the clearing and cleaning of the Work and its site and any other amount that is payable by the Contractor to Canada under the Contract, minus any monies retained pursuant to GC 9.3.1 (b); and
  - (b) the aggregate of the amounts payable by Canada to the Contractor pursuant to the Contract up to the date of the loss or damage.
- 4. A difference that is established pursuant to GC 9.3.3 shall be paid forthwith by the party who is determined by the audit to be the debtor to the party who is determined by the audit to be the creditor.
- 5. When payment of a deficiency has been made pursuant to GC 9.3.4, all rights and obligations of Canada and the Contractor under the Contract shall, with respect only to the part of the work that was the subject of the audit referred to in GC 9.3.3, be deemed to have been expended and discharged.

- 6. If an election is not made pursuant to GC 9.3.1 (b), the Contractor shall, subject to GC 9.3.7, clear and clean the work and its site and restore and replace the part of the work that was lost, damaged or destroyed at the Contractor's expense as if that part of the work had not yet been performed.
- 7. When the Contractor clears and cleans the Work and its site and restores and replaces the work referred to in GC 9.3.6, Canada shall pay the Contractor out of the monies referred to in GC 9.3.1 so far as they will thereon to extend.
- 8. Subject to GC 9.3.7, payment by Canada pursuant to GC 9.3.7 shall be made in accordance with the Contract but the amount of each payment shall be 100 percent of the amount claimed notwithstanding GC 5.3 a) and b).



Appendix "E"

# TECHNICAL SPECIFICATIONS AND PLANS



Agriculture and Agriculture et Agri-Food Canada Agroalimentaire Canada

01B46-14-0056

# **TECHNICAL SPECIFICATIONS**

# LIGHTING RETROFIT

# T12 TO T8 FLUORESCENT FIXTURES CONVERSION

**Research Farm** 

1468, St-Cyrille St., Normandin, Quebec G8M 4K3

### Part 1 General

### 1.1 GENERAL SCOPE OF WORK

.1 The work includes in general, but not limited to, the conversion of T12 fluorescent lighting fixtures to T8 (4' lamps). Ballasts, lamps and sockets will be replaced. For information purposes only, the building lighting plans are attached in an appendix.

### 1.1 **REFERENCES**

- .1 Canadian Standards Association (CSA International)
  - .1 CSA C22.1 CEC-09, Canadian Electrical Code, Part 1 Safety Standard for Electrical Installations.
    - .2 CSA CAN3-C235-87, Preferred Voltage Levels for AC systems 0 50,000 V.
- .2 Health Canada / Workplace Hazardous Materials Information System (WHMIS).

# 1.2 SHOP DRAWINGS AND QUALITY CONTROL

- .1 Shop drawings:
  - .1 The contractor shall submit the technical specifications of the ballasts, the lamps,
  - the sockets and the quick connectors that will be utilized within the project.
  - .2 If changes are required, notify the Engineer/Project Manager of these changes before proceeding.
- .2 Quality Control:
  - .1 Provide CSA certified components.

### **1.3 ELECTRICAL WORKS**

1. Electricity works include labor, handling, materials and tooling for furniture, installation, connection and complete start-up, clean and safe for electrical systems and other, comply with art rules, manufacturer recommendations, as shown or described in drawings and specifications.

# 1.4 QUALITY ASSURANCE

- .1 Qualifications: electrical works to be carried out by qualified licensed electricians who hold a valid Master Electrical Contractor license or by apprentices supervised by electricians who hold such a license. Each work team must be supervised by a licensed electrician. The license must respect all requirements of the Province where the works are done.
- .2 Site Meetings:
  - a. Site meetings: the contractor must participate to the following job meetings:
    - .1 Before installation begins.
    - .2 As required, during progress of work.
    - .3 Upon completion of work, after cleaning is carried out.
- .3 Health and Safety Requirements
  - a. Regardless of the circumstances and the nature of the work, individuals with access to the work site must wear protective footwear and hard hats.
  - b. A safety perimeter on the floor must be placed under the work zone in order to protect the public and the occupants.
  - c. The Contractor shall make sure that the work site is kept clean and tidy for the duration of the work.

# 1.5 DELIVERY, STORAGE AND HANDLING

.1 Material Delivery Schedule: provide Engineer/Project Manager with schedule within 1 weeks after award of Contract.

# 1.6 SYSTEM STARTUP

.1 Instruct the Engineer/Project Manager and operating and maintenance personnel before startup.

# Part 2 Products

# 2.1 MATERIALS AND EQUIPMENT

.1 Materials to be new and CSA certified.

### 2.2 WARNING SIGNS

.1 Warning Signs: in accordance with requirements of the Engineer/Project Manager and maintenance personnel.

# 2.3 WIRING TERMINATIONS AND CONNECTIONS

1. Ensure lugs, terminals, screws used for termination of wiring are suitable for either copper or aluminum conductors.

### 2.4 WIRING

- 2.4.1 Building Wires
  - .1 Circuit conductors; copper, size as indicated and not less than #12 A WG.
  - .2 Copper conductors: size as indicated, with 600 V insulation of chemically crosslinked thermosetting polyethylene material rated RW90 and RWU90 as required by installation location.
  - .3 Armour: metal clad cable for new installations and relocations.
- 2.4.2 Armoured Cables
  - .1 Conductors: Insulated, copper size as indicated.
  - .2 Type: AC90 XLPE.
  - .3 Armour: metal clad cable.
  - .4 Connectors: connectors suitable for conductors.
  - .5 Maximum length: any new armour cable installation will not be more than 3 meters in length.
  - .6 Installation of wires: install only conductors that are CSA approved for inside lighting fixtures usage.

# Part 3 Execution of Works

# 3.1 INSTALLATION

.1 Complete the installation in accordance with CSA C22.1 except where specified otherwise.

# 3.3 RETROFIT

- .1 Luminaires shall be modified by replacing existing lamps, ballasts and sockets with energy efficient models. The lighting fixtures are equipped with louvers or diffusers. Remove and replace all louvers and diffusers. If the contractor damages the louvers or diffusers, he shall replace them at his own cost.
- .2 All T12 lamps removed by the contractor shall be disposed in cardboard boxes with individual spacers by a fluorescent lamp recycler. Provide proof following disposal.
- .3 Existing T12 luminaires shall be retrofitted with T8 fluorescent lamps and rapid start electronic ballasts (IS). The number of retrofitted fixtures shall match the number of existing fixtures. Margin for error of 3 % in quantity.

# NUMBER OF FIXTURES TO BE CONVERTED

1 Lamp T12 fixture = 108 units in the main building. 2 Lamp T12 fixture = 375 units in main building, 8 units in building #23 and 9 units in building #33.

- .4 The Facility Manager will indicate to the contractor where he will store his equipment and material during work period.
- .5 Provide two (2) lamp replacement boxes of 24 units each to the owner.

# 3.4 WIRING

.1 Luminaires shall remain on existing lighting circuits. Install quick-connect lugs between power and ballasts wiring. Do not start work before putting breaker « off» and use protective measures to insure that circuit remains off for the duration of shift. Level of quality: Standard or approved equivalent

# 3.5 LUMINAIRE SUPPORTS

.1 For suspended ceiling installations support luminaires from ceiling grid in accordance with in effect regulations.

# Part 4 Products

# 4.1 LAMPS

.1

Lamp Design and Wattage	Base	Туре	Initial Lumens	Life hr	Description	Colour temperature <sup>o</sup> K (CRI)
T8-32	Medium 2 pin	IS	3100 (Initial)	(24000) (IS)	Medium white	4100 (≥80)

- .2 Lumen maintenance: 94% or 2900 mean lumens
- .3 Level of quality : Philips or approved equivalent.

# 4.2 BALLASTS

- .1 Fluorescent ballasts: CBM and CSA certified, energy efficient type.
  - .1 <u>*Rating: voltage is 347 volts*</u>, 60 Hz, for use with 28/ 32W, rapid start or instant start lamps.
  - .2 RFI/EMI suppression circuit compliant to the Federal Communication Commission (USA) FCC (CFR47) Part 18, sub-part C, Class A and Part 15, sub-part B, Class B.
  - .3 Totally encased and designed for 40°C ambient temperature.
  - .4 Power factor: minimum 90 % with 95% of rated lamp lumens.
  - .5 Crest factor: 1.5 maximum current, 2.0 maximum voltage.
  - .6 Capacitor: thermally protected.
  - .7 Thermal protection: non-resettable, on coil.
  - .8 Harmonics:
    - .1 10 % maximum THD, including 49th for electronic discrete and hybrid ballasts,
  - .9 Operating frequency of electronic ballast: 21 kHz minimum.
  - .10 Ballast Factor: greater than 0.90.

# Research Farm Normandin

Ballast Efficacy Factor (BEF)	Lamps	Low BF:0.85	Norm 0.85 <bf:1.0< th=""><th>High BF1.01</th></bf:1.0<>	High BF1.01
	_		Instant-Start Ballast (BEF	7)
	1	3.08	3.11	3.03
DEE (DE 1001	2	1.60	1.58	1.55
BEF = [BF x 100] /Ballast Input	3	1.04	1.05	1.04
Watts Based on:	4	0.79	0.80	0.77
(1) Type of ballast (2) No. of lamps driven by ballast		Prog	grammed Rapid-Start Ballas	t (BEF)
(3) Ballast Factor	1	2.84	2.84	2.95
	2	1.48	1.47	1.51
	3	0.97	1.00	1.00
	4	0.76	0.75	0.75


- .11 Sound rated: Class A.
- .12 Mounting: integrated in the luminaire.
- .13 Level of quality: Standard or approved equivalent

# 4.3 SHUNTED SOCKETS

- .1 Existing sockets shall be replaced on each lighting fixtures with turned-type lampholders. Dispose of discarded sockets.
- .2 Acceptable materials are:
  - .1 Leviton #23351shunt or approved equivalent
  - .2 Standard #38241 or approved equivalent

# 4.4 WASTE MANAGEMENT AND DISPOSAL


- .1 Separate and recycle waste materials in accordance with applicable Waste Management and Disposal codes.
- .2 Place in indicated containers the substances which correspond to the definition of toxic waste or dangerous material. Disposal according to applicable regulations.
- .3 Recover and sort plastic waste, paper packaging and cardboard and recycle.
- .4 Waste material must be recovered, handled, and stored on site and then be disposed in a sorted form.
- .5 Waste material must be transported to a certified and approved recycling facility.



DNDARE AERIENNE 120/240V 10 OVERHEAD SECONDARY LI 10 OVERHEAD SECONDARY LI 10 INDICATIONS UND WIRING AND CONDUIT, AS UND TELEPHONE CONDUIT, AS	LIGNE AERIENNE PRIMAIRE 14,400/25KV TRIPHASEE AVEC NEUTRE, FILERIE TYPE ACSR #2 14,400/25KV, 3 OVERHEAD PRIMARY LINE WITH NEUTRAL TYPE ACSR #2. LIGNE SECONDAIRE AERIENNE 347/600V 30 3 #2 NSF2	HAUBAN GUY	DISTRIBUTION EXTERIEUR: OUTSIDE DISTRIBUTION: POTEAU DE BOIS À INSTALLER OU À REMPLACER WOOD POLE TO INSTALL OR TO REPLACE	LAMPADAIRE EXISTANT A ENLEYER AVEC SA FILERIE UGHTING STANDARD WITH WIRING TO REMOVE ST.C: PRISE DE COURANT POUR STATIONNEMENT A ENLEVER AVEC SA FILERIE PARKING RECEPTACLE WITH WIRING TO REMOVE	DEMOLITION:	BATIMENT EXISTANT A CONSERVER EXISTING BUILDINGS TO RETAIN BATIMENT A CONSTRUIRE BUILDING TO BUILT	BATIMENTS: BUILDING:	LEGENDE / LEGEND :	RMATION 2 - X RMATION 2 - X RMATION 1: TYPES DES APPAREILS D'ECLAIRAGE, VOIR LES DESCRIPTIONS DANS LE TABLEAU DES LUMINAIRES. LIGHTING FIXTURES TYPES, SEE DESCRIPTION IN LIGHTING FIXTURES INTERRUPTEURS DANS LA MEME PIECE, LA LETTRE EN MINUSCULE A L'INTERIEUR DU LUMINAIRE INDIQUE L'INTERRUPTEUR QUI LE CONTROLE. WHEN THERE IS MANY SWITCHES IN THE SAME ROOM, SMALL LETTER INSIDE FIXTURE INDICATE THE CONTROL SWITCH.	AT ACCOMP JSES ET D WITH LETTE RECONNED SUPPLEMED UORESCEN	INS D'INDICATION CONTRAIRE, LES SYMBOLES DESSINES.; EN TRAITS FILLES SONT DECRITS DANS D'AUTRES DIVISIONS QUE LA DIVISION 16. S DOIVENT ETRE RACCORDES PAR LA DIVISION 16. PT WHERE OTHERWISE INDICATED, THE SIGNS DRAW IN DOTTED LINES BE SPECIFIED BY OTHER DIVISION, BUT CONNECTED BY DIVISION 16. SONT A FOURNIR, INSTALLER ET RACCORDER. PT WHERE OTHERWISE INCICATED, THE SIGNS DRAWN IN SOLID LINES BE SUPPLIED, INSTALLED AND CONNECTED.	SLES GENERALES / VERAL INFORMATION:
GRADATEUR ELECTRONIQUE AVEC INDICATEUR EN/HORS LUMINEUX ET INTERRUPTEUR A EFFLEUREMENT. IL DOIT ETRE MUNI DUNIE GUSSIERE REGLABLE DE 0 A MAX. LE TOUT S'INSERANT DANS UNE PLAQUE DECORATIVE DE FINITION LE TOUT S'INSERANT DANS UNE PLAQUE DECORATIVE DE FINITION LE TOUT S'INSERANT DANS LA COULEUR DU GRADATEUR SERA MOIRE. MODELE DE REFERENCE PRESCOLTE ENHANCE EN 1000 UPIH. PRESET TYPE DIMMER, COMPLETELY ELECTRONIC COMPLETE WITH TOROID FILTER. IT IS EQUIPES WITH SOFT-TOUCH ON/OFF BUTTON WITH LED INDICATOR, WITH A SUDE PROVIDING RANGE FROM 0 TO MAX. THIS DIMMER IS SUITABLE FOR TIGON WATTS OF LOAD OF MUST FIT IN STANDARD DECORA LEVITON WALL PLATE. THE FINISH MUST BE WORY.	\$4 INTERRUPTEUR QUADRIPOLAIRES 15A/125V. 15A/125V. FOUR WAY SMITCH.	<pre>\$ INTERRUPTEUR UNIPOLAIRE 15A/125V. AVEC LAMPE TEMOIN. A L'EPREUVE DES INTEMPERIES 15A/125V. SINGLE POLE WATERPROOF SWITCH WITH PILOT LIGHT. \$ INTERRUPTEUR TROIS VOIES 15A/125V. \$ 15A/125V. THREE WAY SWITCH.</pre>	NEGATIVE IMPULSION, AND INSTALLED IN ENCLOSURE CONFORM TO QUEBEC ELECTRICAL CODE STANDARD SECTION 1800. INTERRUPTEUR UNIPOLAIRE 15A. A TENSION DE LIGNE 120V. OU 347V. SELON LES INDICATIONS. LINE VOLTAGE SWITCH 15A. SINGLE POLE 120V. OR 347V. AS INDICATED.	INTERRUPTEUR A BAS VOLTAGE AVEC LED INTEGRES. POUR LES PIECES DONT LES INSTALLATIONS ELECTRIQUES DOIVENT ETRE CONFORME A LA SECTION 18-000 DU CODE CANADIEN DE L'ELECTRICITE PREVOIR: INTERRUPTEUR BAS VOLTAGE DEUX DIRECTIONS ET A CONTACTES MOMENTARES À MODIFIER. INSTALLER DEUX DIDDES DE FACON À ENVOYER UNE IMPULSION POSSITVE OU UNE IMPULSION NEGATIVE. LE TOUT MONTE DANS UN BOTTER CONFORME AUX EXIGENCES DE LA SECTION 18-000 DU CODE D'ELECTRICITE DU QUEBEC S LOW VOLTAGE SWITCH WITH INTEGRATED LED. IN THE RANADIAN ELECTRICAL CODE SECTION 18-000 ADD: TO THE CANADIAN ELECTRICAL CODE SECTION 18-000 ADD: LOW VOLTAGE SINGLE POLE DOUBLE THROW SWITCH WITH MOMENTARY LOW VOLTAGE SINGLE POLE DOUBLE THROW SWITCH WITH MOMENTARY LOW VOLTAGE TO MODIFY, INSTALL TWO DIODES FOR SENDING À POSITIVE OR	ECLAIRAGE LIGHTING	CABINET D'INTERFACE DE L'ORDINATEUR DES SERRES VOIR PLANS D'ELECTRICTE DES SERRES ES-1 A ES-3 GREENHOUSE COMPUTER INTERFACE ENCLOSURE REFER TO PLAN ES-1 TO ES-3 PANNEAU DE CONTROLE D'ECLAIRAGE DES SERRES. VOIR PLANS D'ELECTRICTE DES SERRES ES-1 A ES-3 GREENHOUSE LIGHTING CONTROL PANEL REFER TO PLAN ES-1 TO ES-3	PANNEAU DE CONTROLE DES EQUIPEMENTS DES SERRES SUR NORMAL. VOIR PLANS D'ELECTRICTE DES SERRES ES-1 A ES-3 GREENHOUSE EQUIPMENTS CONTROL PANEL ON "NORMAL" REFER TO PLAN ES-1 TO ES-3 VOIR PLANS D'ELECTRICTE DES SERRES ES-1 A ES-3 GREENHOUSE EQUIPMENTS CONTROL PANEL ON "EMERGENCY" REFER TO PLAN ES-1 TO ES-3	EQUIPEMENTS DE SERRES IDENTIFIES AUX PLANS ELECTRIQUES GREENHOUSE EQUIPMENTS IDENTIFIED TO ELECTRICAL PLANS	BOITE DE TIRAGE 250/250/150mm AVEC PORTE À CHARNIERE POUR USAGE FUTUR, À FIXER SOUS LA DALLE DU PLAFOND. ELLE DOIT EIRE ACCESSIBLE ET EIRE NUNIE D'UN CONDUIT EMT SOmme JUSQU'AU PANNEAU ELECTRIQUE. • 250/250/150mm PULL BOX WITH HINGE DOOR FOR TO INSTALL UNDER THE CEILING SLAB. STALL BE ACCESSIBLE AND EQUIPPED WITH SOmme EMT CONDUIT TO THE ELECTRICAL PANEL. MINI CENTRE DE DISTRIBUTION ETANCHE AUX INTEMPERIES POUR BORNES D'ALIMENTATION DES CHAUFFE-MOTEURS DU STATIONNEMENT ARRIÈRE. WEATHERTIGHT_DISTRIBUTION MINI-CENTER FOR BEHIND PARKING BLOCK-HEATERS.	PDP       WAN DISTRIBUTION PRINCIPAL         CDP       CENTRE DE DISTRIBUTION PRINCIPAL         CDP       WAN DISTRIBUTION PANEL         INTERRUPTEUR DE TRANSFERT AUTOMATIQUE         T.A.       AUTOMATIC TRANSFER SWITCH         COM-XXX       CENTRE DE CONTROLE DES MOTEURS. VOIR DIAGRAMME         MOTOR CONTROL CENTER. REFER TO DIAGRAM.	ANNEAU ELECTRIQUE TYPE SURFACE VOIR DIAGRAMME ELECTRIQUE. SURFACE TYPE ELECTRIQUE TYPE ENCASTRE VOIR DIAGRAMME ELECTRIQUE. RECESSED TYPE ELECTRIQUE TYPE ENCASTRE VOIR DIAGRAMME ELECTRIQUE. RECESSED TYPE ELECTRIQUE PANEL REFER TO ELECTRICAL DIAGRAM. TRANSFORMATEUR DE VOLTAGE ET DE PUISSANCE INDIQUES. VOIR LE DIAGRAMME ELECTRIQUE. VOLTAGE TRANSFORMER OF CAPACITY INDICATED. REFER TO ELECTRICAL DIAGRAM.	DISTRIBUTION DISTRIBUTION

						<b>A</b> -	SERV		€[]	ح <b>ا</b> فل	PET	) Ĺ			⊢⊗	÷Ά		G		
ST-2 BORNE D'ALIMENTATION POUR CHAUFFE-MOTEURS TYPE 2. SUPPLY BOLLARD FOR BLOCKHEATERS TYPE 2.	BOLLARD FOR BLO	<ul> <li>→ PRISE DE COURANT DOUBLE 15A/125V *5-15R' FOURNIE PAR LE FABRICANT DE LA HOTTE À ALMENTER.</li> <li>15A. 125V. 5-15R DUPLEX RECEPTACLE SUPPLIED BY THE HOOP MANU- FACTURER TO CONNECT.</li> <li>← ENSEMBLE DE DEUX PRISES DE COURANT DOUBLE *5-15R' MONTEES DANS UN PIEDESTAL, À INSTALLER AU CENTRE DU COMPTOIR SET OF TWO DUPLEX RECEPTACLE 5-15R INSTALLED IN MONUMENT TO INSTALL ON THE COUNTER CENTER.</li> </ul>	DES INTEMPERIES A INSTALLER A 200mm AU DESSUS DU COMPTOIR. 15A/125V "5-15R" WEATHERPROOF DUPLEX RECEPTACLE TO INSTALL AT 200mm ABOVE COUNTERS	PRISE DE COURANT DOUBLE 15A/125V "5-15R" A INSTALLER A 1000 MM DU PLANCHER 15A. 125V. DUPLEX RECEPTACLE TO INSTALL AT 1000mm FROM FLOOR.	PRISE DE COURANT DOUBLE 15A/125V "5-15R" A INSTALLER A 150 MM AU-DESSUS DU COMPTOIR. VOIR PLANS D'ARCHITECTURE. 15A. 125V. 5-15R DUPLEX RECEPTACLE INSTALLED AT 150mm ABOVE COUNTER. SEE ARCHITECTURAL DRAWINGS.	PRISE DE COURANT DOUBLE 15A/125V "515R" A INSTALLER A 300 MM DU PLANCHER. 15A, 125V. 515R DUPLEX RECEPTACLE TO INSTALL AT 300mm F.F.	RVICES ELECTRIQUE : ECTRICAL SERVICES :	LANPADAIRE AVEC DEUX LUMINAIRES VOIR TABLEAU. LIGHTING STANDARD WITH TWO LUMINAIRE REFER TO CHART.	LAMPADAIRE AVEC UN LUMINAIRE VOIR TABLEAU. LIGHTING STANDARD WITH LUMINAIRE REFER TO CHART.	CELLULE PHOTOELECTRIQUE 2000W. / 125V. PHOTO-ELECTRIC CELL 2000W. / 125V.	CONTROLE D'ECLAIRAGE EXTERIEUR PREFILE EN USINE. E EXTERIOR LIGHTING CONTROL FACTORY WIRED.	APPAREIL D'ECLAIRAGE EXTERIEUR PLAFONNIER. VOIR TABLEAU. OUTDOOR LIGHTING FIXTURE CEILING TYPE, REFER TO CHART.	APPAREIL D'ECLAIRAGE EXTERIEUR TYPE MURAL. VOIR TABLEAU. OUTSIDE LIGHTING FIXTURE WALL TYPE REFER TO CHART.	APPAREL D'ECLAIRAGE AUTONOME AVEC 2 PHARES AU TUNGSTEN (H.I.T.) 12V./9W.,ACCUMULATEUR AU PLOMB PUR SCELLE A LONGIVITE PROLONGEE, D'UNE CAPACITE DE 216W.POUR UNE DUREE D'UNE DEMIE-HEURE,INDICATEUR DE CHARGE,VOLTNETRE,AMPEREMETRE, ET SUPPORT DE MONTAGE L'APPARELL DOIT EIRE CONFORME A LA NORME CSA-C22.2 NO.141. "MODELE DE REFERENCE :12ESL-216-2Q-B2-V-A-MA-12-125V. DE EMERGI-LITE" A INSTALLER AVEC UNE PRISE DE COURANT A 2.440mm DU PLANCHER. EMERGENCY LIGHTING UNIT WITH 2 SEALED BEAM(H.I.T.) 12V./9W PURE LEAD SEALED BATTERY LONGUFE CAPACITY 218W. 30MIN. WITH VOLTMETER, AMMETER C/W MOUTING BRACKET - SHALL BE CONFORMED TO CSA C22.2 NO. 141 REFERENCE MODELE 12ESL-218-2Q-B2-V-A-MA-12-125V TO INSTALL WITH A RECEPTACLE AT 2.440mm FROM THE FLOOR.	APPAREIL D'INDICATION DE SORTIE. VOIR TABLEAU. EXIT INDICATING LIGHT. REFER TO CHART.	APPAREIL D'ECLAIRAGE INTERIEUR TYPE MURAL, VOIR TABLEAU INSIDE LIGHTING FIXTURE WALL TYPE, REFER TO CHART	APPAREIL D'ECLAIRAGE INTERIEUR TYPE PLAFONNIER, VOIR TABLEAU INSIDE LIGHTING FIXTURE CEILING TYPE, REFER TO CHART	APPAREIL D'ECLAIRAGE FLUORESCENT À RACCORDER DIRECTEMENT AU PANNEAU D'URGENCE, DE FACON À FONCTIONNER 24 HEURES/24 HEURES. FLUORESCENT LIGHTING FIXTURE CONNECTED TO EMERGENCY PANEL BOARD, 24 HOUR OPERATION.	1 TUBE FLUORESCENT LIGHTING FIXTURE, REFER TO CHART. APPAREIL D'ECLAIRAGE FLUORESCENT 2 TUBES. VOIR TABLEAU. 2 TUBE FLUORESCENT LIGHTING FIXTURE, REFER TO CHART.	APPAREIL D'ECLAIRAGE FLUORESCENT 1 TUBE. VOIR TABLEAU.
pwc Project Manager Administrat drawing number drawing na. no.de dessin sheet no. QU91009-B E1 de	date 91-01-31 approved YVON BUTEAU approved YVON BUTEAU Acte 91-01-31 Tender, J.J.J.J.J.J.J.J.J.J.J.J.J.J.J.J.J.J.J.	designed PIERRE DU-PERRE designed PIERRE DU-PERRE date 91-01-31 drawn PAUL LAFRANCE drawn PAUL LAFRANCE dote 91-01-31 reviewed Rogert LAROUCHER Torvert Source	PAGE 1	rat	FERME EXPERIMENTAL complexe bureau, laborat pavillons de services EXPERIMENTAL FARM	project NORMANDIN	revisions A detail no.			THE PHESENT WORKS. ALL SOUTAGES IDENTIFIED ON THE PRESENT DOCUMED MUST BE UNIFORM IN ALL POINTS AN PRESENT AN ASPECT OF NEW.	RESTORE, REPAIR AND REBULD IN TH SAME MANNER ALL SURFACES THAT I BEEN DEMOLISHED OR MODIFIED DURIN	THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS ON THE SITE BEFORE STARTING THE WORK. THE DEPARTME	RAGREER, REPARER ET APPAREILLER J SURFACE OU IL Y A EU DEMOLITION O MODIFICATION DUE AUX PRESENTS TRA TOUTES LES SURFACES IDENTIFIEES AL PRESENTS DOCUMENTS DEVRONT PRES ASPECT DE NEUF ET ETRE EN TOUS P UNIFORMES.	L'ENTREPRENEUR DOT PRENORE ET VE TOUTES OIMENSIONS SUR PLACE AVAN COMMENCER LES TRAVAUX, LE MINISTE N'ASSUME AUCUNE RESPONSABILITE QU DIMENSIONS PRISES A L'ECHELLE SUR LES DESSINS.	<u>иун 4, Боорнан ан на Аладия и А</u>				Agriculture Canada	Public Works Travaux Canada Canada

1



NOTES: - LES PLANS [ APPAREILS D STRUCTURE, D'INSTALLATIC L'APPAREILS. L - DE PLUS L'E D'ECLAIRA PIECES D ETRE MU TENSION	G2 G1 FLU FLU FLU	E E D3 FLV0 E2 FLV0 E2 FLV0 E2 FLV0 E2 FLV0 E2 FLV0 E1 FLV0 E2 FLV0 E2 FLV0	C B2 B1 A MODELES MODEL FLUO FLUO
PECLAIRAGE INDIQUENT LES TYPES ET ECLAIRAGE AINSI QUE LES SOURCES E A POSITION EXACTE AINSI QUE LE MOT OTVENT TENIR COMPTE DES CONTRAINT LES EQUIPEMENTS MECANIQUES ET LI N PAR RAPPORT AUX EXIGENCES DES INT L'INSTALLATION DES ENTREPRENEUR DOFT EN FAIRE APPRO NTREPRENEUR DOFT FOURNIR DES DES N DES METHODES D'INSTALLATION DES N DES METHODES D'INSTALLATION DES N DES SECTEURS 500 ET 60 NIE DE BALLAST -18°C/0 INDIQUEE.	L. 347 V. BLANC CHAUD 2. 347 V. 2. TUBES 347 V. 2. TUBES BLANC CHAUD BLANC CHAUD 1. 347 V. 2. T. 40W. BLANC CHAUD 2. 40W. 2. 40W. 3. 40W.	L 347 V. BLANC CHAUD T. 347 V. 2T. 40W. W.W. L 347 V. 1T. 40W. I. 347 V. 1T. 40W. I. 347 V. 1T. 40W. II. 40W. II. 40W. II. 40W. II. 40W. II. 40W. II. 40W. II. 40W. II. 40W. U. 1T. 40W. II. 40W. II. 40W. ELANC CHAUD II. 40W. U. 2T. 40W. BLANC CHAUD 2T. 40W. BLANC CHAUD 2T. 40W. BLANC CHAUD	TABLE TENSIONS VOLTAGE NMB. DE TUBES/ UMPES. VOLTAGE N. OF TUBES AND LAMPES. 2. 347 V. 347 V. 327. 40%. 327. 40%.
TOUS LES ADPAREILS ET 600 DOIVENT LA LOCALISATION ES DES DIFFERENTS TYPES TOUS LES APPAREILS ET 600 DOIVENT ET 600 DOIVENT	REGLETTE AVE DE PRUTECTION / STRIP VIRE CITAL STRIP VIRE STRIP VIRE CUMPANIA SUSPENSION AU OOUZE PROVING SUSPENSION AU OOUZE PROVING SUSPENSION AU OUZE PROVING SUSPENSION AU OUZE PROVING SUSPENSION AU OUZE PROVING SUSPENSION AU OUZE PROVING DE COULEUR ALZAK ATO WINNE A CHARNIE CONSTRUCTED OF COULEUR AU CHORE A CHARNIERE CEMA TEUR DE RACCORI CLEAR ACRYLIC LENS SYSTEM CEMA-3 ENCLOSURE WITH CONNEC CLEAR ACRYLIC LENS SYSTEM CEMA-3 ENCLOSURE WITH CONNEC CLEAR ACRYLIC LENS SYSTEM CEMA-3 ENCLOSURE WITH CONNEC CLEAR ACRYLIC LENS SYSTEM CEMA-3 ENCLOSURE WITH CONNEC CONNEC CONNEC CONNECTION CONNEC	115     STRIP       1220     STRIP       1220     REGLETTE       65     STRIP       1220     REGLETTE       55     STRIP       95     STRIP       1220     REGLETTE       55     STRIP       1220     REGLETTE       1220     REGLETTE       115     REGLETTE       1220     STRIP       122     DE       122     DE       122     DE       122     DE       122     STRIP       122     STRIP       122     DE       122     DE       122     DE       122     DE       122     STDE       122     STDE       122     STDE       122     DE       122     DE       123     DE       124     DE       125     STDE	CARACTERI NS TECHNICHAL CA AVEC CADRE A DIFFUSEUR KJE DISPOSITIF A ENC A RESSORT A RESSORT TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER AND VIS TRIGGER
SHTING PLANS SHOW THE TYPES AND THE QUANTITIES OF LIG S, INCLUDING THEIR CIRCUITS AND CONTROLS. THE EXACT D BY THE STRUCTURE, THE MECHANICAL EQUIPEMENTS AND TYPICAL INSTALLATION IN RESPECT OF REQUIREMENTS FORET ROOMS. BEFORE ATION THE CONTRACTOR SHALL OBTAIN FROM THE PROJET M CALISATION APPROVAL OF THE FIXTURES. INDICATED ALL FLUORESCENT FIXTURES. SINDICATED ALL FLUORESCENT FIXTURES. MITHALATION METHODS FOR THE ALL TYPES OF FIXTURES. C/OFF OF VOLTAGE SPECIFIED.	SUSPENDU A 5500 HM DU PLANCHER DU SELLON LES INDICATIONS TO SELLON LES INDICATIONS DR AS INDICATED. ES BORES DES UNMARES DORENT ETRE CONSUME SU ACAUES DORENT ETRE E UNMARE POLICATED ACTION DATES IN CONSULTS SUSPENSION PORTS, ICHNICALTES A CONCET TE FINITE DELLE CAMPES DATE INTERPORT TO STATUSTALLER EN SURFACE. L'INSTALATION DICIT ETRE ETANCHE A L'HUMIDITE ET A LA PCIUSSIERE A S500 MM DU PLANCHER ETANCHE A L'HUMIDITE ET A LA PCIUSSIERE ETANCHE A L'HUMIDITE ET A LA PCIUSSIERE DUST AND MOISTURE PROOF DUSSIERE HUNG UP AT 5500 F.F. DUST AND MOISTURE PROOF	L'INTERIEUR DES VALANCES SITUES AU-DESSUS DES VAUITES, URINOIRS ET CABINETS. WALL TYPE TO INSTALL INSIDE THE VALANCES ABOVE THE VANITES. TO INSTALLER SOUS LES ARMOIRES DES COMPTOIRS TO INSTALL RECOMPTOIRS APPLIQUER MURAL A INSTALLER DANS LE RETRAIT DU PLAFOND DU CORRIDOR MALL TYPE TO INSTALL ON THE CORRIDOR CEILING RECESS A INSTALLER DANS LE PUITS DE LUMIERE A TOUS LES JOOMM c/c TO INSTALLER DANS LE PUITS DE LUMIERE A TOUS LES JOOMM c/c SURFACE MONTED. SUSPENDRE A 2750 MM DU PLANCHER	LIGHTING CHART STICS CARACTERISTIQUES D'INSTALLATION INSTALLATION CARACTERISTICS A ENCASTRER DANS PLAFOND USTER A ENCASTRER DANS PLAFOND SUSPENDU EN TULES ACOUSTIQUES ACOUSTICS ACOUSTIQUES ACOUSTIQUES ACOUSTICS A
OF LIGHTING XACT CONSTRAINTS AND BATION BATION ALL BE	ISTLVANIA KDC-78-248 KDC-78-248 KDC-78-248 KDC-78-248	K-402-248       P-248       LS-248       K401-148       P-148       LS-148       LS-148       LS-148       K401-148       LS-148       LS-148       K401-148       LS-148       LS-148       K401-148       LS-148       K401-148       LS-148       K401-148       KWG-402-248       HALIDE       KWG-402-248       LS-WG-248-P48WG       LS-WG-248-P48WG       LS-WG-248-P48WG       LS-WG-248-P48WG       LS-WG-248-P48WG       LS-WG-248-P48WG	REFERENCES REFERENCES STLVANIA 3E-34-448- 2-TC YORK YORK YORK H1 FLUE H2 FLUE H2 FLUE
	1 LAMPE 400 W. MH. CLEAR 1 LAMPE DE 400 W. MH. CLARPE 1 LAMP DE 400 W. M.H. CLEAR 1 LAMP DE 1 LAMP 9525 1 LAMP 1	BLANC CHAUD 200 X 185 21, 40W. 185 21, 40W. 185 X 185 X 185 X 1397 W.W. 1397 W.W. 1397 Y. 400 W. MH. CLAIR. 1397 I LAMPE 400 W. MH. CLAIR. 1397 Y. 1 LAMPE 400 W. MH. CLAIR. 1397	TABLEAU I NIMB. DE TUBES/ N. OF TUBES AND LAMPES. DIMENSI N. OF TUBES AND LAMPES. DIMENSI N. OF TUBES AND LAMPES. DIMENSI PLANC CHAUD 2T. 40W. 1220 X S47 V. BLANC CHAUD 217. 40W. 1220 X 185 217. 40W. 1397
	INTERFITICATIE VIELLIARE QUE 75X.	CADRE AVEC LENTILLE EN LEXAN -6 ATTACHES A RESSORT -SPECIFICATION MINIMALES SELON LA CLASSE 2 DIVISION 2 GROUPE EF, G DE LA SECTION 18 DU C.E.Q -STAINLESS STEEL ENCLOSURE -FARME WITH LEXAN LENS -6 STRING FASTENERS MIN. -MIN. SPECIFICATION AS PER CLASS 2 DIV 2 GROUP E, F, G - C.E.Q. SECTION 18 CLASS 2 DIV 2 GROUP E, F, G - C.E.Q. SECTION 18 CLASS 2 DIV 2 GROUP E, F, G - C.E.Q. SECTION 18 - C.E.Q. SECTION 0.	D'ECLAIRAGE / LIGH
	HANG UP AT 5500 F.F. MIN DUST AND MOISTURE PROOF EXIGENCES MINIMALES SELON UA CLASSE 2 DIVISION 2 GROUPE E.F.G. DE LA SECTION 18 DU C.E.Q. E.F.G. GROUP E.F.G C.E.Q. SECTION 18 DU C.E.Q. E.F.G. C.E.Q. SECTION 18 DU C.E.Q. SECTION 18	PLANCHER. EXIGENCES MINIMALES SELON LA CLASSE 2 DIVISION 2 GROUPE E.F.G. DE LA SECTION 18 DE C.E.Q. HANG UP AT 5500 F.F. MIN REQUIREMENT CLASS 2 DIV 2 GROUP E.F.G C.E.Q. SECTION 18 C.E.Q. SECTION 18 DUSTALLER SOUS LA DALLER DE L'ETAGE DOUT ETRE ETANCHE A L'HUMIDITE ET A LA POUSSIERE TO INSTALL UNDER THE FIRST OR MEZZANINE SLAB DUST AND MOISTURE PROOF L'INSTALLATION DOIT ETRE ETANCHE A L'HUMIDITE ET A LA POUSSIERE.	TING CHART CARACTERISTIQUE D'INSTALLATION CARACTI INSTALLATION CARACTI SUSPENDRE A 2750 MM DI L'INSTALLATION DOIT ETANCHE A L'HUMIDITE POUSSIERE POUSSIERE DUST AND MOISTURE F DUST AND MOISTURE F NINIMALES SELON LA CLAS DIVISION 2 GROUPE ELF, G, SECTION 18 DE C.E.Q. SURFACE MIN. REQUIREMED CLASS 2 DIV 2 GROUP EL SUSPENDRE A 5500 mm.
	R PURSLEY FMH-400 SOUSE-HINDS NVM-ZA- CO-HR54- A-E-PUSCE FILO R PLUO R	APPLETON ARN-240-347 PURSLEY CAS-MH-4000- 34-77 LE MPM-3PRT FW Q HALOGE	PPLETON M-240-347 N INCANDE
	. 347 V. 2 TUBES BLANC CHAUD 2 TUBES 60W. BLANC CHAUD 2 TUBES 60W. HQI-30007K HQI-30007K 1 LAMPE 1 SOM, HQI-30007K 1 LAMPE 1 SOM, HQI-30007K 1 LAMPE 1 SOM, HQI-30007K HQI-30007K HQI-30007K HQI-30007K	NE 120 V. TRANSFO. NE 120 V. HRANSFO.	TABLE TENSIONS VOLTAGE N. OF TUBES N. OF TUBES AND LAMPES S-125 V. 1 LAMPE ES-125 V. 1 LAMPE 200 W. 1 LAMPE
	Resultance         Series         With an under Series         <	-COORPS ET PROTECTEUR FINI EMAIL EPOXIDIQUE -COPPER FREE ALLIMINIUM ENCLOSURE -BODY AND PROTECTOR ENAMEL EPOXY FINISHE SELON LES INDICATIONS. LETTRAGE 150 X 19 mm. EXITS LIGHTS W/O APROW AS INDICATED INDICATED SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. NDICATED INDICATED SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. SANS FLECHE SELON LES INDICA- TIONS.LETTRAGE 150 X 19 mm. HUDICATED INDICATES INDICE INDICATED INDICATES INDICE INDICATES INTO INFO INDICATES INDICATES INTO INFO INDICATES INTO INFO INDICATES INTO INFO INDICATES INTO INFO INDICATES INTO INFO INDICATES INTO INFO INTO	AU D'ECLAIRAGE / LIGE
	E.     Ludit       Ludit     SUSPENDRE A 5,500mm DU PLANCHER L'INSTALLATION DOT ETRE ENANCHER A L'HUMIDITE ET A LA POUSSIERE. HANG UP AT 5500 F.F. MIN DUST AND MOISTURE PROOF     BALLAST	SURFACE DUST AND MOISTURE PROOF SURFACE DUST AND MOISTURE PROOF SURFACE, PLAFONIER OU MURAL SELON LES INDICATIONS. MURAL SELON LES INDICATIONS. MURAL SURFACE, CEILING OR WALL MOUNTED TYPE AS INDICATED. INSTALLER AU MUR A 450 mm. AU DESSUS DE LA PORTE. INSTALL ON THE WALL AT 450mm OVER THE DOOR. WALL AT 450mm OVER THE DOOR. TUILES ACOUSTIQUES DE GYPSE OU EN TUILES ACOUSTIQUES DE GYPSUM CEILING T-BAR OR GYPSUM CEILING	TO INSTALLER AU WUR DU A TASO MAN DU PLAFOND. EXIGENCES MINIMALES SELON CLASSE 2 DIV. 2 GROUPE E, F, G DE LA SECTION 18 DU C.E.Q. AT 450 mm FROM CELUN REQUIREMENTS CLASS 2 1 E,F,G Q.E.C. SECTION 1


́.

<u>М</u>

a r t

i.

1





		Instrumentaria         Instrum					
REAL         DECLARENCE         LOHITUC         CHART           Image: Comparison of the compariso	NUMAL         DECLARIZACIÓN         V         LOTINICO         CHARTINICO         Manual         Manual <thm< td=""><td></td><td>NOTES: - LES PLANS D'ECLAIRAGE APPARELS D'ECLAIRAGE CONTROLE - LA POSITION APPARELS DOTVENT TED STRUCTURE , LES EQUI D'INSTALLATION PAR RA L'OCAUX. AVATI L'INSTA APPARELS. L'ENTREPREN L'APPARELS. L'ENTREPREN D'ECLAIRAGE FL D'ECLAIRAGE FL PIECES DES SE ETRE MUNIE DE TENSION INDIQU</td><td>BB         HPS         347 V.           CC         HPS         347 V.           DD         HPS         347 V.</td><td>Y HPS 347 V. Z HPS 347 V. AA HPS 347 V.</td><td>HPS 347 V.</td><td>V MODELES MODEL SOURCES VOLIAGE 347 V.</td></thm<>		NOTES: - LES PLANS D'ECLAIRAGE APPARELS D'ECLAIRAGE CONTROLE - LA POSITION APPARELS DOTVENT TED STRUCTURE , LES EQUI D'INSTALLATION PAR RA L'OCAUX. AVATI L'INSTA APPARELS. L'ENTREPREN L'APPARELS. L'ENTREPREN D'ECLAIRAGE FL D'ECLAIRAGE FL PIECES DES SE ETRE MUNIE DE TENSION INDIQU	BB         HPS         347 V.           CC         HPS         347 V.           DD         HPS         347 V.	Y HPS 347 V. Z HPS 347 V. AA HPS 347 V.	HPS 347 V.	V MODELES MODEL SOURCES VOLIAGE 347 V.
DECLIVACION     CONTINUE     CONTINUE       INTERNET     INTERNET     INTERNET     INTERNET     INTERNET     INTERNET       INTERNET     INTERNET <td>DECLINING         Instruments         Instruments</td> <td></td> <td>E INDIQUENT LES TYPES ET AINSI QUE LES SOURCES D VEXACTE AINSI QUE LE MOD VIR COMPTE DES CONTRAINTE PEMENTS MECANIQUES ET LE PEMENTS MECANIQUES ET LE PEMENTS MECANIQUES ET LE DEUR DOT EN FAIRE APPRO UORESCENT INSTALLATION DES ETHODES D'INSTALLATION DES D'INSTALLATION DES DES UDRESCENT INSTALLATION DES DES UDRESCENT INSTALLATION DES DES UDRESCENT INSTALLATION DES D'INSTALLATION D'INSTALLATION DES D'INSTALLATION D'INSTALLATION D'INSTALLATI</td> <td>1 LAMPE 150 W. CLAIR 150 W. CLAIR CLAIR</td> <td></td> <td>150 W. CLAIR HPS CLAIR HPS CLAIR</td> <td>I LAMPES AND LAMPES AND LAMPES AND LAMPES</td>	DECLINING         Instruments		E INDIQUENT LES TYPES ET AINSI QUE LES SOURCES D VEXACTE AINSI QUE LE MOD VIR COMPTE DES CONTRAINTE PEMENTS MECANIQUES ET LE PEMENTS MECANIQUES ET LE PEMENTS MECANIQUES ET LE DEUR DOT EN FAIRE APPRO UORESCENT INSTALLATION DES ETHODES D'INSTALLATION DES D'INSTALLATION DES DES UDRESCENT INSTALLATION DES DES UDRESCENT INSTALLATION DES DES UDRESCENT INSTALLATION DES D'INSTALLATION D'INSTALLATION DES D'INSTALLATION D'INSTALLATION D'INSTALLATI	1 LAMPE 150 W. CLAIR 150 W. CLAIR CLAIR		150 W. CLAIR HPS CLAIR HPS CLAIR	I LAMPES AND LAMPES AND LAMPES AND LAMPES
Inclution         Characterization	IDENTITION         CHART           23         NUMBER DESCRIPTIONS         RETURNED           24         NUMBER DESCRIPTIONS         RETURNED           25         NUMBER DESCRIPTIONS         RETURNED           26         NUMBER DESCRIPTIONS         RETURNED           26         NUMBER DESCRIPTIONS         RETURNED           26         NUMBER DESCRIPTIONS         RETURNED           27         NUMBER DESCRIPTIONS         RETURNED         RETURNED           28         RETURNED         RETURNED         RETURNED           28         RETURNED         RETURNED         RETURNED         <		LES QUANTITES DES VALIMENTATION ET DE SE DE FIXATION DES ES IMPOSEES PAR LA ES CARACTERISTIQUES DIFFERENTS VWER LA LOCALISATION SINS D'ATELIERS POUR S LES APPAREILS DO DOIVENT F. DE		ACRIMENTAL BULCK: POLYEST AUMINIARE UTUL ULMINIARE UTUL ULMINIARE UTUL PRESENTALIMIN RECEAST ALIMIN RECEAST ALIMIN RECEAST ALIMIN RECEAST ALIMIN RECEAST MITCHE BULKETING ACRITICAL BULKE ACRITICAL BULKE ACRI	A 88, WE POR COULE WE POR TRATE CONTRE OFFRANT UNE LE FIN EST PE NOR NOR NOR NOR NOR NOR NOR NOR NOR NOR	D'ECLAIRAGE / D'ECLAIRAGE / SIONS SISIONS TECHNICHAL CARACTERISTIQUES TECHNICHAL CARACTERIS TECHNICHAL CARACTERIS
REFERENCES REFERE	REFERENCES REFERE		UGHTING PLANS SHOW THE TYPES AND THE O JRES, INCLUDING THEIR CIRCUITS AND CONTROL TION AND THE TYPE OF SUPPORTS DEPENDING SED BY THE STRUCTURE, THE MECHANICAL EQUING HE TYPICAL INSTALLATION IN RESPECT OF REQU JIFFERET ROOMS. BEFORE ALLATION THE CONTRACTOR SHALL OBTAN FRO LOCALISATION APPROVAL OF THE FIXTURES. CONTRACTOR MUST SUBMIT SHOP DRAWINGS F NSTALLATION METHODS FOR THE ALL TYPES OF NITALLED IN AREA NO:500 AND & UIPED WITH BALLAST FOR OPER BC/OF OF VOLTAGE SPECIFIED BC/OF OF VOLTAGE SPECIFIED	SHAPE       CONCRETE       BASE       AND NOT         WRE       JOOmm THE SOIL NIVEL       SOIL NIVEL       SOIL NIVEL         WARE       FRANCING       FRANCING       FORMET       FORMET <t< td=""><td>A ENCASTRER A L'EXTERIEUR DANS LE RECESSED LUMINAR OUTSIDE IN THE S RECESSED LUMINAR OUTSIDE IN THE S APPLIQUER MURAL A INSTALL HORIZONTALEMENT A INSTALL HORIZONTALEMENT A INSTALL HORIZONTALEN DE LA PORTE. MURAL APPLICATED TO INSTAL ASOMM FROM THE TOP OF (HONRIZONTAL) ASUPPORT CYLINDRIQUE, MOD BL-P. LE SUPPORT DOIT BL-P. LE SUPPORT DOIT DANS LA BASE DE BETON D A CE QU'IL EXCEDE 300mm NIVEAU DU SOL FINI SUPPORT MUST BE SINKED CONCRETE BASE AND NOT B</td><td>DUNCALISATION ET LA HAUTEUR D'INSTALLATION VOIR LES ELEV SUR LES PLANS D'ARCHITECTU ITO INSTALL ON THE WALL, FOI DRAWING DRAWING DRAWING DRAWING HE BUCASTRER DANS LE MUR À 1000mm</td><td>CHART CHART CHART CHART CHART D'INSTALLATION CARACTERISTIQUES D'INSTALLATION CARACTERISTIQUES</td></t<>	A ENCASTRER A L'EXTERIEUR DANS LE RECESSED LUMINAR OUTSIDE IN THE S RECESSED LUMINAR OUTSIDE IN THE S APPLIQUER MURAL A INSTALL HORIZONTALEMENT A INSTALL HORIZONTALEMENT A INSTALL HORIZONTALEN DE LA PORTE. MURAL APPLICATED TO INSTAL ASOMM FROM THE TOP OF (HONRIZONTAL) ASUPPORT CYLINDRIQUE, MOD BL-P. LE SUPPORT DOIT BL-P. LE SUPPORT DOIT DANS LA BASE DE BETON D A CE QU'IL EXCEDE 300mm NIVEAU DU SOL FINI SUPPORT MUST BE SINKED CONCRETE BASE AND NOT B	DUNCALISATION ET LA HAUTEUR D'INSTALLATION VOIR LES ELEV SUR LES PLANS D'ARCHITECTU ITO INSTALL ON THE WALL, FOI DRAWING DRAWING DRAWING DRAWING HE BUCASTRER DANS LE MUR À 1000mm	CHART CHART CHART CHART CHART D'INSTALLATION CARACTERISTIQUES D'INSTALLATION CARACTERISTIQUES
	HANDLEL HANDLE	HYDRE HYDRE SHILLE	PROBATI NTS AN SHALL NTS AN FIXTU	ER MOLDCAST PARACYL LUMINAIRES POLL108-1 -34-BLP POTEAU: PO S1-4-20JA FERRURE 99502-BL 99502-BL 99502-BL SERIE SERIE SERIE SERIE MOLDCAST SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SERIE SI - 4-20JA	KIM KIM SI-REQUIS HPS-347-BL HPS-347-BL SI-REQUIS -PC	4-02-15 14-02-15 14-02-15 14-02-15 14-02-15 14-02-15 14-02-15	UR REFERENCES

i i na de la como de la La como de la


•

			Ŧ	TABLEAU       DES         SPECIAL       SPECIAL         1       20A         1       20A         2       20A         4       50A         5       30A         10       15A         13       30A         13       30A         13       30A
				S PRISES ET FICHES D INGLE RECEPTACLES A INGLE RECEPTACLES A ENSION DLTAGES N/PHASES DLTAGES N/PHASES 0/208V 10 600V 10 600V 10 208V 10 208V 10 208V 10 208V 10 30 600V 10 30 10 10 10 10 10 10 10 10 10 10 10 10 10
	STORESS &			E COURANT SIMPLES E COURANT SIMPLES ND PLUGS ELECTRICA NOMENCLATURE DES PRISES CONFIG. RECEPTACLE 630R/ARRH3382 630R/ARRH3382 615R/ARRH3382 1450R 1550R 1450R 1450R 1450R 150R 150R 1-5-522 1-5-5222 1-5-52222 1-5-522223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-52223 1-5-5223
χ.	Resolution Format C C C C C C C C C C C C C			SPECIALES SPECIALES CHART L CHART NOMENCLATURE DES FICHES CONFIG. PLUG 14-30P 14-30P 14-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-50P 15-5151 6-15P/ENP-6151 3 FILS BIPOLAIRES/CPH-7913 3 FILS QUADRIPOLAIRES/CPH-7734
	AND SPECIAL EL OUTLETS CH designed PIERRE DU-PERRE date 91-01-31. date 91-01-31. date 91-01-31. reviewed ROBERT LAROUCHE gate 91-01-31 date 91-01-31 date 91-01-31 Tender VI BUTEAU date 91-01-31 Tender VI BUTEAU date 91-01-31 Tender Adminut PWC Project Manager Admin drawing number QU91009-B E4	A detail no. A detail no. B location day sur dessin c drawing in c drawing in c drawing in c dessin no. C drawing in c dessin no. Pavillons de EXPERIMENTA S, laboratories, buildin TABLEAU TABLEAU TABLEAU	L'ENTREPRENEUR DOIT PRENDRE B TOUTES DIMENSIONS SUR PLACE , COMMENCICER LES TRAVAUX, LE MI N'ASSUME AUCUNE RESPONSABILI DIMENSIONS PRISES A L'ECHELLE LES DESSINS. RAGREER, REPARER ET APPAREIL SURFACE OU IL Y A EU DEMOLT MODIFICATION DUE AUX PRESENT TOUTES LES SURFACES IDENTIFIE PRESENTS DOCUMENTS DEVINENTS DEVINENTS DECUNES ON THE SITE BEFOR STARTING THE WORK. THE DEPA DECLINES ANY RESPONSIBILITY A DIMENSIONS SCALED ON THE DRA BEEN DEMOLSHED ON THE DRA INFORMER ALL SURFACES TO BEEN DEMOLSHED OR MODIFIED THE PRESENT WORKS. ALL SURFACES TO BEEN DEMOLSHED OR MODIFIED THE PRESENT AN ASPECT OF NEW.	Public Works Canada Canada Canada






NOTES         DASS CETTE PIECE, TOUTE L'INSTALLATION DOIT ETRE CONFORME A LA SECTION 18-000 DU CODE CANADEN DE L'ELECTRICTE DU QUEBEC POUR LES EMPLACEMENTS DANGERELVE DE CLASSE 1, DM/SION 1.         A       IN THIS ROOM, ALL INSTALLATION MUST BE CONFORM TO SECTION 18-000 OF THE ELECTRICAL CODE OF QUEBEC PONSION 1.         DANS CETTE PIECE, TOUTE L'INSTALLATION MUST BE CONFORM DE L'ELECTRICITE DU QUEBEC POUR LES EMPLACEMENTS DE L'ELECTRICITE DE CLASSE 2, DM/SION 2.         B       IN THIS ROOM, ALL INSTALLATION MUST BE CONFORM TO RECARDING EXPLOSION PROOF FACILITIES IN CLASS 2, DM/SION 2.         C       DANS CETTE PIECE, TOUTE L'INSTALLATION DOIT ETRE CONFORME A LA SECTION 18-000 DU CODE CANADIEN DANSEREUX DE CLASSE 3, DM/SION 1.         C       IN THIS ROOM, ALL INSTALLATION MUST BE CONFORM TO SECTION 18-000 OF THE ELECTRICAL CODE OF QUEBEC DANGEREUX DE CLASSE 3, DM/SION 1.         C       IN THIS ROOM, ALL INSTALLATION MUST BE CONFORM TO SECURION 18-000 OF THE ELECTRICAL CODE OF CALSENTS DM/SION 1.		pour la suite voir la page #E20 for continuation see #E20	10 PLAN THI CONTLE 1:100		
NOTES 1-TOUS LES APPAREILS D'ECLAIRAGE D'URGENCE A 120 V. DU SECTEUR PRINCIPAL DOVENT ETRE RACCORDES AU PANNEAU PSU207-C42. ALL EXERGENCY LIGHTING UNIT IN THE MAIN SECTOR SHALL BE CONNECTED TO PANEL PSU207-C42. 2-TOUTES LES INDICATIONS DE SORTIE "TYPE "O" " ET LES APPAREILS D'ECLAIRAGE FLUORESCENT D'URGENCE A 347 DU SECTEUR PRINCIPAL DOVENT ETRE RACCORDES AU PANNEAU COP-U1-430EC1 ALL "SORTIE" INDICATION TYPE "O" AND EMERGENCY FLUORESCENT FINTURES 347V. IN THE MAIN SECTOR SHALL BE CONNECTED TO PANEL COP-U1-430EC1. 3-POUR LES INFORMATIONS RELATIVES AUX SERRES DETAILLES DES SERRES. REFER TO GREENHOUSE PLANS FOR INFORMATION ON ROOM 407, 410 AND 411. 4-POUR L'ECLAIRAGE DU MOBILIER DES LABORATOIRES CONSULTER LE PLAN AGRANDI E14 DE 30. FOR THE UGHTING OF LABORATORY FURNITURE REFER TO ENLARGE PLAN E14 OF 30 REFER TO ENLARGE PLAN E14 OF 30				PR22 PR22 PR22 PR22 PR22 PR22 PR22 PR22	
OFFICES, LABOR, AND MAIN SE LIGHTING designed PIEPRE DU-PERRE designed PIEPRE DU-PERRE dete 91-01-31 remained ROBERT LAROUCHE dete 91-01-31 remained WON BUTEAL dete 91-01-31 Tande Jack Manager Januar PWC Project Manager Januar drawing number QU91009-B E11	revisions revisions revisions revisions revisions revisions revisions revisions revisions revisions A datali na. na. du datali na. du datali c drawing na c drawi	L'ENTREPRENEUR DOIT PRENORE I TOUTES DIMENSIONS SUR PLACE COMMENSIONS PRISES A LECHELLE UMENSIONS PRISES A LECHELLE ES DESSINS. RAGREER, REPARER ET APPARELL SURFACE OU IL Y A EU DEMOLIT MODIFICA TION DUE AUX PRESENT TOUTES LES SURFACES IDENTRINT ASPECT DE NEUF ET ETRE EN TO UNIFORMES. THE CONTRACTOR SHALL VERIFY DIMENSIONS ON THE SITE BEFORE STARTING THE WORK. THE DEPA DECLINES ANY RESPONSIBILITY A: DIMENSIONS SCALED ON THE DRA BEEN OEXOLISHED ON THE DRA INE PRESENT WORKS. ALL SURFACES THE BEEN OEXOLISHED ON THE PRESENT DOO MUST BE UNIFORM IN ALL PORNTE PRESENT AN ASPECT OF NEW.	PLAN CLE/KEY P	Agriculture	Public Works Tray Canada Can



......


. .....

.





\_\_\_\_\_



PANNELUL : PDE-SOE     347/600 V.     32     32     4       PIECE : SOE     CHARGES     RACCORDEES $31/600$ V.     32 $4$ NOAL     SPRIES SPEC     ACCORDEES $31/600$ V. $32$ $15$ $16$ $1$	PANNEAU : PDE-AJOE     347/600 V     32     47       PIECE : 4JOE     CHARGES     RACCORDEES     JL U     B       VININ 3000     COLARGES     RACCORDEES     JL U     B     B       VININ 3000     COLARGES     RACCORDEES     JL U     B     B     B       VININ 3000     COLARGE RE-AJOE     B     B     B     B     B     B     B       1930     COLARGE RE-AJOE     B<	

ζ. · ·

.

, ·

≫ 4 §

REAS         COMM.         A PAREILS         UCCARRAGE           1         a         HOR         TYPES         QUAVIT.         LOCAL         WATTS           2         2         A         403         E         2         403         E         3         403         E         103         425         403         425         1020         A         B         418         A         3         421         22         2 </th <th>PR2-1305</th> <th></th> <th>•</th> <th></th> <th></th> <th></th> <th></th>	PR2-1305		•				
	NO NO	00	им.				IRAGE
a         402         61         2         403         B         5         403           2 X a         403         B         5         403           2 X a         407         E1         3         407           2 X a         407         E1         3         407           a         416         61         3         407           a         2 X a         202         A         8         416           a         421         A         3         422           a         423         A         3         422           a         423         A         3         421           a         423         A         3         422           a         423         A         3         423           a         428         A         2         428           4 X a         420         F         18         420           2 X a         432         2         428         428           4 X a         420         F         18         420           2 X a         432         2         438         420           3 3		IDENT.	LOCAL	TYPES	QUANT.	LOCAL	WATTS
$\begin{array}{ c c c c c c c c c c c c c c c c c c c$		٩	<b>1</b> 02	- G1	2	402	170
a         406         E1         2         406         E1         3         407           2         X         407         E1         3         407           2         X         408         G1         3         407           a         418         A         1         2         418           a         418         A         1         418           a         421         A         3         421           a         422         A         3         422           a         423         A         3         422           a         423         A         3         422           a         420         F         18         2         423           4         X         420         D1         16         420           2         X         432E         E1         2         430E           2         X         432E         E1	2	×	403	œ	UI	403	425
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	• •	< 🗅	50	2 🗆	- 2	406	1/2
$ \begin{array}{cccccccccccccccccccccccccccccccccccc$	л +	<  ×	407	3 🗉	<b>س</b> ہ	407	25
b         416         A         8         416           a         418         A         1         418           2 X a         202         A         8         426           2 X b         202         A         8         426           a         421         A         3         422           a         422         A         3         422           a         423         A         3         423           a         426         A         3         423           a         428         A         3         422           a         420         F         18         420           4 X c         420E         E1         2         422           2 X a         432E         E1         2         439E           2 X a         432E         E1         2         432E           3 3         422         432E         2         432E	ол (	۵ )	418	G	12	415	102
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	7	σ	416	A	8	416	680
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	8	٩	418	A		418	85
$ \begin{array}{ c c c c c c c c c c c c c c c c c c c$	Q	$\times$	202	A	œ	426	88
a       421       A       3       421         a       422       A       3       422         a       423       A       3       423         a       424       A       3       423         a       428       A       2       428         b       428       D1       3       425         4       X       420       F       18       420         4       X       420       F       18       420         4       X       429E       E1       2       428         2       X       432E       E1       2       432E         3       432E       E1       2       432E       432E         432E <td< td=""><td>10</td><td>×</td><td>202</td><td>A</td><td>8</td><td>428</td><td>680</td></td<>	10	×	202	A	8	428	680
a       422       A       3       422         a       423       A       3       423         a       424       A       3       423         a       424       A       3       423         a       425       A       3       423         a       428       D1       3       425         a       428       D1       3       425         4       X       420       F       18       420         4       X       420       D1       16       420         4       X       420       D1       16       420         4       X       420       E1       2       4306         2       X       4328       E1       2       4306         2       X       4328       E1       2       4328         2       X       4328       E1       2       4328         2       X       4328       E1       2       4328         3       4328       E1       2       4328       4328         4       3       4328       1       1       1		۵	421	≻	З	421	25
a       423       A       3       423         a       424       A       3       424         a       425       A       3       424         a       425       A       3       424         a       425       A       3       425         a       428       A       2       428         b       428       D1       3       428         4       X       420       A       20       428         4       X       420       D1       16       420         4       X       420       E1       2       426         2       X       431E       E2       5       430E         2       X       432E       E1       2       429E         2       X       432E       E1       2       432E         2       X       432E       E1       2       432E         2       X       432E       2       432E       432E         3       432E       1       1       1       1         4       1       1       1       1       1	12	۵	422	A	3	422	25
a       424       A       3       424         a       425       A       3       425         a       428       D1       3       425         b       428       D1       3       425         4       X       420       A       2       428         4       X       420       F       18       420         a       430E       E2       5       430E       22       2         2       X       429E       E1       2       430E       22       430E         2       X       432E       E1       2       432E       431E       2       432E         2       X       432E       E1       2       432E       432E       2       432E         2       X       432E       E1       2       432E       432E <t< td=""><td>13</td><td>۵</td><td>423</td><td>A</td><td>3</td><td>423</td><td>25</td></t<>	13	۵	423	A	3	423	25
a         425         A         3         425         A         3         425           a         428         A         2         428         A         2         428           b         420         A         20         A         20         420           4         X         420         F         18         420         420           4         X         420         D1         16         420         420           a         430E         E2         2         116         420         430E         221         431E           2         X         432E         E1         2         432E         432E         21         432E           2         X         432E         E1         2         432E	14	۵	424	A	З	424	253
a         428         A         2         428           b         428         01         3         428           4 X b         420         F         18         420           4 X c         420         F         18         420           a         430E         E2         5         430E           2 X a         431E         E2         21         431E           2 X a         432E         E1         2         432E           2 X a         432E         E1         2         432E           2 X a         432E         E1         2         432E           3         432E         E1         2         432E           4         432E         E1         2         432E           3         4         432E         1         432E           4         1         1         1         1         1           4         1         1         1         1         1         1           4         1         1         1         1         1         1           1         1         1         1         1         1         1 <td>5</td> <td>٩</td> <td>425</td> <td>A</td> <td>3</td> <td>425</td> <td>255</td>	5	٩	425	A	3	425	255
b         428         D1         3         428           4 X a         420         A         20         420         420           4 X c         420         D1         18         420           a         430E         E2         2         5         430E           2 X a         431E         E2         21         431E         22           2 X a         432E         E1         2         432E         21         431E           2 X a         432E         E1         2         432E         432E         21         432E	16	٩	428	A	2	428	170
$\begin{array}{ c c c c c c c c c c c c c c c c c c c$	17	σ	428	D1	3	428	135
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	- 18 18	×	420		20	420	1800
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	919	:  ×	420	ור !	18	420	162
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	21	<	1305	ŋ [	лõ	1705	12/
$\begin{array}{c ccccccccccccccccccccccccccccccccccc$	22	×	た」E	E	21	むTE	189
2 X a     432E     E1     2     432E       1     1     1     1     1       1     1     1	23	$\times$	429E	Ę	2	429E	180
	24	×	432E	Ę	2	432E	180
	25						LIBRE
	26						
	27						NBI I
	22						
	5 5						IIRR
							LIBR
	32				a de a de reger a de rècular a constant a de de se a constant de reger de se a constant de se a constant de se		LIBR
	33						ESPA
	34						ESPA
	35						ESPA
	80 80			-			ESP &
	37						ESPA
	85						ESPACE
	39						ESPACE
	đ						ESPA
	41						ESPA
	42						ESPA
	43						ESPACE
	44						ESPA
	\$5						ESPA
	46 6						ESPA
							ESPAC
	47		AT COMPANY AND TAKING AN AND TAKING AND				ESPA

22	NEAU :		Ű			ĥ	
IEAU	SUIT	2	CO	COMM.	Ър	APPAREILS	D'ECLAIRAGE
PANN	CIRC	RELAIS	IDENT.	LOCAL	TYPES	QUANT:	LOCAL
P0E-620E	_		2 X a	502	Ī	СЛ	502
		2	۵	504	E4	14	504
*******		3					
	2	4	3 X a	506	E2-E3	10	506
******		σ	1			:	
	2	8	2 X d	510	د.	£	510
	2	7	σ	510	5	ы	510
	2	8	α	511	нı	8	511
	ы	8	a	512	H1	4	512
	ы	10	٥	513	H1	4	513
	ы	11	۵	514	æ	8	514
	ы	12	۵	515	H2		5 5 5
	4	13	2 X a	516	×	ę	516
*****	<u>с</u> п.	14	2 X b	517	×	8	517
	თ	15	۵	519	ß	7	519
çanı	6	16	۵	520E	Ę	7	520E
		17					
		18					
		19					
ş		20					
		21	-				
		22					
çactarine		23					
		24					
		25					
- Januar dan	-	26				an de la constant de	
		27					
		28					
puparo		29					
		30					
-		31					
and the second	- A company of the second s	32				STATE STATE WAS IN COMPANY WITH A SHARE WITH A STATE OF STATE	
TOTAL							

	347/60	<u>20 V.</u>	<u></u>	45
)EES	ES C.	C. ES	CHARGE	S RACCORDEES
X	P0I CIR	CIR POI DIS	X	SORTIES SPEC. NO. NO. W.
A CARLON DE LA COMPANYA DE LA		a 15		-2 (P-431E)
				ور و و و و و و و و و و و و و و و و و و
				an a
			co	IP. #14 (P-431E)
	6 02			
	30, 11			
	15 13		PO	1PE ₽9 (P-431E)
			-	
	15 17			
-431E)	50 19	20 0 50	CHAUFFE E	EAU 60°C (P-431E)
	50 21			
	50 23	24 🕷 50		
	25	26		
	27	28		
	- 29	30		
	31	32		
	33	34		
	35	38		
	37	38		
	65	40		
.70810 WATTE	41		and in the second state in the second state of the second state of the second state of the second state of the	
	STE RACCORDEES No. \$ X No. \$ X		$\begin{array}{c c c c c c c c c c c c c c c c c c c $	$\begin{array}{c c c c c c c c c c c c c c c c c c c $

· .

.

			4400	A A A C C		2000		5000		14000		5000		10500			3840	5-3845	2480	TOTAL	PANNE
					*2.**Ce	19 19		læ	A HE	ν Ν	5.	N 5000 2			6.225.27	Starting Strand	1400 4	- 5 - 5	2432		PANNEAU : PDE-611E PIECE : 611E
		THE REAL AND A THE ATTICATION OF THE ATTICATIONO				Charles Charles Charles Ch	OPPERATURE AND INCOMENDATION AND AND AND AND AND AND AND AND AND AN		BANK ECIE	1812 E 1211- 1.202	C' 22 - Stranger C'	1007. EUR 674 12	the second s	Sector and the sector	1. 1. 1. 1. 2. 5. 2. 1. 2. C.	1. St. 1.	Soucersa Perc	- ECT VUA CUV	ECK PARY-CILE	LOAD DESCRIPTION CHARGE RACCORDEE	
39 40	37 38 /	35 36 /5	33 34 /	1531 3215	15-29 30/5-	15-27 28 13	15-25 26:0	15-23 24 50	· •	-	17 18 15 17 T	15 15. 16 15	50 13 14 %	50 11 12 40	30 9 10 70	NO 7 8/5-5	20 5 6 15-3×	1372 3 4 1.5	1521215	CIRCUIT	<u>347/600 V</u> .
		SCIE NATING 3	15 - SOLE ROUGAN 2000	r 61 Scarco		COM ROVEUR	0 11 2000	(c) (c)	0 0 8 0 10 F. F. P.	11	1/2	ANTENS DE	and the second		MANNEL CONNON	2 CONTRA MAY	2 4 10 1 G	14. 1 1 1 2200	024 113-144 7 7 2 4-5.	LOAD DESCRIPTION CHARGE RACCORDEE	
				TAXABLE IN CONTRACTOR		5					and a become		-							eo I	A. F.
			32750			1500		3000				2000	2000		10700		UBRE	2250	2700	TOTAL	

PANNEAU PIECE : ! 000

PANNEAU : PIECE :	: PR4	ธิ	POUR	ONTRO	CONTROLE DE L'	L'ECLAIRAGE	AGE
		сомм.	MM.	Ąp	APPAREILS	D'ECLAIRAGE	RAGE
		IDENT.	LOCAL	TYPES	QUANT.	LOCAL	WATTS
POE-611E 1		2 X a	602	د	4	602	1800
	2	σ	602 <sup>-</sup>	63	3	602	255
		۵	603	63	2	503 208	170
	4	۵	604	œ	3	604	255
	5						LIBRE
2	8	2 X a	608	<u>1</u> –2	6	606	2700
ۍ ا			606	Ę	4	606	2250
3	8	ס	606	E2	თ	606	425
ស	9	۵	607	62	8	607	680
υ	10	2 X a	808	ជ	თ	808	290
4		2 X a	609	د	ບາ	609	2250
сл	12	2 X a	609	د.	ъ	609	2250
СЛ	13	۵	610	E2	6	610	510
ол	14	۵	611E	E2	12	811E	1080
	15						LIBRE
	16						LIBRE
	17						LIBRE
	18	occupatro,					LIBRE
	19						LIBRE
	20						ESP.
-	21						ESP.
	22						ESP.
	23						ESP.
	24						ESP.
	25						ESP.
	26						ESP.
	27						ESP.
	28						ESP.
	29						ESP.
	30						ESP.
	31						ESP.
NU DO BRADINA MANAGANA ANA ANA ANA ANA ANA ANA ANA ANA			Conversion of the second		and the contract of the second second second		ESP.
TOTAL			1				

4

P.	
The second secon	

U : PDE-519E	<u>347/800 V</u> .		
CHARGES RACCORDEES	ES C. D C.	CHARGES RA(	RACCORDEES
W. NO. NO. \$ XX H	PO CIF AC CIF PO		NO. NO. W. WATIS
SECHOIR #15A. (P-518)		SECHOIR #14	en en en en
	5 8		
SECHOIR #13A. (P-518)	40 7 8 40	SECHOIR #25	#25A (P-518) 28000
	01 8		
	40 11 12 40		******
UNITHERME #1 (P-517)	13 14	UNITHERNE #2	2 (P-517) 1200
	15 18		-
	17   18		
UNITHERME #3 (P-517)	20 19 20 30	DEPOUSSIEREUR (P-515)	JR (P-515) 10500
	23 24		
	25 28	-	
	27 28		
	29 30		
	31 32		
	33 34		
	35 36		
	37 38		
	39 40		secture
		שיאנא אינער אינ אינער אינער אינע	

: 158500 WATTS T. : 1	בעדיים או איז	85	37	35	33	31	29	27	25	20 23	20 21	3 (P-517) 20 19	20 17		(P-517) 20 13		6 07	A. (P-518) 40 👼 7	40 5			ES SJ.	NAMPH WARD AND AND AND AND AND AND AND AND AND AN	
: <u>153 AMPS.</u>		40	38		34	32	30	28			22	20 30	18	18	14	12	04.01	8 40	8 40	2 40	AC CIF	ω RC. LES	ne (na mana and an	
BARRES : 225 AMPS.												DEPOUSSIEREUR (P-515)			UNITHERNE #2 (P-517)			SECHOIR #25A (P-518)		SECHOIR #14A. (P-518)	NO. NO. W.	CHARGES RACCORDEES	NA MATANANA NA MANANA NA MANANA NA MANANA	77
78500					sarastas.			****		1		10500			1200			28000		28000	TOTAL WATTS			- 11-11-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1-1

	area and																	
	-									20	20	20	20	20	20	\$	5	
š.				-	-				-					Č.		100		
	41	39	37	35	33	ц Ц	29	27	25	23	21	79 8	77	5	13	11	ω	
: <u>153 AMPS.</u>	42	40	38	38	34	32	30	28	28	24	22	20	18	16	14 8	12	10	
ķ										30	30	8 S	20	20	20	40	ð	
	140515-1604659723975532942976-160420-16																	
BARRES	SIGN TO SHE SHE SHE SHE SHE SHE											DE	-		UN			
												DEPOUSSIEREUR			UNITHERNE			
: 225 AMPS.	autors frazenskom multer veriges											REUR			#2			
Ŗ	Allowing											(P-515)			(P-517)			-
1	er vorozever	procession of the second s	outside of a	cristin.	saran şiranı							5					in the second	1
78500	No The State of									1		10500			1200			1000
õ		-		-							chicard	-						

10

•		
•		

		0058/

 $\triangleright$ 

Tel que construit

THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS ON THE SITE BEFORE STARTING THE WORK. THE DEPARTMENT DECLINES ANY RESPONSIBILITY AS FOR DIMENSIONS SCALED ON THE DRAWINGS. RESTORE, REPAIR AND REBUILD IN THE SAME MANNER ALL SURFACES THAT HAVE BEEN DENOLISHED OR MODIFIED DURING THE PRESENT WORKS. ALL SURFACES IDENTIFIED ON THE PRESENT DOCUMENTS MUST BE UNIFORM IN ALL POINTS AND PRESENT AN ASPECT OF NEW.

RAGREER, REPARER ET APPAREILLER TOUTE SURFACE OU IL Y A EU DEMOLITION OU MODIFICATION DUE AUX PRESENTS TRAVAUX. TOUTES LES SURFACES IDENTIFEES AUX PRESENTS DOCUMENTS DEVRONT PRESENTER UN ASPECT DE NEUF ET ETRE EN TOUS POINTS UNIFORMES.

L'ENTREPRENEUR DOT PRENDRE ET VERIFIER TOUTES DIMENSIONS SUR PLACE AVANT DE COMMENCER LES TRAVAUX, LE MINISTERE N'ASSUME AUCUNE RESPONSABUTE QUANT AUX DIMENSIONS PRISES À L'ECHELLE SUR LES DESSINS.

LAROUCHE

Â

QU91009-B

767265

I-PERRE


 $\bigcirc$ 


Agricult Canada

Public Works Canada

÷ •.

- .






PANNEAU : PS-B23 BATIMENT #23 CHARGES RACCORDEES TOTAL SORTIES SPEC. WATTS W. NO. NO. \$ XX ( 400		» OL IIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIIII	$\sim 15$ $\sim 120/208$	→ CIRC. → CIRC.
	55 DISJ.	あっ のISJ. POIES 1 3 つ CIPC 22	$f : \overline{G} : \overline{G} : DISJ.$ $f : \overline{G} : DISJ.$ $f : \overline{G} : POLES$ $f : \overline{G} : CIRC.$ $f : \overline{G} : DISJ.$ $f : \overline{G} : DISJ.$	$ \begin{array}{c} 120/208 \\ \hline 120/208 \\ \hline 3 - CIRC. \\ \hline 4 2 CIRC. \\ \hline 4 2 CIRC. \\ \hline 5 15 DISJ. \\ \hline 4 2 \\ \hline 4 2 \\ \hline 7 5 \\ 7 5 \\ \hline 7 5 \\$

gennese and	a constants	Nov surgests	Spraware	, www.ac	-	-	n (cominen	-	-	e, rue pro		
18000	ESPACE	ESPACE	ESPACE	ESPACE			10000			1	TOTAL WATTS	8
18000 C. TOT. : 34200 WAITS T. : 33 AMPS. BARRES : 100 AMPS.							P   51			AEROTHERME	W. NO. NO.	
200 W/	ALA PARTA PA										6	
ATTS											X	ranananananan ananan
												a sale contraction of the sale
.⊣ 					30 🎮 11	30	30	15	15	15	്നര	<u>a 7</u>
: 33 AMPS	19	17	ភែ	13	 	G	1	ير س	3		CļF	4C
3											AC	ω
MP	20	â	8		다	0	8	8	4	2		2C.
ŗ.,						5	15	20	20	2 1 20		SJ.
	Notice and the second sec										0	
BARR											X s	СПА
ES : 1						ALA	TO3			With the second s	63	CHARGES
BARRES : 100 AMPS,						ALARME DE NIVEAU	ECLAIRAGE INT./EXT			XFO T3	NO. NO. W.	RACCORDEES

	の時代を見たわり大きたけ	horn management		20 1			ALTERNATION COMPANY AND A CANADA	AND VALIDITIES IN AND INCOME.			
										FSDACE	
				<u>,</u>	17					ESPACE	
				8	15					ESPACE	
				14	13					ESPACE	
				12	30 2 11	2					
ALARME DE NIVEAU	ÅL			10 15	ن 0 9	3					
ECLAIRAGE INT./EXT	D3			а 15	42	- 3				10000	
					φ	-				10000	
						4					
				4 20	15 3						
XFO T3	Contraction of the second second			2 2 20	15 1				AEROTHERME		
SORTIES SPEC.	-63-	X s	đ				X	6	W. NO. NO.	WATTS	
	ADDRESS OF A CONTRACTOR OF A C	n Contraction and an and an an an an	or subcluster and the subcluster	7C 111 5J	Я Эс	() preservation	אורייניים אורייניער אירייניער אייריאיין	Anno Ministra Anno Man	A CONTRACTOR OF A CONTRACT	ofertre/	
RACCORDEES	RGES	CHAI		C. ES	ES		ES	CORDE	CHARGES RACCORDEES		
									BATIMENT #23	BATIMEN	
4		JP		<u>10 Y</u> .	347/600 <u>V</u>				PANNEAU : PDE-B23	PANNEA	
NY LANDAR NY TANÀNA MANGKANA AMIN'NA MANGKANA MANGKANA MANGKANA MANGKANA MANGKANA MANGKANA MANGKANA MANGKANA MA			NAME OF AVAILABLE AVAILABLE	NF Bandar Valation (States)	ner færske til stort ellered, skalt til færste som	A CONTRACTOR OF	The local second se		an and a subsection of the s		
	t										
	1										
		Ŕ									
		<u> A</u>									
	あいみわ ろういい ト										



		11	

1) POMPE D'IRRIGATION AU DIESEL RELOCALISEE PAR LA DIV DIESEL IRRAGATION PUMP RELOCALIZED BY SECTION 15.

сл Сл

LEGENDE

EGEND

÷.,

at y i

. .

•

(2)

POMPE INCENDIE DIESEL INSTALLEE PAR LA DIVISI DIESEL FIRE PUMP INSTALLED BY SECTION 15.

ION 15.

RESERVOIR DE DIESEL INSTALLE PAR LA DIVISION 15. DIESEL OIL TANK INSTALLED BY SECTION 15.

-B23-C9

\_3 #10 C:13n PDE-823

(L)

4 POMPE DE SURP BOUSTER PUMP

PRESSION INSTALLEE PAR LA DIVISION 15 A INSTALLED BY SECTION 15 TO CONNECT.

RACCO

Сл ACCUMULATEURS INSTALLES ET RACCORDES PAR LA DIVISION BATTERIES INSTALLED AND CONNECTED BY SECTION 15.  $\cdot$ ц Сл

ග CONTROLEUR POMPE INCENDIE INSTALLE PAR LA DIVISION 15 A RAFIRE PUMP CONTROLLER INSTALLED BY SECTION 15 TO CONNECT.

B23-C10

(-)RACO

CONTROLEUR POMPE DE SURPRESSION INSTALLE PAR LA DIVISION 15 A BOUSTER PUMP CONTROLLER INSTALLED BY SECTION 15 TO CONNECT.

8 PANNEAU INDICATEUR DE NIVEAU D'EAU DU RESERVOIR PREFILE EN USINE. VOIR DIAGRAMME LEVEL WATER TANK INDICATOR PANEL FACTORY ASSEMBLED. SEE DIAGRAM.


 $\bigcirc$ SONDE DE HAUT ET DE BAS NIVEAU D'EAU DECRI DIMSION 15 À RACCORDER. LEVEL DETECTOR SENSORS SPECIFIED BY SECTION TO CONNECT 15 15

10 INTERRUPTEUR MANOME A RACCORDER. PRESSURE SWITCH SPE IND BY ŝ RIT A LA DIVISION 15 SECTION 15 TO CONNECT

CENERATEUR DE SIGNAL ET HAUT-PARLEUR INTEGRE AVEC T PROGRAMMABLES. - UNE TONALTE POUR LE SIGNAL DE BAS NIVEAU - UNE TONALTE POUR LE SIGNAL DE HAUT NIVEAU SIGNAL GENERATOR AND INTEGRATED MONITOR WITH PROGRA UNES. - TUNE FOR LOW LEVEL - TUNE FOR HIGH LEVEL

ABLE


VUE EN PLAN PLAN VIEW





Appendix "F"

# **INSURANCE TERMS**



# **INSURANCE TERMS**

- IN1 GENERAL
- IN1.1 Worker's Compensation
- IN1.2 Indemnification
- IN1.3 Proof of Insurance
- IN1.4 Insured
- IN1.5 Payment of Deductible
- IN2 COMMERCIAL GENERAL LIABILITY
- IN2.1 Scope of Policy
- IN2.2 Period of Insurance
- IN3 AUTOMOBILE INSURANCE
- IN3.1 Scope of Policy
- IN4 BUILDER'S RISK / INSTALLATION FLOATER
- IN4.1 Scope of Policy
- IN4.2 Amount of Insurance
- IN4.3 Period of Insurance
- IN4.4 Insurance Proceeds

### IN1 GENERAL

### IN1.1 Worker's Compensation

 The Contractor shall provide and maintain Worker's Compensation Insurance in accordance with the legal requirements of the Province or Territory where the work is being carried out.

### IN1.2 Indemnification

 The insurance required by the provisions of these Insurance Terms shall in no way limit the Contractor's responsibility under the Indemnification clause of the General Conditions of the contract. Any additional coverage the Contractor may deem necessary to fulfill his obligations under the aforesaid clause shall be at his own discretion and expense.

### IN1.3 Proof of Insurance

- 1) Before commencement of the Work, and within thirty (30) days after acceptance of its bid, the Contactor shall deposit with Canada a CERTIFICATE OF INSURANCE (form AAFC / AAC5314) available upon request.
- 2) Upon request by Canada, the Contractor shall provide originals or certified true copies of all contracts of insurance maintained by the Contractor pursuant to the provisions contained herein.

### IN1.4 Insured

1) Each policy shall insure the Contractor and shall include Her Majesty the Queen in right of Canada, represented by the Minister of Agriculture & Agri-Food Canada as an additional Insured, with respect



### **INSURANCE TERMS (Continued)**

### IN1.5 Payment of Deductible

1) The payment of monies up to the deductible amount made in satisfaction of a claim shall be borne by the Contractor.

### IN2 COMMERCIAL GENERAL LIABILITY

### IN2.1 Scope of Policy

- 1) The insurance coverage provided shall not be less than that provided by IBC Form 2100, as amended from time to time, and shall have:
  - (a) an Each Occurrence Limit of not less than \$5,000,000.00;
  - (b) a Products/Completed Operations Aggregate Limit of not less than \$5,000,000.00 ; and
  - (c) a General Aggregate Limit of not less than \$10,000,000.00 per policy year, if the policy is subject to such a limit.
- 2) The policy shall either include or be endorsed to include coverage for the following exposures or hazards if the Work is subject thereto:
  - (a) Blasting.
  - (b) Pile driving and caisson work.
  - (c) Underpinning.
  - (d) Removal or weakening of support of any building or land whether such support be natural or otherwise if the work is performed by the insured contractor.
  - (e) Asbestos.
  - (f) Non-owed Automobile Policy.

# IN2.2 Period of Insurance

 Unless otherwise directed in writing by Canada, or, otherwise stipulated elsewhere herein, the policy required herein shall be in force and be maintained from the date of contract award until the day of issue of the Certificate of Completion except that the coverage for Completed Operations Liability shall, in any event, be maintained for a period of at least six (6) years beyond the date of the CERTIFICATE OF SUBSTANTIAL PERFORMANCE.

# IN3 AUTOMOBILE INSURANCE

### IN3.1 Scope of Policy

1) Automobile Liability Insurance in respect of licensed vehicles shall have limits of not less than one

### **INSURANCE TERMS (Continued)**

### IN4 BUILDER'S RISK / INSTALLATION FLOATER

### IN4.1 Scope of Policy

- 1) The insurance coverage provided by a Builder's Risk policy or an Installation Floater policy shall not be less than that provided by IBC Forms 4042 and 4047, as amended from time to time.
- 2) The policy shall permit use and occupancy of the project, or any part thereof, where such use and occupancy is for the purposes for which the project is intended upon completion.
- 3) The policy may exclude or be endorsed to exclude coverage for loss or damage caused by any of the following:
  - (a) Asbestos.
  - (b) Fungi or spores.
  - (c) Cyber.
  - (d) Terrorism.

#### IN4.2 Amount of Insurance

 The amount of insurance shall not be less than the sum of the contract value plus the declared value (if any) set forth in the contract documents of all material and equipment supplied by Canada at the site of the project to be incorporated into and form part of the finished Work. If the value of the Work is changed, the policy shall be changed to reflect the revised contract value.

### IN4.3 Period of Insurance

1) Unless otherwise directed in writing by Canada, or, stipulated elsewhere herein, the policy required herein shall be in force and be maintained from prior to the commencement of work until the day of issue of the CERTIFICATE OF SUBSTANTIAL PERFORMANCE.

### IN4.4 Insurance Proceeds

- 1) The policy shall provide that the proceeds thereof are payable to Her Majesty or as Canada may direct in accordance with
- 2) The Contractor shall, without delay, do such things and execute such documents as are necessary to effect payment of the proceeds.



Appendix "G"

# FORM A - SUBCONTRACTING



### FORM A –SUBCONTRACTING / SOUS-TRAITANCE

If there is to be no subcontracting, proposer must confirm it on this form and sign.

Si aucun sous-traitant ne sera utilisé, l'offrant doit le confirmer sur ce formulaire et le signer.

### Contractor's list of subcontractors

It is my/our intention to employ the following subcontractors whom I/we believe, following investigation, to be reliable and competent for the performance of the portion of services being subcontracted. All other services will be performed by me/us.

#### Liste des sous-traitants de L'entrepreneur

J'ai (nous avons) l'intention de faire appel aux sous-traitants suivants qui, je crois (nous croyons), après avoir effectué une enquête, sont dignes de confiance et compétents pour l'exécution des travaux sous-traités. Je (nous) assurerai tous les autres services.

Nom de l'entreprise / Name of company	Services donnés en sous-traitance/ Services to be subcontracted	Nombre d'années en association avec ce sous-traitant/Number of years that you are associated with that subcontractor	Nombre d'années d'expérience du sous-traitant dans ce domaine/Years of experience of subcontractor in the field	Portion du contrat (%) / Portion of the contract (%)

Je m'engage (nous nous engageons) à ne pas confier d'autres services en sous-traitance à des personnes ou à des sociétés, à moins d'obtenir l'autorisation écrite du ministre de l'Agriculture

It is agreed that I (we) shall not subcontract with any other individual or organization or for any other work, without the consent of the Minister of Agriculture

Name

Position

Signature

Date