



NCR, Materiel Management
200 Kent Street, Station 9W088
Ottawa, Ontario
K1A 0E6

FP802-140036

June 30, 2014

**Subject: REQUEST FOR PROPOSAL: FP802-140036
SERVICING SECURITY SYSTEMS INSTALLED AT FISHERIES AND
OCEANS CANADA BUILDING IN OTTAWA**

ADDENDUM NO. 2

Further to the above mentioned Request for Proposal documentation previously posted on the Government Electronic Tendering Site (GETS) Addendum (#2) is hereby issued

Question 1

Are there site visits planned to view the current security deployments at the three locations? If site walkthroughs are not to be permitted will installation drawings be provided indicating the location of security devices to be maintained?

Answer 1

Site visits to view the current security deployments at the three locations are not permitted. For security reasons, installation drawings indicating the location of security devices to be maintained will not be provided.

Question 2

The List of Equipment table with Section 6.1 within Appendix "C" is incomplete and is missing quantities of items; will this table be updated?

Answer 2

The List of Equipment table with Section 6.1 within Appendix "C" is incomplete in the English version for this RFP only. The updated List of Equipment table is as follows:

**LIST OF EQUIPMENT
200 KENT ST., 222 QUEEN ST. & 200 ELGIN**

DESCRIPTION	PART NO.	QUANTITY
KEYSCAN CA200	CA200	3
KEYSCAN CA4000	CQCA4100	17
KEYSCAN CA8000	CQCA8100	9
KEYSCAN EC1000	EC1000	1
MOTOROLA READERS	CQPX603	113
T-REXDET	T-REX-XL	111
1076 CONTACTS	1076H	115
RES 5000 DR. STRIKES	5000 RES	89
710 FOLGER ADAMS STRIKES	710	15
R.C.I. DOOR STRIKES	RUTHFORD 7114	7
HANDICAP CONTROLLERS	DOOR OPERATORS	102
HANDICAP BUTTONS	DOOR OPERATORS	204
CP 10 COM BOARD	CQCPB10	27



TRANSFORMERS	LEFTC3716	27
TRANSFORMERS	LM16V40VA	27
LAB CO. 3 AMP	POWER SUPPLIES	27
100 VAC POWER SUPPLY	APC SMART-UPS	1
LINE DRIVERS	ME760R2	4
KEYSCAN 7 V SOFTWARE	V5CLT	1
KEYSCAN 7 V PC	DELL SERVER PET 320	1
DVR	HONEYWELL	1
DVR	PELCO 7000	1
DVR	INTELLEX ULTRA	1
CAMERAS	PELCO	5
CAMERAS	AMERICAN DYNAMICS	23
MASTER POWER SUPPLY	PELCO	1
CARD PRINTER	FARGO DTC 550	1

Question 3

Is there a listing of spare equipment currently available to support your security installations?

Answer 3

There is no spare equipment on location.

All other Terms and Conditions for this requirement remain unchanged.

Yours truly,

Jianna-Lee Zomer

Senior Contracting Officer,
NCR Materiel Management, Materiel and Procurement Services