



REFRIGERATION EQUIPMENT	
TAG	DESCRIPTION
COND	CONDENSING UNIT SPECIFIED BY REFRIGERATION CONSULTANT. KEEPRITE EZ-LINE MODEL KEZ4020HB-1T3B, 5.1kw, 208/3/60, MOTOR 1.49kw, CONNECTION SIZES AT UNIT: LIQUID LINE - 10mm, SUCTION LINE - 22mm
EVAP	EVAPORATOR UNIT SPECIFIED BY REFRIGERATION CONSULTANT. KEEPRITE MODEL KLP214ME-S2B, 1349 L/s, 208/1/60, CONNECTION SIZES AT UNIT: DISTRIBUTOR - 13mm, SUCTION LINE - 22mm

MECHANICAL CONTRACTOR TO INSTALL ALL REFRIGERATION EQUIPMENT SPECIFIED BY THE REFRIGERATION CONSULTANT. PROVIDE INSULATED RS & RL PIPING c/w IDENTIFICATION SECURED TO THE BUILDING AND/OR FREEZER WALL PANEL STRUCTURE. DETERMINE REFRIGERATION PIPE SIZES BASED ON EQUIVALENT PIPING LENGTHS MEASURED ON-SITE.

AREA OF WORK

KEY PLAN

F.C. O'Neill Sorvan & Assoc's Limited
Consulting Engineers
5458
255, rue de la Loi, Suite 100, St-John's, NL A1B 4X6
Tel: (709) 576-1111 Fax: (709) 576-1112

4	RE-ISSUED FOR TENDER	JUN.24 2014
3	ISSUED FOR TENDER	JUN.13 2014
2	99% REVIEW	MAY.23 2014
1	99% REVIEW	MAY.05 2014
1	ISSUED FOR REVIEW	MAR. 31 2014

revisions

project

NEW FOOD STORAGE FREEZER CHILLED FOOD HOLDING SPRINGHILL INSTITUTION SPRINGHILL, NOVA SCOTIA

drawing

design

designed L.A.H.

date MARCH, 2014

drawn L.A.H.

date MARCH, 2014

approved G.S.M.

date MARCH, 2014

Tender

FWGSC Project Manager

Administrateur de projets TPSGC

no. du projet

R.061844.001

drawing no.

no. du dessin

H-3