

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Room 1650, 635 8th Ave. S.W.
Calgary
Alberta
T2P 3M3

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

For the purposes of this procurement, Canada is acting as AGENT for the British Army Training Unit Suffield.

Dans le cadre du présent marché, l'État agit en tant que REPRÉSENTANT de l'Unité d'entraînement de l'Armée britannique Suffield.

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Public Works and Government Services
Canada/Travaux publics et Services gouvernementaux
Canada
Room 1650, 635 8th Ave. S.W.
Calgary
Alberta
T2P 3M3

| | |
|---|--|
| Title - Sujet Exhaust Hoses | |
| Solicitation No. - N° de l'invitation W0142-15X021/A | Amendment No. - N° modif. 007 |
| Client Reference No. - N° de référence du client BATUS-W0142-15X021 | Date 2014-07-10 |
| GETS Reference No. - N° de référence de SEAG PW-\$CAL-097-6241 | |
| File No. - N° de dossier CAL-4-37018 (097) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-07-16 | Time Zone Fuseau horaire Mountain Daylight Saving Time MDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Levesque-Welch, Nicole | Buyer Id - Id de l'acheteur cal097 |
| Telephone No. - N° de téléphone (403) 292-4716 () | FAX No. - N° de FAX (403) 292-5786 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|---|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

This amendment is being raised to answer questions submitted in response to solicitation number W0142-15X021/A:

Q1: The following question was submitted in response to the answer provided under Amendment 004, question 15. Regarding the "Running" exhaust details, is 3.53 M³/S accurate? I ask the question only because it is an extremely large amount of exhaust air for an 8" diameter flexible exhaust hose. Will the hoses actually see this condition? An 8" diameter exhaust hose would normally be good for roughly 0.471 M³/S

A1: The figures were taken from the design of the equipments installed 5 years ago and it's requested that the proposed pipes remain at 8 inches in diameter, as specified.

Q2: As per the answer provided in Amendment 004, are the hose reels existing or will they be procured through another tender notice?

A2: Hose reels are already installed on site.