

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

Title - Sujet Culvert Replacement	
Solicitation No. - N° de l'invitation EZ899-150534/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client	Date 2014-07-15
GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7274	
File No. - N° de dossier PWY-4-37063 (019)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-07-29	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY)	Buyer Id - Id de l'acheteur pwy019
Telephone No. - N° de téléphone (604) 658-2755 ()	FAX No. - N° de FAX (604) 775-6633
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - North Testa River Bridge Culvert No. 5 - Km597.2 Alaska Highway, BC	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Please find following Solicitation Amendment 001 (Addendum No. 1).

All other terms and conditions remain unchanged.

This Solicitation Amendment 001 is raised to provide response to questions received.

Q1.) Can we get clearer drawings for the project? The ones included with the tender documents are scans and we can't make out some of the dimensions of the bevel in Detail P Concrete End Treatment, as well as other details.

A1.) Please refer to Attachment File: EZ899-150534 Drawings Sheet 1-3.pdf

Q2.) Can you confirm the live loading is CL-625-ONT and the structure required service life?

A2.) Please refer to attached Addendum No. 1.

***The following changes/clarifications in the tender documents are effective immediately.
This Addendum will form part of the Contract documents.***

1. Minimum service life of Bridge Culvert: Seventy-five (75) years.
2. Live Loading: CL – 625 - ONT

End of Addendum No.1