

**RETURN BIDS TO:**  
**RETOURNER LES SOUMISSIONS À:**  
Bid Receiving Public Works and Government  
Services Canada/Réception des soumissions Travaux  
publics et Services gouvernementaux Canada  
Room 100,  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6  
Bid Fax: (204) 983-0338

## SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise  
indicated, all other terms and conditions of the Solicitation  
remain the same.

Ce document est par la présente révisé; sauf indication contraire,  
les modalités de l'invitation demeurent les mêmes.

### Comments - Commentaires

Vendor/Firm Name and Address  
Raison sociale et adresse du  
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution  
Public Works and Government Services Canada -  
Western Region  
Room 100  
167 Lombard Ave.  
Winnipeg  
Manitoba  
R3B 0T6

<b>Title - Sujet</b> Sleeper Trailers	
<b>Solicitation No. - N° de l'invitation</b> 5P414-140002/A	<b>Amendment No. - N° modif.</b> 004
<b>Client Reference No. - N° de référence du client</b> 5P414-140002	<b>Date</b> 2014-07-16
<b>GETS Reference No. - N° de référence de SEAG</b> PW-\$WPG-016-9040	
<b>File No. - N° de dossier</b> WPG-4-37049 (016)	<b>CCC No./N° CCC - FMS No./N° VME</b>
<b>Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-08-05</b>	<b>Time Zone</b> Fuseau horaire Central Daylight Saving Time CDT
<b>F.O.B. - F.A.B.</b> <b>Plant-Usine:</b> <input type="checkbox"/> <b>Destination:</b> <input checked="" type="checkbox"/> <b>Other-Autre:</b> <input type="checkbox"/>	
<b>Address Enquiries to: - Adresser toutes questions à:</b> Hall, Marlene	<b>Buyer Id - Id de l'acheteur</b> wpg016
<b>Telephone No. - N° de téléphone</b> (204) 984-6423 ( )	<b>FAX No. - N° de FAX</b> (204) 983-7796
<b>Destination - of Goods, Services, and Construction:</b> <b>Destination - des biens, services et construction:</b>	

Instructions: See Herein

Instructions: Voir aux présentes

<b>Delivery Required - Livraison exigée</b>	<b>Delivery Offered - Livraison proposée</b>
<b>Vendor/Firm Name and Address</b> <b>Raison sociale et adresse du fournisseur/de l'entrepreneur</b>	
<b>Telephone No. - N° de téléphone</b> <b>Facsimile No. - N° de télécopieur</b>	
<b>Name and title of person authorized to sign on behalf of Vendor/Firm</b> <b>(type or print)</b> <b>Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)</b>	
<b>Signature</b>	<b>Date</b>

This **amendment # 004** is raised to respond to Bidder's question.

The following information shall henceforth form part of the solicitation and should be considered when preparing response submissions.

- 
- Q1**     2. Construction: it states the ceiling and outside walls are to be insulated with R40. R-40 is not possible within a 6" wall. In section 4 (exterior walls), it states 6" walls are required. Since this isn't possible with R-40 insulation, is R-20 insulation in the 6" walls acceptable?
- A1**     Yes
- Q2**     3. Floors: We would be using Floor Joists of 2 x 6", which is adequate strength for this size and type of unit. The steel skid below the unit will have cross members running width wise on skid, as well as lengthwise, providing extra support. Is this considered adequate?
- A2**     Yes
- Q3**     4. Exterior Walls: You ask for 12" eave. With the rubber roof we do not provide or require an eave. Is this acceptable?
- A3**     Yes
- Q4**     5. Roof/Ceiling: Our roof will be covered with 0.45 mil EPDM rubber roofing with 20 year guarantee, R-20 insulation with 2" peaked roof, no gables. Is this acceptable?
- A4**     Yes
- Q5**     6. Bedrooms: you require 40 w covered light. We want to supply 1-4' fluorescent light in each bedroom and 1 wall mounted reading lamp. Is this acceptable?
- A5**     Yes
- Q6**     6. Bedrooms: bedroom windows will be 46" x 34" h to meet building code. They will have a sliding pane on half of the window. Is this acceptable?
- A6**     Yes
- Q7**     7. Bathroom: you ask for 2 x 60W lights. We would offer 1 x 4' fluorescent tubes and tri light fixtures above each sink. Is this acceptable?
- A7**     Yes
- Q8**     8. Hallway: (a) The drawing shows 3 windows but specs state 4 windows. Please clarify windows required. (b) Ceiling lighting: you ask for 4 x 40W bulbs. We offer 4 x 4' fluorescent tubes along hallway. Is this acceptable?
- A8**     (a) 4 windows (b) Yes
- Q9**     9. Electrical: (a) 2 - 500W heaters per room may be required due to available wall space

being limited. Is this acceptable? (b) Exterior lights at each entrance will be in recessed light boxes instead of under soffits (no soffits on unit). Is this acceptable?

**A9** (a) Yes (b) Yes

**Q10** 10. Doors and Windows: (a) Please provide after market a/c unit sizes in order to confirm if they will fit in the code window of 46 x 34 slider windows. (b) Storm doors will not be provided. Is this acceptable? (c) Exterior doors are prefinished and therefore do not require painting and will be white. Is this acceptable?

**A10** (a) Yes (b) Yes (c) Yes

**Q11** Unit will be built to meet or exceed part 10 of the Alberta building specifications. Is this Acceptable?

**A11** Yes

**ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME**