

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Room 100,
167 Lombard Ave.
Winnipeg
Manitoba
R3B 0T6
Bid Fax: (204) 983-0338

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Western Region
Room 100
167 Lombard Ave.
Winnipeg
Manitoba
R3B 0T6

Title - Sujet Sleeper Trailers	
Solicitation No. - N° de l'invitation 5P414-140002/A	Amendment No. - N° modif. 005
Client Reference No. - N° de référence du client 5P414-140002	Date 2014-07-23
GETS Reference No. - N° de référence de SEAG PW-\$WPG-016-9040	
File No. - N° de dossier WPG-4-37049 (016)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-08-05	Time Zone Fuseau horaire Central Daylight Saving Time CDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Hall, Marlene	Buyer Id - Id de l'acheteur wpg016
Telephone No. - N° de téléphone (204) 984-6423 ()	FAX No. - N° de FAX (204) 983-7796
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

This **amendment # 005** is raised to respond to Bidder's question.

The following information shall henceforth form part of the solicitation and should be considered when preparing response submissions.

Q1 Item 9. Electrical: you are asking for: hardwired electric baseboard heating with wall mounted (or control can be on heater) thermostats in each room including the bathroom and hallway (800 - 1,000W). Also under windows you ask that we accommodate for window air conditioners for all 6 rooms. Our request is: in lieu of baseboard and future window air conditioners would you consider going with an electric furnace and air conditioner with ducts in the structure? It would also come with fresh air return (as per the Building code). If you go electric you will require as a minimum a hallway fan to move air around. It would also be cost effective to do this vs 6 window air conditioners, 6 thermostats, 16 electric wall heaters and a fan running 24/7.

A1 Canada does not require an electric furnace and air conditioner with ducts. The sleeper trailers will be used for short term accommodations, approximately 4 months, during the summer months. A/C units are not required.

ALL OTHER TERMS AND CONDITIONS REMAIN THE SAME