

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
Pacific Region
401 - 1230 Government Street
Victoria, B.C.
V8W 3X4
Bid Fax: (250) 363-3344

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
401 - 1230 Government Street
Victoria, B. C.
V8W 2Z4

Title - Sujet Steel Breakwater Pontoon	
Solicitation No. - N° de l'invitation F1571-145006/A	Amendment No. - N° modif. 001
Client Reference No. - N° de référence du client F1571-145006	Date 2014-07-23
GETS Reference No. - N° de référence de SEAG PW-\$XLV-211-6506	
File No. - N° de dossier XLV-4-37048 (211)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-08-18	Time Zone Fuseau horaire Pacific Daylight Saving Time PDT
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Buchan, Torrey	Buyer Id - Id de l'acheteur xlv211
Telephone No. - N° de téléphone (250) 363-3249 ()	FAX No. - N° de FAX (250) 363-3960
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction:	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Solicitation No. - N° de l'invitation

F1571-145006/A

Amd. No. - N° de la modif.

001

Buyer ID - Id de l'acheteur

xlv211

Client Ref. No. - N° de réf. du client

F1571-145006

File No. - N° du dossier

XLV-4-37048

CCC No./N° CCC - FMS No/ N° VME

This page is intentionally left blank.

QUESTION & ANSWER – SOLICITATION F1571-145006/A

Q1:

In regards to the Styrofoam billets are you looking for that exact shape as indicated on the drawings or can these billets be cut square with the corners shaved to get the 65% fill?

A1:

Foam must conform to 65% of the cross sectional area, not more than three pieces per cross section.

Q2)

In regards to the requirement for fresh water fill; do we assume that the amount of fresh water is to full capacity of the compartments minus the 65% of foam fill?

A2:

Fresh water fill is not part of this contract.

Q3)

In Note 2 and 3 of Drawing A1 it references Drawing 56120-310-5 detail B. This drawing did not come with the package.

A3:

This drawing was provided at page 5 of 8 of Annex A, Requirement.

Q4)

In Annex A, section 3.4 b., it states Interseal or approved alternate. I would just like to confirm that you will be 100% open to alternate products as Interseal is pretty much the highest cost product out there and not necessarily the best.

A4:

Alternates must be approved by the Technical Authority before use.

Q5)

I cannot find the thickness of the 42" or the 30" pipe sections. I assume 1/2" but want to be sure.

A5:

The 42" and 30" pipe sections must be a ½ inch in thickness.

Q6)

At the end of the pontoons there is a 152 * 152 HSS but there is not thickness listed.

A6:

The HSS 152 x 152 must be a ½ inch in thickness.

Q7)

There are a large amount of anode plates to be installed on the pontoon but no mention of actually supplying the anode. Will this be part of the tender?

A7:

Anode supply and installation is not part of this contract

Q8)

Are Creosoted timbers acceptable materials for use in the Construction of the Optional Deck Portion of the Pontoon?

A8:

Section 3.6a identifies acceptable materials for deck construction

Q9)

Would the Department of Fisheries & Oceans consider allowing the steel supplier to provide a bolted Splice plate connection at the centre of the breakwater to facilitate easier launching of the float?

A9:

No, this is not considered acceptable by DFO.

Q10)

Are the 30" and 42" cross tubes filled with 65% foam as well?

A10:

No, they are not filled with foam.