

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving Public Works and Government
Services Canada/Réception des soumissions Travaux
publics et Services gouvernementaux Canada
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British Columbia
V6Z 0B9
Bid Fax: (604) 775-9381

SOLICITATION AMENDMENT
MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise
indicated, all other terms and conditions of the Solicitation
remain the same.

Ce document est par la présente révisé; sauf indication contraire,
les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Public Works and Government Services Canada -
Pacific Region
800 Burrard Street, Room 219
800, rue Burrard, pièce 219
Vancouver
British C
V6Z 0B9

| | |
|---|--|
| Title - Sujet Replacement Salt Shed | |
| Solicitation No. - N° de l'invitation EZ899-150376/C | Amendment No. - N° modif. 001 |
| Client Reference No. - N° de référence du client | Date 2014-07-25 |
| GETS Reference No. - N° de référence de SEAG PW-\$PWY-019-7287 | |
| File No. - N° de dossier PWY-4-37043 (019) | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-07-30 | Time Zone Fuseau horaire Pacific Daylight Saving Time PDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Ngan, Ken (PWY) | Buyer Id - Id de l'acheteur pwy019 |
| Telephone No. - N° de téléphone (604) 658-2755 () | FAX No. - N° de FAX (604) 775-6633 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC - Fireside Maintenance Camp - Km839 Alaska Highway, BC | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

Solicitation No. - N° de l'invitation

EZ899-150376/C

Client Ref. No. - N° de réf. du client

Amd. No. - N° de la modif.

001

File No. - N° du dossier

PWY-4-37043

Buyer ID - Id de l'acheteur

pw019

CCC No./N° CCC - FMS No/ N° VME

Les documents français seront disponibles sur demande.

Please find following Addendum No. 1.

All other terms and conditions remain unchanged.

The following changes in the tender documents are effective immediately. This addendum will form part of the contract documents.

SPECIFICATIONS

.1 Sketches at the end of Specifications


- (1) **Replace** ESK-1 with the sketch included in this addendum.

.2 Section 26 05 00 – Common Works Results-Electrical

Clause 1.6 Lighting:

- (1) **Replace:** Entire clause with the following:
 - “1. Provide provisions – conduit and junction boxes only – for future interior and exterior lighting installation. Refer to ESK-1 for details.
 2. Install pull string in all conduit runs.
 3. Installation of all conduit and junction boxes, in both interior and exterior of the building, shall be in accordance with clause 1.8 – Wiring Methods.
 4. Provide cover plate for all junction boxes suitable for the installation.”

END OF ADDENDUM No. 1



ESK-1