



RETURN BIDS TO:

RETOURNER LES SOUMISSIONS Á:

**Parks Canada Agency
P.O. Box 900
100 Hawk Avenue
Banff, Alberta T1L 1K2
Bid Fax: (403) 762-5057**

AMENDMENT TO
INVITATION TO TENDER
APPEL D'OFFRES

Tender To: Parks Canada Agency
We hereby offer to sell to Her Majesty the Queen in right of Canada, in accordance with the terms and conditions set out herein, referred to herein or attached hereto, the goods, services, and construction listed herein and on any attached sheets at the price(s) set out therefore.

Soumission aux: l'Agence Parcs Canada
Nous offrons par la présente de vendre à Sa Majesté la Reine du Chef du Canada, aux conditions énoncées ou incluses par référence dans la présente et aux annexes ci-jointes, les biens, services et construction énumérés ici et sur toute feuille ci-annexée, au(x) prix indiqué(s).

Comments - Commentaries

Issuing Office - Bureau de distribution

Parks Canada Agency
Banff Field Unit
P.O. Box 900
Banff Alberta T1L 1K2

Title-Sujet Cascade River Pedestrian Bridge		Date July 25, 2014
Solicitation No. - No. de l'invitation 5P421-15-0033	Amendment No. 003	
Solicitation Closes L'invitation prend fin – at – á 02:00 PM on – le July 30, 2014	Time Zone Fuseau horaire - Mountain Time	
F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/>		
Address Inquiries to: - Adresser toute demande de renseignements à : Rose Marino		
Telephone No. - No de téléphone (403) 760-1319	Fax No. – No de FAX: (403) 762-5057	
Destination of Goods, Services, and Construction: Destinations des biens, services et construction: See Herein		
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur		
Name and title of person authorized to sign on behalf of the Vendor/Firm Nom et titre de la personne autorisée a signer au nom du fournisseur/ de l'entrepreneur		
Signature		Date



Amendment 003

Questions and Answers

Q1. What are the Specs for the Allan Blocks and is there a supplier that Parks uses for these?

A1. The Allan Blocks shall be AB Classic, AB Limestone, AB Caps and AB corner blocks as specified on the Drawings. Further requirements are included in Section 32 32 34 "Reinforced Concrete Block Retaining Wall" of the Specifications. Expocrete Concrete Products Ltd. based in Balzac Alberta is the closest licenced supplier of Allan Block products to the project site. Please contact Jeaneen Galas at 403 470 9826.

Q2. It is mentioned in the paper work about sample testing for material characteristics, for the aluminium are the mill certificates showing this information ok in this case to avoid tab testing of the aluminium?

A2. Mill certificates with material characteristics included would be acceptable for the aluminum supply.

Q3. Aluminium HSS sections on the bridge, are they meant to all be square corner HSS sections or does radius corner work as well?

A3. Square HSS sections were anticipated. Corner radii less than or equal to 3mm would be acceptable.