

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Bid Receiving - PWGSC / Réception des soumissions
- TPSGC
11 Laurier St./11 rue Laurier
Place du Portage, Phase III
Core 0A1 / Noyau 0A1
Gatineau, Québec K1A 0S5

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

THIS DOCUMENT CONTAINS A SECURITY
REQUIREMENT /
CE DOCUMENT CONTIENT UNE EXIGENCE
EN MATIÈRE DE SÉCURITÉ.

Project no. R.052598.506 - N° de projet
R.052598.506

Vendor/Firm Name and Address

Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution

Construction Services Division/Division des services de
construction
11 Laurier St./11 Rue Laurier
3C2, Place du Portage
Phase III
Gatineau, Québec K1A 0S5

| | |
|--|--|
| Title - Sujet Big Chaudiere Dam Replacement | |
| Solicitation No. - N° de l'invitation EP731-150139/A | Amendment No. - N° modif. 004 |
| Client Reference No. - N° de référence du client 20150139 | Date 2014-07-30 |
| GETS Reference No. - N° de référence de SEAG PW-\$\$\$FG-345-65290 | |
| File No. - N° de dossier fg345.EP731-150139 | CCC No./N° CCC - FMS No./N° VME |
| Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-08-07 | Time Zone Fuseau horaire Eastern Daylight Saving Time EDT |
| F.O.B. - F.A.B. Plant-Usine: <input type="checkbox"/> Destination: <input type="checkbox"/> Other-Autre: <input type="checkbox"/> | |
| Address Enquiries to: - Adresser toutes questions à: Nealon, Shawn | Buyer Id - Id de l'acheteur fg345 |
| Telephone No. - N° de téléphone (819) 956-3391 () | FAX No. - N° de FAX (819) 956-8335 |
| Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: PWGSC, Big Chaudiere Dam, French River, Dokis, Ontario. - TPSGC Barrage Big Chaudière, La Rivière des Français, Dokis, Ontario. | |

Instructions: See Herein

Instructions: Voir aux présentes

| | |
|--|--|
| Delivery Required - Livraison exigée | Delivery Offered - Livraison proposée |
| Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur | |
| Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur | |
| Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie) | |
| Signature | Date |

**THIS AMENDMENT IS BEING RAISED TO ANSWER QUESTIONS SUBMITTED BY
POTENTIAL BIDDERS**

QUESTION:

The drawing C003 state that existing dams has to be completely demolished. Is this includes all below the water level structure also or there is a part to be left in place? (ex. Base slab, foundation, part of abutment walls).

If yes, would we be able to work in a dewatered area? (ex. Temporary upstream cofferdam) Technical specification are not detailed on what it means "completely demolished" and on the method. Please clarify.

RESPONSE:

Bid as per plans and specification. Refer to Drawing C003 and to the related demolition notes shown on this drawing.

CLARIFICATION:

Complete demolition means demolition of the entire structures.

Bid as per plans and specification. Refer to section 02 41 16 – Structure Demolition, article 1.4.

CLARIFICATION:

Contractor is responsible to determine sequence and process for demolition.

QUESTION:

The drawing E004 is showing a new overhead 7.2kv line to be built and bell line to move. However, there are not any technical specification and detailed scope of work for this part of the job:

- Specifications only for 0-1000V
- Type of poles
- Conductor size
- Communication line characteristics

Please specify if these work are part of our scope of work. If yes, please provide necessary details and specifications.

Solicitation No. - N° de l'invitation

EP731-150139/A

Amd. No. - N° de la modif.

004

Buyer ID - Id de l'acheteur

fg345

Client Ref. No. - N° de réf. du client

20150139

File No. - N° du dossier

fg345EP731-150139

CCC No./N° CCC - FMS No/ N° VME

RESPONSE: 2.

Bid as per plans and specification. Refer to Drawing E001 showing the single line diagram. All the 7.2kV work is by HONI (Hydro One). Existing lines are HONI lines (Hydro One). Existing 7.2kV equipment will be relocated by HONI (Hydro One). The connection to the electrical building is by the Contractor.