

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1 SECTION 01 29 00 – PAYMENT PROCEDURES

Items covered under LUMP SUM AMOUNT (LSA) of the Bid Form include:

- .1 General Requirements (Spec Ref: 013218-017800);
- .2 Disinfection, Testing and Commissioning (Spec Ref: 331116);
- .3 Metering Vault (including stainless steel piping and accessories up to and including the isolation valves, Spec Ref: 331116)

2 SECTION 01 54 70 – FACILITY ACCESS REQUIREMENTS

1.1.3 – Replace “Immediately upon award of the contract,”

With “Within 48 hours of a Letter of Award,”

1.2.3 – Replace “Immediately upon award of the contract,”

With “Within 48 hours of a Letter of Award,”

3 SECTION 33 11 16 – SITE WATER UTILITY DISTRIBUTION PIPING

Add the following:

2.5.2 Check Valve

.1 Construction:

.1 Wafer style, dual disk check valve to AWWA C518.

.2 Materials:

.1 Body: Ductile Iron

.2 Disc: Bronze to ASTM B584

.3 Seats: Bronze and Buna-N

.4 Spring: Stainless Steel

.3 Coatings:

.1 Valve exterior and interior, that is not stainless steel, to be coated with an ANSI/NSF 61 epoxy coating approved for potable water.

.4 Manufacturers:

.1 Val-Matic

.2 APCO

4 Drawing C-109

- .1 Replace Drawing C-109 with Drawing C-109 Rev 1 attached.

END OF ADDENDUM NO. 1