

**1**  
BASEMENT  
EXISTING + DEMOLITION  
M100 SCALE: 1:50


### DRAWING NOTES

- EXISTING PUMPS P-6 (PARTIALLY DEMOLISHED), P-7, AND P-8 TO BE DEMOLISHED. NEW PUMPS TO BE INSTALLED IN-PLACE. PHASING TO BE UTILIZED TO ELIMINATE DOWNTIME FOR FEEDWATER SYSTEM. REFER TO PROPOSED PHASING ON DRAWING M400.
- DEMOLISH EXISTING THERMAL FLUID PIPING BACK TO HEADER AND CAP REMAINING STUB. THERMAL FLUID FROM DEMOLISHED PIPING IS TO BE DRAINED AND CAPTURED IN EXISTING THERMAL FLUID STORAGE TANKS ON-SITE.
- DEMOLISH EXISTING CONDENSATE PIPING, COMPLETE WITH ALL SUPPORTS AND ACCOUTREMENTS. CAP AND STUB WHERE INDICATED, AS WELL AS AT CONNECTION TO THERMAL FLUID BOILER #1.
- DEMOLISH EXISTING PIPING FROM STEAM GENERATORS #2 AND #3 (PREVIOUSLY REMOVED) BACK TO BLOWDOWN HEADER AND CAP REMAINING STUB.
- DEMOLISH EXISTING STEAM GENERATOR #2 COMPLETE WITH ALL PIPING, SUPPORTS, AND ACCOUTREMENTS. HOUSEKEEPING PAD TO BE DEMOLISHED, AND FLOOR MADE GOOD UPON COMPLETION OF DEMOLITION.
- DEMOLISH EXISTING THERMAL FLUID PUMP #2 COMPLETE WITH ALL PIPING, SUPPORTS, AND ACCOUTREMENTS. HOUSEKEEPING PAD TO BE DEMOLISHED, AND FLOOR MADE GOOD UPON COMPLETION OF DEMOLITION.
- DEMOLISH EXISTING THERMAL FLUID BOILER #2 COMPLETE WITH ALL PIPING, SUPPORTS, AND ACCOUTREMENTS. HOUSEKEEPING PAD TO BE DEMOLISHED, AND FLOOR MADE GOOD UPON COMPLETION OF DEMOLITION.
- EXISTING THERMAL FLUID BASEMENT STORAGE TANK ASSEMBLY TO REMAIN, INCLUDING TANKS, PUMPS, AND PIPING NETWORK.
- EXISTING OBSOLETE FUEL OIL PIPING TO BE DEMOLISHED THROUGH CEILING, COMPLETE WITH ALL SUPPORTS AND ACCOUTREMENTS. CEILING TO BE MADE GOOD UPON COMPLETION OF DEMOLITION.
- EXISTING CONDENSATE RECEIVER AND ASSOCIATED SUPPORTS, PIPING, AND ACCOUTREMENTS TO REMAIN.
- EXISTING BLOWDOWN TANK, COMPLETE WITH ALL SUPPORTS AND ACCOUTREMENTS, TO REMAIN.
- EXISTING FEEDWATER PIPING TO FEEDWATER PUMPS P-6, P-7, AND P-8 TO REMAIN.
- EXISTING BUILDING DOMESTIC WATER SUPPLY TO REMAIN.
- EXISTING THERMAL FLUID BOILER #1 AND ASSOCIATED SUPPORTS, PIPING, AND ACCOUTREMENTS TO REMAIN.
- EXISTING STEAM GENERATOR #1 AND ASSOCIATED SUPPORTS, PIPING, AND ACCOUTREMENTS TO REMAIN.
- EXISTING THERMAL FLUID LOOP #1 PUMP AND ASSOCIATED SUPPORTS, PIPING, AND ACCOUTREMENTS TO REMAIN.
- DEMOLISH EXISTING THERMAL FLUID EXPANSION LOOP PIPING, COMPLETE WITH ALL SUPPORTS AND ACCOUTREMENTS. PIPING IS TO BE CAPPED AT STORAGE TANKS IN BASEMENT AND DEMOLISHED THROUGH CEILING. CEILING TO BE MADE GOOD UPON COMPLETION OF WORK. EXISTING BASEMENT VENT STORAGE TANKS ARE TO BE DEMOLISHED.
- DEMOLISH EXISTING DOMESTIC COLD WATER PIPING IN TRENCH AND CAP WHERE INDICATED. PIPING IS TO BE DEMOLISHED UP TO THERMAL FLUID PUMP #2.
- DEMOLISH EXISTING DOMESTIC COLD WATER PIPING IN TRENCH AND CAP WHERE INDICATED. PIPING IS TO BE DEMOLISHED UP TO FORMER LOCATION OF THERMAL FLUID PUMP #3.
- CAP EXISTING DROPS AFTER COMPLETION OF PUMP DEMOLITION. REFER TO M400 FOR PHASING.
- EXISTING CONDENSATE TRANSFER PUMPS P-1 AND P-2 BELOW CONDENSATE TANK TO BE DEMOLISHED. NEW PUMPS TO BE INSTALLED ADJACENT TO CONDENSATE TANK. REFER TO NEW INSTALLATION LOCATION ON M200.

### GENERAL NOTES

- CONTRACTOR IS RESPONSIBLE FOR DEMOLISHING ALL EXISTING UNUSED HANGERS ON-SITE.
- ALL HANGERS REMOVED FROM SITE ARE TO BE DEMOLISHED UP TO ANCHOR POINT.
- REFER TO DRAWINGS M300, M301, AND M302 FOR SCHEMATICS.

 Public Works and  
Government Services Canada  
Architectural and Engineering Services  
Ontario Region  
  
Travaux publics et  
Services gouvernementaux Canada  
Services d'architecture et de génie  
Région de l'Ontario



revision	description	date
01	ISSUED FOR ADDENDUM 1	2014/08/08
00	ISSUED FOR TENDER	2014/07/24
0A	ISSUED FOR 99% REVIEW	2014/05/22

Do not scale drawings.  
Verify all dimensions and conditions on site and  
immediately notify the engineer of all discrepancies.

A	Detail No.
B	No. du detail
C	drawing no. - where detail required dessin no. - où détail exigé
	drawing no. - where detailed dessin no. - où détaillé

project title  
titre du projet  
**OTTAWA** ONTARIO  
CLIENT  
560 KING STREET,  
KINGSTON, K7L 4V7  
**KINGSTON PENITENTIARY  
HEATING PLANT UPGRADE**

drawing title  
titre du dessin  
**BASEMENT  
PIPING  
DEMOLITION**

drawn by  
dessiné par  
**PATRICK BOURGEOIS**

designed by  
conçu par  
**CARY MCGEE, P.ENG**

approved by  
approuvé par  
**CARY MCGEE, P.ENG**

tender  
soumission  
**DUNCAN PARKER, P.ENG.**

project manager  
administrateur  
de projets

project date  
date du projet  
**2014/04/07**

project no.  
no. du projet  
**R.068125.001**

drawing no.  
dessin no.  
**M100**