

CONTRACT ADDENDUM**Old Chelsea Picnic Area New Pedestrian
Bridge and Trail****Tender file no. NG274****August 14, 2014****ADDENDUM No. 1**

The following shall be read in conjunction with and shall form an integral part of the Tender / Proposal and Contract Documents:

QUESTIONS / ANSWERS

Q1 Can we propose an equivalent in aluminum for the prefabricated bridge?

A1 *No, prefabricated bridge must be composed of "Corten" steel.*

ADDENDA AU CONTRAT**Nouveau pont piétonnier et sentier – Aire
de pique-nique Old Chelsea****Dossier de soumission no. NG274****Le 14 août 2014****ADDENDA no. 1**

Ce qui suit doit être interprété comme faisant partie intégrante de la proposition/appel d'offres et des documents relatifs au contrat :

QUESTIONS / RÉPONSES

Q1 Pouvons-nous proposer un équivalent en aluminium pour le pont préfabriqué?

R1 *Non, le pont préfabriqué doit être composé d'acier « Corten »*

Nicole Galipeau *NGalipeau*
Senior Contract Officer | Agent principal aux contrats
Procurement Services | Services de l'approvisionnement