


GENERAL NOTES:

1. PROVIDE THE DESIGN AND INSTALLATION METHOD SPRINKLER SYSTEM FOR "AREA OF WORK" IN ACCORDANCE WITH NFPA 13-2013 AND LOCAL CODES. PROVIDE SPRINKLER HEADS WITH LITERS OF ASSURANCE. REFER TO SPECIFICATIONS.
2. EXISTING SPRINKLER HEADS ARE SHOWN ON DRAWING. UNLESS OTHERWISE NOTED, REDUCATE EXISTING HEADS AND ADD ADDITIONAL HEADS TO MATCH EXISTING AS REQUIRED.
3. MODIFY EXISTING PIPING LAYOUT AND RE-ROUTE EXISTING PIPING AS REQUIRED TO ACCOMMODATE INSTALLATIONS OF MECHANICAL/ELECTRICAL SERVICES AND EQUIPMENT. COORDINATE WITH OTHER TRADES.
4. PROVIDE NEW, CONCEALED SPRINKLER HEADS IN ROOM ABOVE "INMATE ELEVATOR STORAGE". REVIEW ARCHITECTURAL DRAWINGS FOR EXISTING SPRINKLER HEADS AND SHELVE UNITS (92.5" AFF). PROVIDE ADEQUATE SPRINKLER COVERAGE (92.5" AFF). PROVIDE ADEQUATE SPRINKLER COVERAGE AND INSTALL BATTERIES WHERE REQUIRED TO MAINTAIN 2.743m (9'-0") CEILING HEIGHT. COORDINATE WITH GENERAL CONTRACTOR.
5. BUILDING OCCUPANCY IS LIGHT HAZARD EXCEPT AS NOTED BELOW:
 - MECHANICAL ROOMS. ORDINARY HAZARD GROUP -1.
 - STORAGE ROOMS. ORDINARY HAZARD GROUP -1.
6. INSTALL HANGERS AT 2.440 O.C. ON ALL PILING 2.440 AFF OR LOWER.
7. ARCHITECTURAL SELECTED CEILING PLAN, LIGHTING AND DUCTWORK LAYOUTS ARE SHOWN FOR REFERENCE ONLY. CONFORM WITH DRAWINGS BY OTHERS.
8. ALLOW FOR CUTTING AND PATCHING.



5			
4			
3			
2			
1			
0	ISSUED FOR TENDER	2014-04-25	
Requester/ Client/ client	Description/Description	Date/Date	

**CORRECTIONAL
SERVICE OF
CANADA**

Project title/Titre du projet

AGASSIZ, B.C.

**KENT INSTITUTION
A AND D
REDEVELOPMENT**

Consultant Signature Box Only

Designed by/Concept par

Drawn by/Dessine par
M. NG / 2013.08.09

PWGSC Project Manager/Administrateur de Projets TPSCC

DAVID SINGAR, Regional Manager, Architectural and Engineering Services/

gestionnaire régionale, Services d'architecture et de génie, INFAC
OREST KLUFAS

Drawing title/Titre du dessin

PARTIAL MAIN FLOOR PLAN RENOVATION - FIRE PROTECTION

Project No./No. du projet	Sheet/ Feuille	Revision no./ La Révision no.
R.018361.001	F-1	0

PAGSC - B1 - 1000X707

DM5XXXXXX