

PART 1 - GENERAL

1.1 SUBMITTALS

- .1 Submittals: in accordance with Section 01 33 00 - Shop Drawings, Product Data and Samples.
- .2 Shop drawings; submit drawings stamped and signed by professional engineer registered or licensed in Province of BC, Canada.
- .3 Shop drawings and product data accompanied by:
 - .1 Detailed drawings of bases, supports, and anchor bolts.
 - .2 Manufacturer to certify current model production.
 - .3 Certification of compliance to applicable codes.
- .4 In addition to transmittal letter referred to in Section 01 33 00 - Shop Drawings, Product Data and Samples: use MCAC "Shop Drawing Submittal Title Sheet". Identify section and paragraph number.
- .5 Closeout Submittals:
 - .1 Provide operation and maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.
 - .2 Approvals:
 - .1 Submit 2 copies of draft Operation and Maintenance Manual to Departmental Representative for approval. Submission of individual data will not be accepted unless directed by Departmental Representative.
 - .2 Make changes as required and re-submit as directed by Departmental Representative.
 - .3 Additional data:
 - .1 Prepare and insert into operation and maintenance manual additional data when need for it becomes apparent during specified demonstrations and instructions.
 - .4 Site records:
 - .1 Departmental Representative will provide 1 set of reproducible mechanical drawings. Provide sets of white prints as required for each phase of work. Mark changes as work progresses and as changes occur. Include changes to existing mechanical systems, control systems and low voltage control wiring.
 - .2 Transfer information weekly to reproducibles, revising reproducibles to show work as actually installed.
 - .3 Use different colour waterproof ink for each service.
 - .4 Make available for reference purposes and inspection.
 - .5 As-built drawings:
 - .1 Identify each drawing in lower right hand corner in letters at least 12 mm high as follows: - "AS BUILT DRAWINGS: THIS DRAWING HAS BEEN REVISED TO SHOW MECHANICAL SYSTEMS AS INSTALLED" (Signature of Contractor) (Date).
 - .2 Submit to Departmental Representative for approval and make corrections as directed.
 - .3 Perform testing, adjusting and balancing for HVAC using as-built drawings.
 - .4 Submit completed reproducible as-built drawings with Operating and Maintenance Manuals.
 - .6 Submit copies of as-built drawings for inclusion in final TAB report.

1.2 QUALITY ASSURANCE

- .1 Health and Safety Requirements: do construction occupational health and safety in accordance with Section 01 35 33 - Health and Safety Requirements.

1.3 MAINTENANCE

- .1 Furnish spare parts in accordance with Section 01 78 00 - Closeout Submittals as follows:
 - .1 One set of packing for kitchen sink..

1.4 DELIVERY, STORAGE, AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Construction/Demolition Waste Management and Disposal: separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

Not Used

PART 3- EXECUTION

3.1 PAINTING REPAIRS AND RESTORATION

- .1 Prime and touch up marred finished paintwork to match original.
- .2 Restore to new condition, finishes which have been damaged.

3.2 CLEANING

- .1 Clean interior and exterior of all systems including strainers.

3.3 FIELD QUALITY CONTROL

- .1 Site Tests: conduct following tests in accordance with Section 01 11 55 – General Instructions and submit report as described in PART 1 - SUBMITTALS.
- .2 Manufacturer's Field Services:
 - .1 Obtain written report from manufacturer verifying compliance of Work, in handling, installing, applying, protecting and cleaning of product and submit Manufacturer's Field Reports as described in PART 1 - SUBMITTALS.
 - .2 Provide manufacturer's field services consisting of product use recommendations and periodic site visits for inspection of product installation in accordance with manufacturer's instructions.
 - .3 Schedule site visits, to review Work, as directed in PART 1 - QUALITY ASSURANCE.

3.4 PROTECTION

- .1 Protect equipment and systems openings from dirt, dust, and other foreign materials with materials appropriate to system.

END OF SECTION

PART 1 - GENERAL

1.1 SECTION INCLUDES

- .1 Materials and installation for copper domestic water service used in the following:
 - .1 Copper incoming domestic water service, up to NPS 2 1/2.
 - .2 Hard drawn copper domestic hot and cold water services inside building.
 - .3 Soft copper tubing inside building.

1.2 RELATED SECTIONS

- .1 Section 01 33 00 - Shop Drawings, Product Data and Samples.
- .2 Section 01 74 21 - Construction/Demolition Waste Management And Disposal.
- .3 Section 02 81 01 - Hazardous Materials.
- .4 Section 01 35 33 - Health and Safety Requirements.
- .5 Section 01 78 00 - Closeout Submittals.
- .6 Section 21 05 01 - Common Work Results for Mechanical.
- .7 Section 23 05 01 - Installation of Pipework.
- .8 Section 23 05 23.01 - Valves - Bronze.

1.3 REFERENCES

- .1 American National Standards Institute (ANSI)/American Society of Mechanical Engineers International (ASME).
 - .1 ANSI/ASME B16.15-02, Cast Bronze Threaded Fittings, Classes 125 and 250.
 - .2 ANSI/ASME B16.18-01, Cast Copper Alloy Solder Joint Pressure Fittings.
 - .3 ANSI/ASME B16.22-01, Wrought Copper and Copper Alloy Solder Joint Pressure Fittings.
 - .4 ANSI/ASME B16.24-01, Cast Copper Alloy Pipe Flanges and Flanged Fittings, Class 150, 300, 400, 600, 900, 1500 and 2500.
- .2 American Society for Testing and Materials International, (ASTM).
 - .1 ASTM A307-03, Standard Specification for Carbon Steel Bolts and Studs, 60,000 PSI Tensile Strength.
 - .2 ASTM B88M-03, Standard Specification for Seamless Copper Water Tube (Metric).
 - .3 ASTM F492-95, Standard Specification for Propylene and Polypropylene (PP) Plastic-Lined Ferrous Metal Pipe and Fittings.
- .3 American Water Works Association (AWWA).
 - .1 AWWA C111-00, Rubber-Gasket Joints for Ductile-Iron Pressure Pipe and Fittings.
- .4 Canadian Standards Association (CSA International).
 - .1 CSA B242-M1980(R1998), Groove and Shoulder Type Mechanical Pipe Couplings.
- .5 Department of Justice Canada (Jus).

- .1 Canadian Environmental Protection Act, 1999, c. 33 (CEPA).
- .6 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .7 Manufacturer's Standardization Society of the Valve and Fittings Industry (MSS).
 - .1 MSS-SP-67-02, Butterfly Valves.
 - .2 MSS-SP-70-98, Cast Iron Gate Valves, Flanged and Threaded Ends.
 - .3 MSS-SP-71-97, Cast Iron Swing Check Valves, Flanged and Threaded Ends.
 - .4 MSS-SP-80-03, Bronze Gate, Globe, Angle and Check Valves.
- .8 National Research Council (NRC)/Institute for Research in Construction.
 - .1 NRCC 38728, National Plumbing Code of Canada (NPC) - 1995.
- .9 Transport Canada (TC).
 - .1 Transportation of Dangerous Goods Act, 1992, c. 34 (TDGA).

1.4 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Shop Drawings, Product Data and Samples.
- .2 Submit product data for following: valves.
- .3 Provide maintenance data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals.

1.5 HEALTH AND SAFETY

- .1 Do construction occupational health and safety in accordance with Section 01 35 33 - Health and Safety Requirements.

1.6 WASTE MANAGEMENT AND DISPOSAL

- .1 Separate waste materials for reuse and recycling in accordance with Section 01 74-21 - Construction/Demolition Waste Management and Disposal.
- .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
- .3 Separate for reuse and recycling and place in designated containers. Steel Metal/Plastic waste in accordance with Waste Management Plan.
- .4 Place materials defined as hazardous or toxic in designated containers.
- .5 Handle and dispose of hazardous materials in accordance with CEPA , TDGA , Regional and Municipal regulations.
- .6 Fold up metal banding, flatten and place in designated area for recycling.

PART 2- PRODUCTS

2.1 PIPING

- .1 Domestic hot, cold and recirculation systems, within building.

- .1 Above ground: copper tube, hard drawn, type K: to ASTM B88M.

2.2 FITTINGS

- .1 Bronze pipe flanges and flanged fittings, Class 150 and 300: to ANSI/ASME B16.24.
- .2 Cast bronze threaded fittings, Class 125 and 250: to ANSI/ASME B16.15.
- .3 Cast copper, solder type: to ANSI/ASME B16.18.
- .4 Wrought copper and copper alloy, solder type: to ANSI/ASME B16.22.

2.3 JOINTS

- .1 Rubber gaskets, latex-free 1.6 mm thick: to AWWA C111.
- .2 Bolts, nuts, hex head and washers: to ASTM A307, heavy series.
- .3 Solder: 95/5 tin copper alloy.
- .4 Teflon tape: for threaded joints.
- .5 Grooved couplings: designed with angle bolt pads to provide rigid joint, complete with EPDM flush seal gasket.
- .6 Dielectric connections between dissimilar metals: dielectric fitting to ASTM F492, complete with thermoplastic liner.

2.4 GATE VALVES

- .1 NPS 2 and under, soldered:
 - .1 Rising stem: to MSS-SP-80, Class 125, 860 kPa, bronze body, screw-in bonnet, solid wedge disc as specified Section 23 05 23.01 - Valves - Bronze.
- .2 NPS 2 and under, screwed:
 - .1 Rising stem: to MSS-SP-80, Class 125, 860 kPa, bronze body, screw-in bonnet, solid wedge disc as specified Section 23 05 23.01 - Valves - Bronze.
- .3 NPS2 and under, soldered:
 - .1 To MSS-SP-80, Class 125, 860 kPa, bronze body, renewable composition disc, screwed over bonnet as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 Lockshield handles: as indicated.
- .4 NPS 2 and under, screwed:
 - .1 To MSS-SP-80, Class 150, 1 MPa, bronze body, screwed over bonnet, renewable composition disc as specified Section 23 05 23.01 - Valves - Bronze.
 - .2 Lockshield handles: as indicated.

2.5 BALL VALVES

- .1 NPS 2 and under, screwed:
 - .1 Class 150.

- .2 Bronze body, chrome plated brass stainless steel ball, PTFE adjustable packing, brass gland and PTFE BunaN seat, steel lever handle as specified Section 23 05 23.01 - Valves - Bronze.
- .2 NPS 2 and under, soldered:
 - .1 To ANSI/ASME B16.18, Class 150.
 - .2 Bronze body, chrome plated brass stainless steel ball, PTFE adjustable packing, brass gland and PTFE BunaN seat, steel lever handle, with NPT to copper adaptors as specified Section 23 05 23.01 - Valves - Bronze.

PART 3- EXECUTION

3.1 INSTALLATION

- .1 Install in accordance with COV Plumbing Code.
- .2 Install pipe work in accordance with Section 23 05 01 - Installation of Pipework, supplemented as specified herein.
- .3 Assemble piping using fittings manufactured to ANSI standards.
- .4 Install CWS piping below and away from HWS and HWC and other hot piping so as to maintain temperature of cold water as low as possible.
- .5 Connect to fixtures and equipment in accordance with manufacturer's written instructions unless otherwise indicated.

3.2 VALVES

- .1 Isolate equipment, fixtures and branches with gate butterfly ball valves.
- .2 Balance recirculation system using lockshield globe valves. Mark settings and record on as-built drawings on completion.

3.3 PRESSURE TESTS

- .1 Conform to requirements of Section 21 05 01 - Common Work Results for Mechanical.
- .2 Test pressure: greater of 1 times maximum system operating pressure or 860 kPa.

3.4 FLUSHING AND CLEANING

- .1 Flush entire system for 8 h. Ensure outlets flushed for 2 h. Let stand for 24 h, then draw one sample off longest run. Submit to testing laboratory to verify that system is clean copper to Provincial Federal potable water guidelines. Let system flush for additional 2 h, then draw off another sample for testing.

3.5 PRE-START-UP INSPECTIONS

- .1 Systems to be complete, prior to flushing, testing and start-up.
- .2 Verify that system can be completely drained.
- .3 Ensure that pressure booster systems are operating properly.

- .4 Ensure that air chambers, expansion compensators are installed properly.

3.6 DISINFECTION

- .1 Flush out, disinfect and rinse system to requirements of authority having jurisdiction approval of Departmental Representative.
- .2 Upon completion, provide laboratory test reports on water quality for Departmental Representative approval.

3.7 START-UP

- .1 Timing: Start up after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Certificate of static completion has been issued.
 - .4 Water treatment systems operational.
- .2 Provide continuous supervision during start-up.
- .3 Start-up procedures:
 - .1 Establish circulation and ensure that air is eliminated.
 - .2 Check pressurization to ensure proper operation and to prevent water hammer, flashing and/or cavitation.
 - .3 Bring HWS storage tank up to design temperature slowly.
 - .4 Monitor piping HWS and HWC piping systems for freedom of movement, pipe expansion as designed.
 - .5 Check control, limit, safety devices for normal and safe operation.
- .4 Rectify start-up deficiencies.

3.8 PERFORMANCE VERIFICATION

- .1 Timing:
 - .1 After pressure and leakage tests and disinfection completed, and certificate of completion has been issued by authority having jurisdiction.
- .2 Procedures:
 - .1 Verify that flow rate and pressure meet Design Criteria.
 - .2 TAB HWC in accordance with Section 23 05 93 - Testing, Adjusting and Balancing for HVAC.
 - .3 Adjust pressure regulating valves while withdrawal is maximum and inlet pressure is minimum.
 - .4 Sterilize HWS and HWC systems for Legionella control.
 - .5 Verify performance of temperature controls.
 - .6 Verify compliance with safety and health requirements.
 - .7 Check for proper operation of water hammer arrestors. Run one outlet for 10 seconds, then shut of water immediately. If water hammer occurs, replace water hammer arrestor or re-charge air chambers. Repeat for outlets and flush valves.
 - .8 Confirm water quality consistent with supply standards, verifying that no residuals remain as a result of flushing and/or cleaning.

.3 Reports:

- .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: Reports, using report forms as specified in Section 01 91 13 - General Commissioning (Cx) Requirements: Report Forms and Schematics.
- .2 Include certificate of water flow and pressure tests conducted on incoming water service, demonstrating adequacy of flow and pressure.
- .3 Materials and resources.
- .4 Storage and collection of recyclables.
- .5 Construction waste management.
- .6 Resource reuse.
- .7 Local/regional materials.
- .8 Low-emitting materials.

3.9 OPERATION REQUIREMENTS

- .1 Cleaning materials and schedules.
- .2 Repair and maintenance materials and instructions.

END OF SECTION

PART 1 - GENERAL

1.1 SUMMARY

- .1 Section Includes:
 - .1 Materials and installation for plumbing specialties and accessories.
 - .2 Sustainable requirements for construction and verification.
- .2 Related Sections:
 - .1 Section 01 32 17 - Construction Progress Schedule - Critical Path Method (CPM).
 - .2 Section 01 33 00 - Shop Drawings, Product Data and Samples.
 - .3 Section 01 35 33 - Health and Safety Requirements.
 - .4 Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .5 Section 01 78 00 - Closeout Submittals.
 - .6 Section 01 91 13 - General Commissioning (Cx) Requirements.
 - .7 Section 02 81 01 - Hazardous Materials.

1.2 REFERENCES

- .1 American Society for Testing and Materials International (ASTM).
 - .1 ASTM A126-95(2001), Specification for Gray Iron Castings for Valves, Flanges and Pipe Fittings.
 - .2 ASTM B62-02, Specification for Composition Bronze or Ounce Metal Castings.
- .2 American Water Works Association (AWWA).
 - .1 AWWA C700-02, Cold Water Meters-Displacement Type, Bronze Main Case.
 - .2 AWWA C701-02, Cold Water Meters-Turbine Type for Customer Service.
 - .3 AWWA C702-1-01, Cold Water Meters-Compound Type.
- .3 Canadian Standards Association (CSA International).
 - .1 CSA-B64 Series-01, Backflow Preventers and Vacuum Breakers.
 - .2 CSA-B79-94(R2000), Floor, Area and Shower Drains, and Cleanouts for Residential Construction.
 - .3 CSA-B356-00, Water Pressure Reducing Valves for Domestic Water Supply Systems.
- .4 Health Canada/Workplace Hazardous Materials Information System (WHMIS).
 - .1 Material Safety Data Sheets (MSDS).
- .5 Plumbing and Drainage Institute (PDI).
 - .1 PDI-G101-96, Testing and Rating Procedure for Grease Interceptors with Appendix of Sizing and Installation Data.
 - .2 PDI-WH201-92, Water Hammer Arresters Standard.

1.3 SUBMITTALS

- .1 Submittals in accordance with Section 01 33 00 - Shop Drawings, Product Data and Samples.

- .2 Product Data:
 - .1 Submit manufacturer's printed product literature, specifications and datasheet for fixtures and equipment.
 - .2 Indicate dimensions, construction details and materials for specified items.
- .3 Shop Drawings:
 - .1 Submit shop drawings to indicate materials, finishes, method of anchorage, number of anchors, dimensions construction and assembly details and accessories for following: soap dispensing system.
- .4 Certificates: submit certificates signed by manufacturer certifying that materials comply with specified performance characteristics and physical properties.
- .5 Instructions: submit manufacturer's installation instructions.
- .6 Closeout submittals: submit maintenance and engineering data for incorporation into manual specified in Section 01 78 00 - Closeout Submittals, include:
 - .1 Description of plumbing specialties and accessories, giving manufacturers name, type, model, year and capacity.
 - .2 Details of operation, servicing and maintenance.
 - .3 Recommended spare parts list.

1.4 QUALITY ASSURANCE

- .1 Pre-Installation Meetings:
 - .1 Convene pre-installation meeting one week prior to beginning work of this Section and on-site installations in accordance with Section 01 32 17 – Construction Progress Schedule – Critical Path Method (CPM).
 - .1 Verify project requirements.
 - .2 Review installation and substrate conditions.
 - .3 Co-ordination with other building subtrades.
 - .4 Review manufacturer's installation instructions and warranty requirements.
- .2 Health and Safety:
 - .1 Do construction occupational health and safety in accordance with Section 01 35 33 - Health and Safety Requirements.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Waste Management and Disposal:
 - .1 Separate waste materials for reuse and recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.
 - .2 Remove from site and dispose of packaging materials at appropriate recycling facilities.
 - .3 Collect and separate for disposal paper plastic polystyrene corrugated cardboard packaging material in appropriate on-site bins for recycling in accordance with Waste Management Plan.
 - .4 Divert unused metal materials from landfill to metal recycling facility as approved by Departmental Representative Engineer Consultant.
 - .5 Fold up metal and plastic banding, flatten and place in designated area for recycling.

PART 2 - PRODUCTS

2.1 WATER HAMMER ARRESTORS

- .1 Stainless steel Copper construction, bellows type: to PDI-WH201.

PART 3- EXECUTION

3.1 MANUFACTURER'S INSTRUCTIONS

- .1 Compliance: comply with manufacturer's written recommendations or specifications, including product technical bulletins, handling, storage and installation instructions, and data sheet.

3.2 INSTALLATION

- .1 Install in accordance with National Plumbing Code of Canada.
- .2 Install in accordance with manufacturer's instructions and as specified.

3.3 CLEANOUTS

- .1 Install cleanouts at base of soil and waste stacks, and rainwater leaders, at locations required code, and as indicated.
- .2 Bring cleanouts to wall or finished floor unless serviceable from below floor.
- .3 Building drain cleanout and stack base cleanouts: line size to maximum NPS4.

3.4 START-UP

- .1 General:
 - .1 In accordance with Section 01 91 13 - General Commissioning (Cx) Requirements: General Requirements, supplemented as specified herein.
- .2 Timing: start-up only after:
 - .1 Pressure tests have been completed.
 - .2 Disinfection procedures have been completed.
 - .3 Certificate of static completion has been issued.
 - .4 Water treatment systems operational.
- .3 Provide continuous supervision during start-up.

3.5 TESTING AND ADJUSTING

- .1 General:
 - .1 In accordance with Section 01 91 13- General Commissioning (Cx) Requirements: General Requirements, supplemented as specified.
- .2 Timing:
 - .1 After start-up deficiencies rectified.
 - .2 After certificate of completion has been issued by authority having jurisdiction.
- .3 Application tolerances:

- .1 Pressure at fixtures: +/- 70 kPa.
- .2 Flow rate at fixtures: +/- 20%.
- .4 Access doors:
 - .1 Verify size and location relative to items to be accessed.
- .5 Cleanouts:
 - .1 Verify covers are gas-tight, secure, yet readily removable.
- .6 Water hammer arrestors:
 - .1 Verify proper installation of correct type of water hammer arrester.

END OF SECTION

PART 1 - GENERAL

1.1 RELATED REQUIREMENTS

1.2 REFERENCES

- .1 Canadian Standards Association (CSA International)
 - .1 CAN/CSA-B45 Series-02(R2008), Plumbing Fixtures.
 - .2 CAN/CSA-B125.3-0], Plumbing Fittings.
 - .3 CAN/CSA-B651-04, Accessible Design for the Built Environment.

1.3 ACTION AND INFORMATIONAL SUBMITTALS

- .1 Provide submittals in accordance with Section 01 33 00 - Submittal Procedure.
- .2 Product Data:
 - .1 Provide manufacturer's printed product literature and datasheets for fixtures, and include product characteristics, performance criteria, physical size, finish and limitations.

1.4 CLOSEOUT SUBMITTALS

- .1 Provide maintenance data in accordance with Section 01 78 00 - Closeout Submittals.
- .2 Include:
 - .1 Description of fixtures and trim, giving manufacturer's name, type, model, year, capacity.
 - .2 Details of operation, servicing, maintenance.
 - .3 List of recommended spare parts.

1.5 DELIVERY, STORAGE AND HANDLING

- .1 Deliver, store and handle in accordance with Section 01 61 00 - Common Product Requirements.
- .2 Deliver materials to site in original factory packaging, labelled with manufacturer's name, address.
- .3 Packaging Waste Management: remove for reuse and return of padding and packaging materials] in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

PART 2 - PRODUCTS

2.1 MANUFACTURED UNITS

- .1 Fixtures: manufacture in accordance with CAN/CSA-B45 series.
- .2 Trim, fittings: manufacture in accordance with CAN/CSA-B125.
- .3 Exposed plumbing brass to be chrome plated.

- .4 Number, locations: architectural drawings to govern.
- .5 Fixtures to be product of one manufacturer.
- .6 Trim to be product of one manufacturer.
- .7 Service sinks:
 - .1 KS-1 : double compartment, ledge back:
 - .1 From 1.0 mm thick type 302 stainless steel, self-rimming, undercoated, clamps. Overall sizes: 740 x 420 x 200 mm.
 - .2 Trim: chrome plated brass, with swing spout, aerator, single lever handle, washerless controls, accessories to limit maximum flow rate to 8.35 litres/minute at 413 kPa, spray fitting.
 - .3 Single lever faucet, with escutcheon, swing spout, lever handle, deluxe pull-out spray with adjustable spray pattern and lock & turn activation button, chrome plated solid brass, mechanical water mixing valve, bronze body, temperature adjusting dial.
 - .4 Waste fitting: integral stainless steel basket strainer/stopper, tailpiece, cast brass P-trap with cleanout.
- .8 Fixture piping:
 - .1 Hot and cold water supplies to each fixture:
 - .1 Chrome plated flexible supply pipes each with handwheel stop, reducers, escutcheon.
 - .2 Waste:
 - .1 Brass P trap with clean out on each fixture not having integral trap.
 - .2 Chrome plated in all exposed places.

PART 3- EXECUTION

3.1 APPLICATION

- .1 Manufacturer's Instructions: comply with manufacturer's written recommendations, including product technical bulletins, handling, storage and installation instructions, and datasheets.

3.2 INSTALLATION

- .1 Mounting heights:
 - .1 Standard: to comply with manufacturer's recommendations unless otherwise indicated or specified.
 - .2 Physically handicapped: to comply with most stringent of either NBCC or CAN/CSA-B651.

3.3 ADJUSTING

- .1 Conform to water conservation requirements specified this section.
- .2 Adjustments:
 - .1 Adjust water flow rate to design flow rates.

- .2 Adjust pressure to fixtures to ensure no splashing at maximum pressures.
- .3 Checks:
 - .1 Aerators: operation, cleanliness.
 - .2 Vacuum breakers, backflow preventers: operation under all conditions.
 - .3 Wash fountains: operation of flow-actuating devices.
- .4 Thermostatic controls:
 - .1 Verify temperature settings, operation of control, limit and safety controls.

3.4 CLEANING

- .1 Clean in accordance with Section 01 11 55 – General Instructions.
 - .1 Remove surplus materials, excess materials, rubbish, tools and equipment.
- .2 Waste Management: separate waste materials for recycling in accordance with Section 01 74 21 - Construction/Demolition Waste Management and Disposal.

END OF SECTION