

RETURN BIDS TO:
RETOURNER LES SOUMISSIONS À:
Regional Manager/Real Property
Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

SOLICITATION AMENDMENT MODIFICATION DE L'INVITATION

The referenced document is hereby revised; unless otherwise indicated, all other terms and conditions of the Solicitation remain the same.

Ce document est par la présente révisé; sauf indication contraire, les modalités de l'invitation demeurent les mêmes.

Comments - Commentaires

Vendor/Firm Name and Address
Raison sociale et adresse du
fournisseur/de l'entrepreneur

Issuing Office - Bureau de distribution
Regional Manager/Real Property Contracting/PWGSC
Ontario Region, Tendering Office
12th Floor, 4900 Yonge Street
Toronto, Ontario
M2N 6A6
Ontario

Title - Sujet Collins Bay Inst. Landfill Closure	
Solicitation No. - N° de l'invitation EQ447-150709/A	Amendment No. - N° modif. 003
Client Reference No. - N° de référence du client R.058456.004	Date 2014-08-21
GETS Reference No. - N° de référence de SEAG	
File No. - N° de dossier PWL-4-37038 (030)	CCC No./N° CCC - FMS No./N° VME
Solicitation Closes - L'invitation prend fin at - à 02:00 PM on - le 2014-08-26	
Time Zone Fuseau horaire Eastern Daylight Saving Time EDT	
F.O.B. - F.A.B.	
Plant-Usine: <input type="checkbox"/> Destination: <input checked="" type="checkbox"/> Other-Autre: <input type="checkbox"/>	
Address Enquiries to: - Adresser toutes questions à: Cowieson, Jim	Buyer Id - Id de l'acheteur pwl030
Telephone No. - N° de téléphone (416) 512-5829 ()	FAX No. - N° de FAX (416) 512-5862
Destination - of Goods, Services, and Construction: Destination - des biens, services et construction: CSC Collins Bay Institution 1455 Bath Road Kingston, ON K7M 7W9	

Instructions: See Herein

Instructions: Voir aux présentes

Delivery Required - Livraison exigée	Delivery Offered - Livraison proposée
Vendor/Firm Name and Address Raison sociale et adresse du fournisseur/de l'entrepreneur	
Telephone No. - N° de téléphone Facsimile No. - N° de télécopieur	
Name and title of person authorized to sign on behalf of Vendor/Firm (type or print) Nom et titre de la personne autorisée à signer au nom du fournisseur/ de l'entrepreneur (taper ou écrire en caractères d'imprimerie)	
Signature	Date

Questions and Answers

Q:

Section 31.32.19.10 – GCL Liner:

Specifications instruct contractor to install GCL as per manufacturer's instructions. However, the GCL will have to be installed on rough waste. Will contractor be required to place and grade material to install GCL on smooth surface as per manufacturer's instructions?

If so, could the existing soil on top of LF1 be stockpiled, then used as a grading layer under the GCL?

A:

Unless otherwise directed by the Departmental Representative, the contractor shall utilize only existing waste material from Landfill 3 as the fill material for Landfill 1.

Please refer to Specification Section 31.23.33.01, subsection 3.10 on page 14, and Specification section 31.32.19.02 subsection 3.2 on page 4.

The above requirements should ensure that a relatively smooth surface is utilized. Although not required by the specification, surface material stripped from Landfill 1 during scarification would also be permitted to be stockpiled and used to assist in the preparation of the smooth surface. If the contractor elects to do this however, associated costs should be incorporated in their pricing and not listed as a separate line item.

Q:

Upon consultation with Utilities Kingston the hydro pole on Front Road is owned by Hydro One. Hydro One will not respond to requests for pole relocation quotes in a timely fashion. Is it possible to have this item covered under a cash allowance?

A:

This item is expected to be part of lump sum cost. It is the contractor's responsibility to coordinate with the utilities company for the relocation of the guy wire to ensure timely delivery of work.