

The following changes to the tender documents are effective immediately and will form part of the contract documents:

1.1 CHANGES TO Drawings

.1 Drawing H-2 of 7, DECK REPAIRS CONSTRUCTION DETAILS

- .1 Delete all references to measurement "230 x 150 x 610 LG SPACERS @ 1905 O/C (TYP)" and replace with "203 x 150 x 610 LG SPACERS @ 1905 O/C (TYP)".

Questions

Can you provide any extra depth information for the harbour to aid in determining silt curtain installation point and sizes?

Response – The mouth of the harbour was dredged to an approximate depth of 215.0m (max) in winter 2014. Note that the contractor must allow boat traffic to move in and out of the harbour until October 31, 2014.

**END OF ADDENDUM**